

Air Permeability Test Certificate



This is to certify that the following test and results have been produced in compliance with England and Wales regulation 43 of the Building Regulations 2010, Scotland Section 6 of the Domestic and Non-Domestic Handbook, Northern Ireland Technical Booklet and Isle of Man The Building Control (Approved Documents) Order 2014. A full report in line with the current approved procedures can be requested from the iATS tester.

Unique Certificate Number

10211645

Test Method

Blower Door

Date of Test

22nd October 2021

Building name / Plot number

Plot 34

Building Address

Clarksville Farm, Crumpsall,

r^2 (Correlation ≥ 0.98 - ≤ 1.00)

0.9974

n (Slope ≥ 0.5 - ≤ 1.0)

0.604

Envelope Area of Building m^2

250

Report Reference

Tester's Name

Matthew Holland

Company Name

Complete Sustainability Solutions

iATS Tester No.

0563

Tester's level of competence

Level 2: Buildings > 4000m³

Related party disclosure

No related party

Signed

A handwritten signature in black ink, appearing to read 'M. Holland', is written over a white rectangular background.

Independent Airtightness Testing Scheme
16 St Johns Business Park,
Lutterworth,
Leicestershire, LE17 4HB

e: certificate@iats-uk.org

t: 0300 688 0016

w: iats-uk.org

Company Registration No: 09309058

	Calculated at 50 PA
Air permeability $m^3(h.m^2)$	5.49
Air change rate (1/h)	N/A