


Notes

1. This drawing to be read in conjunction with all mechanical, electrical & public health drawings for this contract.
2. All services work to be carried out in accordance with the relevant Engineering Specification for this contract.
3. Emergency exit signage indicative. Final locations and setting out to be confirmed with BCO and subject to alterations as part of Cat B fit out



A	LDL Millie Linear Suspended Direct LED Luminaire with Opal Diffuser. 1690mm length. "E" denotes emergency version
A1	LDL Millie Linear Suspended Direct LED Luminaire with Opal Diffuser. 1130mm length. "E" denotes emergency version
A2	LDL Millie Linear Suspended Direct LED Luminaire with Opal Diffuser. 1410mm length. "E" denotes emergency version
A3	LDL Millie Linear Suspended Direct LED Luminaire with Opal Diffuser. 1690mm length. "E" denotes emergency version
A4	LDL Millie Linear Suspended Direct LED Luminaire with Opal Diffuser. 2250mm length. "E" denotes emergency version
A5	LDL Millie Linear Suspended Direct LED Luminaire with Opal Diffuser. 2810mm length. "E" denotes emergency version
A6	LDL Millie Linear Suspended Direct LED Luminaire with Opal Diffuser. 3370mm length. "E" denotes emergency version
D1 O D1E	Delta Light Entro recessed IP44 downlight with wide (45°) beam. "E" denotes emergency version
D2 O D2E	Delta Light Diro recessed downlight. "E" denotes emergency version
D3 O D3E	Delta Light Entro recessed IP20 downlight with wide (45°) beam. "E" denotes emergency version
D4 O D4E	LDL Lighting Felix adjustable recessed downlight. "E" denotes emergency version
	LDL LED tape

- | | | |
|---|----|--|
|  | P1 | Architectural feature pendant (details to be confirmed) |
|  | P2 | Architectural feature pendant (details to be confirmed) |
|  | W1 | Architectural feature wall light (details to be confirmed)
For use in lift lobby and circulation spaces |
|  | W2 | Delta Light Montur feature wall light. "E" denotes emergency version |
|  | W3 | Architectural feature wall light (details to be confirmed)
For use in Lounge |
|  | W4 | Architectural feature wall light (details to be confirmed)
For use in TBC |
|  | S1 | LDL WP2 surface mounted linear LED IP66 luminaire with glass fibre body & opal polycarbonate diffuser. "E" denotes emergency version |
|  | S1 | LDL WP2 wall mounted linear LED IP66 luminaire with glass fibre body & opal polycarbonate diffuser. "E" denotes emergency version |
|  | | Delta Light magnetic track lighting system |
|  | T1 | Delta Light LED Line OK ADM linear track light |
|  | T2 | Delta Light Spot 52/66 spot light |
|  | X1 | Existing wall-mounted uplight to be refurbished with new LED and DALI drivers |
|  | X2 | Existing suspended luminaire to be refurbished with new LED and DALI drivers |

- | | |
|---|---|
| E1 | LDL LED3 recessed emergency LED with open area optic |
| E2 | LDL LED3 recessed emergency LED with corridor optic |
| E3 | LDL TR2 surface mounted emergency LED with open area optic |
| E4 | LDL TR2 surface mounted emergency LED with corridor optic |
| E4E | LDL LD5S emergency external bulkhead |
| EXIT | Emergency exit sign with ISO legend |
| 5A | 5amp round-pin socket outlet for lamps to be served from lighting control system |
| Lighting connection point | Lighting connection point for illuminated / heated mirror |
| Indicative containment routes | Indicative containment routes for lighting (refer to 4000 series drawings for further details of containment) |
| ACC | Lighting control system area controller |
| WCM | Lighting control system hard wired lighting control module |
| Single gang, single way | Recessed light switch (single gang, single way) |
| Single gang, two way | Surface light switch (single gang, single way) |
| Surface light switch | Surface light switch (single gang, two way) |
| Lighting control scene plate | Lighting control scene plate |
| Recessed presence detector | Recessed presence detector with photocell & IR receiver |
| Surface mounted presence detector | Surface mounted presence detector with photocell & IR receiver |
| Denotes temporary mains rated presence detector | Denotes temporary mains rated presence detector |



hilsonmoran.com

info@hilsonmoran.com

Client

Bruntwood

Project

38-42 Mosley Street Grade 2* Listed Building
Cat A Refurbishment

Drawing Title

Electrical Services
Roof Level Lighting, Emergency Lighting &
Lighting Controls Layout

Scale 1:100	Sheet Size A1	Checked ARM	Approved TAR
Status			HM Project No.
RIBA Stage 4 Tender Drawing			27618
Drawing No. 27618-HM-ZZ-RF-DR-ES-2205			Rev. P02