




PLAN UPPER DECK

Supply:
 Size: Non-standard
 Airflow: 10.14 m³/s
 E.S.P.: 300 Pa
 Coil Vel: 2.29 m/s
 Exhaust:
 Size: Non-standard
 Airflow: 10.14 m³/s
 E.S.P.: 300 Pa
 Coil Vel: 2.29 m/s
 Unit Wgt: 4163.33 kg

Section A:

S.No	Module	Length(mm)
1	Inlet Section	
2	Access Section	650
3	Panel and rigid filter	400
4	Access Section	550
5	Plenum Fan	1050

Section B:

S.No	Module	Length(mm)
6	Plate heat exchanger	3100

Section C:

S.No	Module	Length(mm)
7	DX Cooling coil	600
8	Access Section	550
9	Outlet Section	

Section D:

S.No	Module	Length(mm)
10	Inlet Section	
11	Access Section	800
12	Panel Filter	350

Section E:

S.No	Module	Length(mm)
13	Access Section	750
14	Outlet Section	

CUSTOMER COMMENTS / APPROVAL	
UNIT LOCATION	INTERNAL / EXTERNAL
ACCESS HANDLING - IN DIRECTION OF SUPPLY AIR	LEFT HAND / RIGHT HAND
APPROVED BY	
DATE	

Customer		STONE ASSOCIATES	AHU No.	1	Not To Scale All Dimensions shown are in mm		All dimensions shown are estimated. Detailed drawings to be produced on receipt of order.	
Project		PRINTWORKS AHU	Model	Non-standard	Selected		Initial	Date
Location		HRU-01	Air flow	10.14 m ³ /s	Approved			
			Quantity	1 Nos.	Dwg No.			



UNIT B, NATIONAL COURT
 FOX WAY, LEEDS, LS10 1PS
 Ph: (+44) 0113 218 6100
 Fax: (+44) 0113 218 6101

No.	Revision	Date