


Air Permeability Test Certificate



This is to certify that the following test and results have been produced in compliance with England and Wales regulation 43 of the Building Regulations 2010, Scotland Section 6 of the Domestic and Non-Domestic Handbook, Northern Ireland Technical Booklet and Isle of Man The Building Control (Approved Documents) Order 2014. A full report in line with the current approved procedures can be requested from the iATS tester.

Unique Certificate Number	10164695
Date of Test	12 th October 2020
Building name / Plot number	Plot 15
Building Address	Crumpsall, Manchester, Greater Manchester
r^2 (Correlation ≥ 0.98 - ≤ 1.00)	0.9995
n (Slope ≥ 0.5 - ≤ 1.0)	0.591
Envelope Area of Building m ²	275
Report Reference	
Tester's Name	Matthew Holland
Company Name	Complete Sustainability Solutions
iATS Tester No.	0563
Tester's level of competence	Level 1: Buildings < 4000m ³
Related party disclosure	No related party
Signed	

Independent Airtightness Testing Scheme
16 St Johns Business Park,
Lutterworth,
Leicestershire, LE17 4HB

e: certificate@iats-uk.org
t: 0300 688 0016
w: iats-uk.org
Company Registration No: 09309058

Measured Air Permeability

5.23

m³/(h.m²) @ 50 Pa