



Foundations should be a minimum of 550 x 150 thick concrete & give 150 cover (or same as depth in certain cases) around all piers, depth from GL to underside 450mm minimum, all subject to site investigation report, for specific sites.



| Scale   | Drawn By      | Checked By    | Authorised By |
|---------|---------------|---------------|---------------|
| 1:20    | MH            | MH            | MH            |
|         | Date April 22 | Date 21.04.22 | Date 21.04.22 |
| Job No. | Drawing No.   |               | Revision      |
|         | SD/BW/02      |               | -             |