

BUILDING REGULATION COMPLIANCE

Calculation Type: New Build (As Built)

Property Reference	CPUK Clarks 2				Issued on Date	01/03/2021
Assessment Reference	1	Prop Type Ref				
Property	87 SADDLECOTE CLOSE, MANCHESTER, MANCHESTER, M8 5QE					
SAP Rating	83 B	DER	17.94	TER	18.48	
Environmental	85 B	% DER<TER	2.92			
CO ₂ Emissions (t/year)	1.39	DFEE	50.67	TFEE	53.03	
General Requirements Compliance	Pass	% DFEE<TFEE	4.46			
Assessor Details	Mr. Laurie Wills, Element Sustainability Limited, Tel: 01829 733444, laurie@elementsustainability.co.uk				Assessor ID	H367-0001
Client						

SUMMARY FOR INPUT DATA FOR New Build (As Built)

Criterion 1 – Achieving the TER and TFEE rate

1a TER and DER

Fuel for main heating	Mains gas		
Fuel factor	1.00 (mains gas)		
Target Carbon Dioxide Emission Rate (TER)	18.48	kgCO ₂ /m ²	
Dwelling Carbon Dioxide Emission Rate (DER)	17.94	kgCO ₂ /m ²	Pass
	-0.54 (-2.9%)	kgCO ₂ /m ²	

1b TFEE and DFEE

Target Fabric Energy Efficiency (TFEE)	53.03	kWh/m ² /yr	
Dwelling Fabric Energy Efficiency (DFEE)	50.67	kWh/m ² /yr	
	-2.3 (-4.3%)	kWh/m ² /yr	Pass

Criterion 2 – Limits on design flexibility

Limiting Fabric Standards

2 Fabric U-values

Element	Average	Highest	
External wall	0.23 (max. 0.30)	0.23 (max. 0.70)	Pass
Party wall	0.00 (max. 0.20)	-	Pass
Floor	0.12 (max. 0.25)	0.12 (max. 0.70)	Pass
Roof	0.11 (max. 0.20)	0.11 (max. 0.35)	Pass
Openings	1.40 (max. 2.00)	1.40 (max. 3.30)	Pass

2a Thermal bridging

Thermal bridging calculated from linear thermal transmittances for each junction

3 Air permeability

Air permeability at 50 pascals	6.51 (average for dwelling type)	m ³ /(h.m ²) @ 50 Pa	
Maximum	10.0	m ³ /(h.m ²) @ 50 Pa	Pass

Limiting System Efficiencies

4 Heating efficiency

This report has been produced by an accredited Elmhurst member whose work is subject to quality assurance audits. The data used to produce the report has been verified by the Elmhurst members' portal.

BUILDING REGULATION COMPLIANCE

Calculation Type: New Build (As Built)

Main heating system

Boiler system with radiators or underfloor - Mains gas
Data from database
Potterton Assure 30 Combi
Combi boiler
Efficiency: 89.0% SEDBUK2009
Minimum: 88.0%

Pass

Secondary heating system

None

5 Cylinder insulation

Hot water storage

No cylinder

6 Controls

Space heating controls

Time and temperature zone control

Pass

Hot water controls

No cylinder

Boiler interlock

Yes

Pass

7 Low energy lights

Percentage of fixed lights with low-energy fittings

100

%

Minimum

75

%

Pass

8 Mechanical ventilation

Not applicable

Criterion 3 – Limiting the effects of heat gains in summer

9 Summertime temperature

Overheating risk (West Pennines (England))

Not significant

Pass

Based on:

Overshading

Average

Windows facing North East

5.25 m², No overhang

Windows facing South West

7.62 m², No overhang

Air change rate

8.00 ach

Blinds/curtains

None

Criterion 4 – Building performance consistent with DER and DFEE rate

Party Walls

Type

U-value

Filled Cavity with Edge Sealing

0.00

W/m²K

Pass

Air permeability and pressure testing

3 Air permeability

Air permeability at 50 pascals

6.51 (average for dwelling type)

m³/(h.m²) @ 50 Pa

Maximum

10.0

m³/(h.m²) @ 50 Pa

Pass

10 Key features

Party wall U-value

0.00

W/m²K

Roof U-value

0.11

W/m²K

Floor U-value

0.12

W/m²K

This report has been produced by an accredited Elmhurst member whose work is subject to quality assurance audits. The data used to produce the report has been verified by the Elmhurst members' portal.