

AFL Architects

NMGH -MULTI STOREY CAR PARK

20200-AFL-MSCP-ZZ-SP-A-0943 P1

NMGH -MULTI STOREY CAR PARK

P1

15-07-2021

20200 - NMGH -MULTI STOREY CAR PARK – NMGH -MULTI STOREY CAR PARK

Client:

Contents

Z31 Powder coatings	1
----------------------------------	----------

A Status - No Comments (FOR INFORMATION)

Z31 Powder coatings

Clauses - Not Used

To be read with preliminaries/ general conditions.

120 Powder coating materials

1. Manufacturer: Obtain from one only of the following:
2. Selected manufacturer: Submit details before commencement of powder coating including:
 - 2.1. Name and contact details.
 - 2.2. Details of accreditation schemes.
 - 2.3. Technical data of product including current Agrément certificates.

210 Working procedures

1. Comply with the follow following standards.
 - 1.1. Aluminium components: To BS 6496 or BS EN 12206-1.
 - 1.2. Steel components: To BS EN 13438.
 - 1.3. Safety standards: To British Coatings Federation 'Code of safe practice - Application of thermosetting powder coatings by electrostatic spraying'.

220 Powder coating applicators

1. Applicator requirements
 - 1.1. Approved by powder coating manufacturer.
 - 1.2. Currently certified to BS EN ISO 9001.
 - 1.3. Comply with quality procedures, guarantee conditions, standards and tests required by powder coating manufacturer.
 - 1.4. Applicator to use only one plant.
 - 1.5. Selected applicator: Submit details before commencement of powder coating including:
 - 1.5.1. Name and contact details.
 - 1.5.2. Details of accreditation schemes.

225 Guarantees

1. Powder coating manufacturer and applicator guarantees
 - 1.1. Submit sample copies before commencement of powder coating.
 - 1.2. Submit signed project specific copies on completion of work.

230 Control samples

1. Sequence: Prior to ordering materials for the works, obtain approval of appearance for:
 - 1.1. Powder coated samples: Of various grades and forms of background metal to be used, showing any colour, texture and gloss variation.
 - 1.2. Fabrication samples: Showing joint assembly, how powder coating is affected and how any cut metal edges are finished and protected.
2. Samples to include the following information
 - 2.1. Product reference.
 - 2.2. Colour.
 - 2.3. Reference number.

- 2.4. Name.
- 2.5. Gloss level.

235 Independent inspection at plant

1. **Requirement:** Contractors/ suppliers of the following designated components must commission an approved Independent Inspection Authority to carry out acceptance inspections to confirm that powder coating application complies with this specification.
 - 1.1. **Designated components:**
2. **Acceptance inspections:** Carry out for each variation of colour and finish of each component work package at applicator's plant prior to any fabrication of units, in accordance with the following:
 - 2.1. Where three or more production runs are required for application of coatings, not less than three acceptance inspections must be carried out in accordance with BS 6001-1, general inspection level 2, with an acceptance quality limit of 1%.
 - 2.2. Where less than three production runs are required for application of coatings, one acceptance inspection must be carried out in accordance with BS 6001-2, with a limiting quality of 5% where the probability of acceptance is 10%.
3. **Components failing inspection:** Reprocess or replace and reinspect.
4. **Inspection reports:** Independent Inspection Authority must submit copies.

240 Qualicoat quality assurance system

1. **Requirement:** Powder and coating application to the following designated components is to be tested and approved in accordance with the Qualicoat system.
 - 1.1. **Designated components:**

250 Component design

1. **Condition of components to be powder coated**
 - 1.1. To comply with relevant recommendations of BS 4479-1, -3, and -4.
 - 1.2. Of suitable size to fit plant capacity.
 - 1.3. Of suitable thickness to withstand oven curing.

310 Pretreatment of aluminium components

1. **Condition of components to be pretreated**
 - 1.1. Free from corrosion and damage.
 - 1.2. All welding and jointing completed and finish off as specified.
 - 1.3. Free from impurities including soil, grease, oil.
 - 1.4. Suitable for and compatible with the pretreatment process.
2. **Conversion coating requirements**
 - 2.1. **Chromate system:** To BS 6496 or BS EN 12206-1.
 - 2.2. **Chromate-free system:** To BS EN 12206-1. Submit details before using.
3. **Rinsing requirements:** Use demineralized water. Drain and dry.

320 Pretreatment of steel components

1. **Condition of components to be pretreated**
 - 1.1. Free from corrosion and damage.
 - 1.2. All welding and jointing completed and finish off as specified.
 - 1.3. Free from impurities including soil, grease, oil.
 - 1.4. Suitable for and compatible with the pretreatment process.

2. Conversion coating requirements: To BS EN 13438.
3. Rinsing requirements: Use demineralized water. Drain and dry.

430 Extent of powder coatings

1. Application: To visible component surfaces, and concealed surfaces requiring protection. Coated surfaces will be deemed 'significant surfaces' for relevant BS 6496 or BS EN 13438 performance requirements.

435 Application of powder coatings

1. Surfaces to receive powder coatings: Free from dust or powder deposits.
2. Powder colours: Obtain from one batch of one manufacturer.
3. Commencement of powder coating: To be continuous from pretreatment.
4. Jig points: Not visible on coated components.
5. Curing: Controlled to attain metal temperatures and hold periods recommended by powder coating manufacturer.
6. Stripping and recoating of components: Only acceptable by prior agreement of powder coating manufacturer. Stripping, pretreatment and powder coating are to be in accordance with manufacturer's requirements.
7. Overcoating of components: Not acceptable.

440 Performance and appearance of powder coatings

1. For aluminium components
 - 1.1. Standard: To BS 6496 or BS EN 12206-1.
2. For steel components
 - 2.1. Standard: To BS EN 13438.
3. Visual inspection after powder coating: Significant surface viewing distances to be as specified in the relevant Standard, unless specified otherwise.
4. Colour and gloss levels: To conform with approved samples.

450 Aluminium alloy fabrications

1. Units may be assembled
 - 1.1. Before powder coating.
 - 1.2. From components powder coated after cutting to size.
 - 1.3. Where approved, from components powder coated before cutting to size.
2. Exposure of uncoated background metal: Not acceptable.
3. Assembly sealants: Compatible with powder coatings. Obtain approval of colour if sealants are visible after fabrication.

460 Steel fabrications

1. Unit assembly: Wherever practical, before powder coating.
2. Exposure of uncoated background metal: Not acceptable.
3. Assembly sealants: Compatible with powder coatings. Obtain approval of colour if sealants are visible after fabrication.

470 Fixings

1. Exposed metal fixings: Powder coat together with components, or coat with matching repair paint system applied in accordance with the powder coating manufacturer's recommendations.

480 Damaged components – repair or replacement

1. **Before delivery to site:** Check all components for damage to powder coatings. Replace damaged components.
2. **Site damage:** Submit proposals for repair or replacement.

510 Protection

1. **Powder coated surfaces of components:** Protect from damage during handling and installation, or by subsequent site operations.
2. **Protective coverings:** Must be:
 - 2.1. Resistant to weather conditions.
 - 2.2. Partially removable to suit building in and access to fixing points.
3. **Protective tapes in contact with powder coatings:** Must be:
 - 3.1. Low tack, self adhesive and light in colour.
 - 3.2. Applied and removed in accordance with tape and powder coating manufacturers' recommendations. Do not use solvents to remove residues as these are detrimental to the coating.
4. **Inspection of protection:** Carry out monthly. Promptly repair any deterioration or deficiency.

535 Documentation

1. **Submit the following information for each batch of powder coated components**
 - 1.1. Supplier.
 - 1.2. Trade name.
 - 1.3. Colour.
 - 1.4. Type of powder.
 - 1.5. Method of application.
 - 1.6. Batch and reference number.
 - 1.7. Statutory requirements.
 - 1.8. Test certificates.
 - 1.9. Maintenance instructions.

540 Completion

1. **Protection:** Remove.
2. **Cleaning and maintenance of powder coatings:** Carry out in accordance with procedures detailed in powder coating manufacturer and applicator guarantees.

Ω End of Section

A Status - No Comments (FOR INFORMATION)



Specification created using NBS Chorus