

Craig Musgrave

Subject: FW: Hologic Crewe Road_Noise

From: Mike Potts <mike@echoacoustics.co.uk>
Sent: 03 February 2022 11:50
To: Bill Jennings <bill.jennings@jda-architects.com>
Subject: Hologic Crewe Road_Noise

Bill,

I have visited the Crewe Road facility, I note that it is now fully operational. The ambient sound environment on site is still dominated by traffic on Wythenshawe Road and it is evident that there is **no audible or measurable sound emanating from the building** itself. In light of this, I would suggest that Condition 5 (Part 2) of Planning Consent 126686/JO/2020, can be considered to have been complied with.

I trust that this is sufficient but please don't hesitate to contact me if you have any further questions.

Kind regards,

Mike Potts

Acoustic Consultant

Echo Acoustics

Tel: 07913 392792

E-mail: mike@echoacoustics.co.uk

This message is Confidential and may contain legal, privileged or professional information, intended for the addressee(s) only. The views expressed in this e-mail are not necessarily the views of Echo Acoustics and/or its subsidiaries nor of its Directors, Officers, Employees, Agents or Servants, and it accepts no liability for its completeness, accuracy or content whatsoever. If you have received this transmission in error, please notify us by return and delete the same; you should not copy, forward or otherwise distribute the information contained in it. Although the sender endeavours to maintain a virus free network, the sender does not warrant that this transmission is virus-free and will not be liable for any damages resulting from any virus transmitted and it is therefore the recipients responsibility to carry out virus checking upon receipt.

For more information about the services offered by Echo Acoustics, please visit our website at <http://www.echoacoustics.co.uk> or call us on 07913 392792.

Recycle - Think before you print