

NOTES:

1. THIS DRAWING SHALL BE READ IN CONJUNCTION WITH ALL RELEVANT ARCHITECTURAL, STRUCTURAL AND SERVICES RELATED DRAWINGS, SCHEDULES AND SPECIFICATIONS.
2. STRIP-OUT OF EXISTING SYSTEMS TO INCLUDE ALL DUCTWORK, FANS, WIRING SUPPORTS AND ANCILLARIES AND ALL NECESSARY MAKING GOOD, I.E. TO EXTERNAL LOUVRE OPENINGS
3. ALL DUCTWORK BRANCHES / LEGS TO BE COMPLETE WITH VOLUME CONTROL DAMPERS.
4. ALL DUCTWORK INTERNALLY TO BE INSULATED IN LINE WITH SPECIFICATION.

