

Legend	
Key	Description
	Approx. line of downstand beam
	VRF Indoor Unit
	Acoustically wrapped BC Controller c/w port isolation valves
	Refrigerant Pipework
	Condensate Pipework
	Local Wall Mounted Controller
	Control Wiring
	Secondary Supply Air Ductwork
	Supply Air Grille
	Flexible Connection
	Volume Control Damper
	Volume Control Damper

- Notes
- All ducting runs, indoor VRF unit locations and diffuser positions must be checked and set out against a fully detailed ceiling layout, structural engineering and electrical services drawings. All dimensions must be checked out on site prior to the installation being executed. The contractor will be expected to co-ordinate, the ductwork and piped services with all other trades.
 - All indoor VRF units shall be independently supported using the appropriate fixings and hangers suitably supported from the soffit.
 - All refrigerant pipework distribution to be within ceiling void zone.
 - All refrigerant pipework to be in half hard copper clipped to cable tray.
 - Condensate drainage pipework to connect to S&VP via a hep0 dry trap as manufactured by Hepworth or equivalent.
 - All condensate drainage to include rodding eyes / inspection caps.
 - All condensate drains to be gravity to falls.
 - Minimum of 100mm lighting zone to be maintained above ceiling zone.
 - Refrigerant pipework shown single line for clarity.
 - The final location of all wall mounted controllers is to be agreed with the Client and Architect.
 - Only the containment routed below the downstand beams have been indicated on this layout.

P1	31	Planning Issue.	DG	JW
Issue	01	Description	Drawn	Checked
Date	22			



Hannan Associates
MEP Design Solutions

Hannan Associates Ltd
Beta House, Alphagate Drive,
Manchester Road, Denton
M34 3SH
Tel : +44 (0)161 337 2200
Email : info@hannan-uk.com
Web : www.hannan-uk.com

Client
Clearbell UK Strategic Limited Partnership

Project
Fretrade Exchange
Refurbishment

Design Stage
Stage 2 'Concept Design'

Drawing Title
Indicative Comfort Cooling Layout
Ground Floor

Scale
1:50

Page Size
A1L

Status
PLANNING ISSUE

Project : Originator : Volume
3882 - HAN - ZZ

Level : File Type : Role : Number
00 - DR - M - 02 12

This drawing is the property of Hannan Associates. It must not be copied or lent to any third party without the written consent of Hannan Associates, and must be returned upon request.

