



Fixings need to recognise metal mesh

Fire Rating: depth of 215mm achieves FR 240'
Acoustic Performance: TBC
Duty Rating: N/A
Maximum Height: N/A



Fire Rating: 120'
Acoustic Performance: 45dB
Duty Rating: Severe
Maximum Height: up to 4500mm
Reference: A306003



What is the difference

Notes:
 Drawings are based on survey data and may not accurately represent what is physically present.
 Do not scale from this drawing. All dimensions are to be verified on site before proceeding with the work.
 All dimensions are in millimeters unless noted otherwise.
 Purcell shall be notified in writing of any discrepancies.

General Notes:

- Please refer to OTH-PUR-TH-IG-DWG-A-2370 to OTH-PUR-TH-07-DWG-A-2399 for location of proposed new walls.
- Please refer to OTH-PUR-TH-ZZ-DWG-A-5687 for catering partitions details.
- Please refer to OTH-PUR-TH-ZZ-DWG-A-5710 to OTH-PUR-TH-03-DWG-A-5725 for Secure Lines and Fire Screen details.

-	27/09/2019	DH	MR	First Issue, Issued for LBC/Planning
ISSUE	DATE	APPROVED	DRAWN	DESCRIPTION



PROJECT STATUS	RIBA STAGE 4
CIENT	MANCHESTER CITY COUNCIL
PROJECT	OUR TOWN HALL
DRAWING TITLE	DETAILS - PARTITION & LINING TYPES 3 of 3
SIZE & SCALE	A1: 1 : 5
DRAWING STATUS	For Review and Comment
JOB NUMBER	236959
DRAWING NO.	REV
OTH-PUR-TH-ZZ-DWG-A-5682 -	
© PURCELL 2009. PURCELL ® IS THE TRADING NAME OF PURCELL ARCHITECTURE LTD.	

	Lendlease
Document Review	
Lendlease Document received on:	
1. Accepted 2. Accepted with comments 3. Rejected	
Lendlease Checked by: Stuart Wheeldon	
Date: 02/10/2019	
Accepted documents are considered to conform to the design intent, but does not mean acceptance of dimensions, details, size or weights; nor does it relieve the designer from responsibilities for errors, omissions and/or compliance with obligations and/or responsibilities of the contract.	