

Appendix E Proforma for Planning Applications



MANCHESTER
CITY COUNCIL

Planning Application – Waste Management Strategy

Planning Application Number: TPL (RENAME, RESIDENTIAL BUILDING)
Date Submitted: 27.10.21 DEANSGATE.

Estimated volumes/ m² required by the development

Low Rise Domestic

Waste Types	Capacity Required (litres)	Number of bins required per household	Confirm what is to be provided
General refuse	140 / 240	1 x wheeled bin	20 x 1,100L bins
Pulpable Recycling	140 / 240	1 x wheeled bin	10 x 1,100L bins
Mixed Recycling	140 / 240	1 x wheeled bin	10 x 1,100L bins
Garden Waste	140 / 240	1 x wheeled bin	2 x 240L bins
Food Waste	23	1 x 23 litre caddy	2 x 240L bins

High Rise Apartment Developments

	Yes/No - how much space has been provided?
0.43m ² has been provided per apartment for the container space. Space to manoeuvre and access containers individually has also been provided so that each container can be accessed and removed for collection individually.	0.43m ² PER 100 APARTMENTS REQUIRE 129m ² REFUSE YARD. A REFUSE YARD 11360 AT 141m ² HAS BEEN PROVIDED.

Commercial Developments

Please state number of bins you propose, showing calculations where appropriate.

General Waste -
Pulpable Recycling -
Mixed Recycling -
Food Waste -
Industrial Waste -

Has / will a contract be obtained with a licenced waste carrier?

☐

Mixed Use Developments

Are the stores for residential and commercial separate from each other?

☐

Internal Stores (Residential and Commercial)

Please provide details of internal stores / segregation of waste and recycling.

Storage Areas for Waste Containers (Residential and Commercial)

Please provide details of container stores, attaching plans if appropriate.

PLEASE REFER TO DESIGN AND ACCESS STATEMENT
FOR REFUSE DETAILS (PAGES 98).
STORE LOCATED ON DRAWING NO. B2-02-2200.

Ensure all bins in the store are accessible

☒

Ensure recycling facilities are as easy to access as general refuse

☒

Please confirm details of waste store ventilation and hygiene / cleaning proposals

Ventilation -	A MECHANICAL VENTILATION SYSTEM WILL HAVE THE BIN STORES - EXTRACT VIA THE SERVICE YARD.
Hygiene -	THE FLOOR AND WALLS WILL BE CONCRETE / FINISHED WITH ROUGH / IMPERVIOUS FINISH.

Please provide details of who will be responsible for placing the bins at the collection point and returning them to the store / property promptly e.g. resident / management company

A RESIDENTIAL MANAGEMENT COMPANY WILL MANAGE THE COLLECTION OF THE BINS.
--

Please ensure that you have attached:

Detailed plans of waste stores	☒
Location plans showing stores	☒
Location plans showing the proposed collection point and the route the collection vehicle will take	☒

Please ensure that you have completed this form in accordance with our GD04 Waste Storage and Collection Guidance for New Developments