

DO NOT SCALE FROM THIS DRAWING.
ALL DIMENSIONS TO BE CHECKED ON SITE.
COPYRIGHT PROTECTED.

	EX1E	THORLUX 8W WIDE ANGLE POLYCARBONATE DIFFUSER, C/W SMART SCAN AND SELF CONTAINED EMERGENCY CONVERSION
	EX2	THORLUX 31W 9W COLUMN MOUNTED AREA FLOODLIGHT
	EX3	THORLUX 31W 9W COLUMN MOUNTED ROADWAY FLOODLIGHT



P4 Emergency Exit Sign Key		
Symbol	Description	
	BETA/SW/M3/WH - P4 FASTEL Beta, Surface Wall Mounted, LED Sign Luminaire, Non-Maintained/Maintained, 3 Hours, White. For Legend Type/Direction See Floor Plan.	
	B/HTM/LU - P4 FASTEL Beta Legend, Hospital Technical Memorandum, Direction UP.	
	LAMBDA/RC/M3/WH - P4 FASTEL Lambda, Recessed Ceiling Mounted, LED Sign Luminaire, Non-Maintained/Maintained, 3 Hours, White. See Floor Plan for Legend Type and Direction.	
	O/HTM/LLR/30/DS - P4 FASTEL Lambda Omikron Pi 300mm Legend, Double Sided, Hospital Technical Memorandum, Direction LEFT-RIGHT.	
	O/HTM/LU/30 - P4 FASTEL Lambda Omikron Pi 300mm Legend, Single Sided, Hospital Technical Memorandum, Direction UP.	
	O/HTM/LL/30 - P4 FASTEL Lambda Omikron Pi 300mm Legend, Single Sided, Hospital Technical Memorandum, Direction LEFT.	
	O/HTM/LR/30 - P4 FASTEL Lambda Omikron Pi 300mm Legend, Single Sided, Hospital Technical Memorandum, Direction RIGHT.	

P4 Emergency Lighting Key		
Symbol	Description	
	M-web - P4 FASTEL M-web Controller with integrated interface box. Monitors a maximum of x100No luminaires or x63No Collector Boxes	
	P4 Wireless Repeater Module, This module will communicate with up to 15 luminaires using 2.4Ghz.	
	P4 FASTEL Emergency Lighting Conversion of luminaire using 3W LED Conversion Kit inc 4-Cell NiCd battery. Maintained/Non-Maintained, 3 hour emergency. (5no OF 16 TO BE 868Mhz)	
	B2ER/RC/M3/WH - P4 FASTEL BiLED2 Escape Route, Recessed Ceiling Mounted, LED Luminaire, Non-Maintained/Maintained, 3 Hours, White.	
	B2OA/SC/M3/WH - P4 FASTEL BiLED2 Open Area, Surface Ceiling Mounted, LED Luminaire, Non-Maintained/Maintained, 3 Hours, White.	
	B2OA/RC/M3/WH - P4 FASTEL BiLED2 Open Area, Recessed Ceiling Mounted, LED Luminaire, Non-Maintained/Maintained, 3 Hours, White.	

P01	APPROVAL	15.06.21
Rev	Description	Date
APPROVAL		
ECO-1 ELECTRICAL SOLUTIONS LTD 200 ROOKERY LANE, ALDRIDGE, WALSALL, WS9 8NP info@eco-1.co.uk www.eco-1.co.uk 01922 214607		
Scale	1:50@A0	Date 26.11.20
Client Name	ESS modular LONDON DUBLIN MANCHESTER BELFAST CORN	
Project	NORTH MANCHESTER GENERAL HOSPITAL	
Drawing Title	EXTERNAL LIGHTING LAYOUT	
Drawing No.	20-074-ECO1-OB-GF-DR-E-2302	Rev. P01
Drawn By	PA	Status. S3