NOTES:

1. ALL SUPPORT SYSTEMS & BRACKETRY SHALL BE DESIGNED & COORDINATED WITH THE BUILDING FABRIC & MECH & ELECTRICAL SERVICES BY THE ELECTRICAL CONTRACTOR.
2. STEEL CLIPS SHALL BE USED FOR ALL CABLING WHERE CLIPPED TO LADDER OR TRAY.
3. THE ELECTRICAL CONTRACTOR SHALL BE RESPONSIBLE TO ENSURE THE ELECTRICAL INSTALLATION FULLY COMPLIES WITH BS7671 - 18TH EDITION
4. ALL EXTERNAL LIGHTING DUSK TO BE CONTROLLED VIA PHOTOCELL & TIMECLOCK

LEGEND

- THORLUX 10M STARBEAM ECO FLOODLIGHT MOUNTED ON MIDCOLUMN
- THORLUX 10M LED REALTA WALL MOUNTED LUMINAIRE
- EB EXTERNAL BOX 400MM X 400MM X 1.7M
- LIGHTNING PROTECTION ROD
- BBT BB TAP WITH HOSE UNION CONNECTION
- IP66 RATED EXTERNAL FIXED CCTV CAMERA
- IP66 RATED EXTERNAL CCTV CAMERA WITH PAN TILT ZOOM FACILITY
- CCTV DATA OUTLET FOR CCTV (POE)
- CTV IP66 RATED UNSWITCHED FUSED CONNECTION UNIT FOR EXTERNAL CCTV CAMERA

SITE BOUNDARY TBC FOR CCTV COVERAGE

Existing 97 spaces

Proposed 26 bike spaces

Proposed 4 spaces

Proposed 14 spaces

Proposed 69 spaces

Proposed 2 spaces

Existing 15 spaces

Proposed 20 spaces

New Electricity Substation

Existing fence to be removed

access route

Retaining wall

Engine route

CAMERAS SHOWN FOR REFERENCE PART OF EXISTING SCHEME

CAMERAS SHOWN FOR REFERENCE AS PART OF EXISTING SCHEME

2NO. 100mmØ HDP DUCT FOR NEW FIRE ALARM AND DISABLED REFUSE LINKS TO BE TERMINATED INTO CHAMBER 10 (APPROXIMATE POSITION SHOWN)

2x 100mmØ HDP DUCT FOR POWER & DATA TO SERVE EXTERNAL CCTV FED FROM COMMS ROOM

3x 100mmØ HDP DUCT FOR NEW MAIN INCOMING CABLES TO/FROM INTO ELECTRICAL SWITCH ROOM

100mmØ STEEL BIG CHIMNEY MORSE RISING INTO PLANTROOM THROUGH SLAB FLASH LUG BEND DUCT

BUILDING MOUNTED EXTERNAL CAMERA

3x 100mmØ HDP DUCT FOR NEW MAIN INCOMING CABLES

100mmØ MORSE CHIMNEYS

2x 100mmØ HDP DUCT FOR NEW MAIN INCOMING CABLES FROM NEW SUB STATION - METERING CUBICAL DETAILS TBC

100mmØ MORSE INCOMING MORSE CONNECTION ONTO BUILDING TRANSFORMER

100mmØ HDP DUCT FOR NEW EXTERNAL LIGHTING SYSTEM

100mmØ HDP DUCT FOR NEW EXTERNAL CCTV CAMERA

BUILDING MOUNTED EXTERNAL CAMERA

BUILDING MOUNTED EXTERNAL CAMERA







EXTERNAL COLUMNS FIXING DETAIL (1:100)

| | | | |
|---|---|---|---|
| C01 | CONSTRUCTION ISSUE | AC 30/7/21 | KB 30/7/21 |
| P01 | PRELIMINARY ISSUE | AC 07/05/21 | KB 07/05/21 |
| Rev | Amendment | Initials Date | Checked Date |

H E Simm
ENGINEERING EXCELLENCE


HEAD OFFICE
Suites 5 & 6 Spinnaker House
141 Sefton Street
Liverpool L8 5RN
Tel: 0151 707 3222
Email: info@hesimm.co.uk
hesimm.co.uk


Project Name:
THE CHRISTIE TIERED CAR PARK

Sheet Title:
EXTERNAL SERVICES

Scale (@ A0): 1:250
Drawn: AC
RIBA Stage: 5
Status: AS
Revision: C01

BS1192 Document Number:
TCP-HES-XX-ZZ-DR-E-600002