

Luis Brito

From: Simon Tucker <Simon.Tucker@canalrivertrust.org.uk>
Sent: 27 May 2021 15:51
To: Luis Brito
Cc: Simon LeaWilson; Deborah McCormick
Subject: RE: 9762 - 129444/FO/2021 Grimshaw Lane Manchester - Surface Water discharge

Good Afternoon Luis

Thank you for your email below.

I have not been consulted directly to comment on a potential SW discharge to the canal. However, I would not expect to be for this type of enquiry and would usually forward this to our utilities section who would have the relevant expertise to advise on the feasibility of any new connection.

I can see that Deborah McCormick from our utilities section has provided a response, and that the comments raised are therefore an accurate reflection of the Trust's position.

I hope this is of assistance. If you need anything more, please let either myself or Deborah know.

Kind Regards

Simon Tucker MSc MRTPI
Area Planner North East, Canal and River Trust

T 07885241223
E simon.tucker@canalrivertrust.org.uk

Canal & River Trust
Fearn's Wharf; Neptune Street; Leeds; LS9 8PB

www.canalrivertrust.org.uk

Sign up for the Canal & River Trust e-newsletter www.canalrivertrust.org.uk/newsletter

Follow @canalrivertrust from the Canal & River Trust on Twitter

Please visit our website to find out more about the Canal & River Trust and download our 'Shaping our Future' document on the About Us page.



From: Luis Brito <luis.brito@ptaconsult.co.uk>
Sent: 27 May 2021 15:30
To: Simon Tucker <Simon.Tucker@canalrivertrust.org.uk>
Cc: Simon LeaWilson <Simon.Lea-Wilson@ptaconsult.co.uk>
Subject: 9762 - 129444/FO/2021 Grimshaw Lane Manchester - Surface Water discharge

CAUTION: This email originated from an external source. DO NOT CLICK/OPEN links or attachments unless you are certain of their origin.

Hi Simon,

We are the structural and civil engineers appointed to support the proposed development at Grimshaw Lane, Manchester, M40 2BA (planning ref. 129444/FO2021). We have been given your contact as the CRT consultee for this planning application.

Following the initial planning consultation, we have been asked by the LLFA to provide evidence that a potential surface water outfall into the adjacent Rochdale Canal was being investigated.

We have since contacted CRT (please see attached email) to advise if a discharge was possible and what conditions would be implemented.

The reply have we received highlights that the canal is at capacity and as such we should considered that a surface water discharge into the canal is not currently viable.

We were wondering if you have been contacted to comment on a potential SW discharge into canal? And if your assessment is in line with what was described above?

Kind regards,

Luís Brito

Senior Civil Engineer



proudly celebrating our 50th anniversary

T: 01494 772 721 | M: 07939 051 133 | W: www.ptaconsult.co.uk
PTA, 29 Red Lion Street, Chesham, Bucks., HP5 1EJ

IMPORTANT: [Email disclaimer](#)

PTA is a trading name of Powell Tolner & Associates Limited. Powell Tolner & Associates Limited is registered in England and Wales. Reg. No.: 8399579, Reg. Office: 22 Wycombe End, Beaconsfield, Buckinghamshire, HP9 1NB, UK.

Keep in touch

Sign up for the Canal & River Trust e-newsletter <https://canalrivertrust.org.uk/newsletter>

Become a fan on <https://www.facebook.com/canalrivertrust>

Follow us on <https://twitter.com/canalrivertrust> and <https://www.instagram.com/canalrivertrust>

This email and its attachments are intended solely for the use of the intended recipient. If you are not the intended recipient of this email and its attachments, you must take no action based upon them; please delete without copying or forwarding and inform the sender that you received them in error. Any views or opinions expressed are solely those of the author and do not necessarily represent those of The Canal & River Trust.

Canal & River Trust is a charitable company limited by guarantee registered in England & Wales with company number 7807276 and charity number 1146792. Registered office address First Floor North, Station House, 500 Elder Gate, Milton Keynes MK9 1BB.

Cadw mewn cysylltiad

Cofrestrwch i dderbyn e-gylchlythyr Glandŵr Cymru <https://canalrivertrust.org.uk/newsletter>

Cefnogwch ni ar <https://www.facebook.com/canalrivertrust>

Dilynwch ni ar <https://twitter.com/canalrivertrust> ac <https://www.instagram.com/canalrivertrust>

Mae'r e-bost hwn a'i atodiadau ar gyfer defnydd y derbynnydd bwriedig yn unig. Os nad chi yw derbynnydd bwriedig yr e-bost hwn a'i atodiadau, ni ddylech gymryd unrhyw gamau ar sail y cynnwys, ond yn hytrach dylech eu dileu heb eu copïo na'u hanfon ymlaen a rhoi gwybod i'r anfonwr eich bod wedi eu derbyn ar ddamwain. Mae unrhyw farn neu safbwynt a fynegir yn eiddo i'r awdur yn unig ac nid ydynt o reidrwydd yn cynrychioli barn a safbwyntiau Glandŵr Cymru.

Mae Glandŵr Cymru yn gwmni cyfyngedig drwy warant a gofrestrwyd yng Nghymru a Lloegr gyda rhif cwmni 7807276 a rhif elusen gofrestredig 1146792. Swyddfa gofrestredig: First Floor North, Station House, 500 Elder Gate, Milton Keynes MK9 1BB.