



Atelier MB
Urban Architects

Planning Condition – Information to Support Discharge

Job: Paragon Mill: 1887

Planning Ref: 132123/LO/2021

- Refer to approval document for further details

EXTERNAL PLANT TREATMENT



Example image of a vinyl wrap to external plant equipment.

“Further to our discussion earlier this week, and ahead of our formal submission of the discharge of condition 4 (6 for FO), please find attached details of the smallest plant enclosure possible. We have also shown by comparison the size of the equipment without this enclosure – using the vinyl wrap instead.

The plant enclosure is inevitably larger than the equipment, due to the air flow required around the equipment to enable it to operate.

If were permitted to use the vinyl wrap instead, the plant itself would much less physically and visually intrusive on the Listed Building.

We consider the wrap a preferable solution, and would be grateful if you could reconsider this option.” Heloise Wood, AtMB email 18/03/21

“I have discussed the shroud with my group leader and the shroud looked the most appropriate option in this instance. Therefore, please proceed to discharge the condition.” Janine Renshaw Livesey , MCC, email 24/03/21