



1. ALL GENERAL SUPPLY AND EXTRACT DUCTWORK SHALL BE MANUFACTURED AND INSTALLED IN ACCORDANCE WITH THE HVCA SPECIFICATION DW144 LOW PRESSURE CLASS A
2. ALL EXTERNAL SUPPLY AND RETURN AIR DUCTWORK SHALL BE INSULATED, FINISHED ALUMINIUM CLAD AND IDENTIFIED

Architectural X-Ref Drawings:	
FF&E X-Ref Drawings:	
Drawing Status:	CONSTRUCTION



hurstwood environmental
Consulting Engineers
www.hurstwood-eng.co.uk

Drawn: R Jordan	Chkd: P Chambers	App: M Jordan	A1
Date: APR 2020	Scale: NTS		
Client:			

Project:
OLD GRANADA STUDIOS - ZONE 6

Project No:	Rev:
63050-VAU-Z6-XX-DR-N-5700	C2