



© This Drawing and its contents are strictly the copyright of GLD

GENERAL NOTES

1. Drawings are to be read in conjunction with all relevant specifications, engineers, architects & services drawings, including approved builders work drawings. Contractor to notify engineer of discrepancies between structural drawings & specifications or other drawings.
2. All dimensions are in millimeters unless noted otherwise.
3. Do not scale from the drawings or the computer digital data, only figured dimensions are to be used.
4. This is a design drawing & shall not be used for construction purposes.
5. Lighting Column to a standard spec and height of column is 6 meters. Stepped Tubular steel column by ASD. Hot dip galvanised with root protection, anti sink base plate and IP66 rated.
6. External lighting to be designed to achieve lighting levels as required by BS 5489 with a minimum average lux level of 10 lux and a uniformity ration of no less than 25%.

LEGEND

- A1 ASD Highway Diamond Elite Black IP66 4000K
LED 0870 - M1 OPTIC
- B1 ASD Highway Diamond Elite Black IP66 4000K
LED 1670 - FO OPTIC
- C4 ASD Stealth Elite Black IP65 4000K
LED 1500 - M1 Optic
- D2 ASD PIR operated bulkhead
- E Denotes emergency version
- CDP 32A Car charging pillar

T4	26.01.2022	Car charging points revised	VG	LD
T3	19.01.2022	Luminaire references revised	VG	LD
T2	22.09.2021	Positioning of street lights revised	VG	LD
T1	21.05.2021	Updated to suit revised layout	VG	LD
P6	03.03.2021	Note 5 revised	VG	LD
P4	04.02.2021	Updated to suit revised layout	VG	LD
P3	07.12.2020	Column height confirmed in notes	VG	LD
P2	07.12.2020	Updated to suit latest XREF	VG	LD
P1	04.12.2020	Preliminary Issue	VG	LD
Rev:	Date:	Amendment:	Drawn:	Check:
Dwn:	VG	Date: 04.12.2020	Scale:	
Chkd:	LD	Date: 04.12.2020	1:300 @ A0	

Client:



Project Title:
Whitehouse Club

Drawing Title:
Site Plan
External Lighting Layout

Status:

TENDER



Drawing No:
J115-GLD-00-DR-ES-6300-005

Rev:

T4