



1. This drawing shall be read in conjunction with all other drawings and specifications.
2. All electrical installation works shall be carried out in accordance with BS7671 incorporating all current amendments.
3. This drawing outlines the lighting illuminance levels and uniformity requirements and an indicative layout.
4. The contractor shall be responsible for the final detailed design and shall design to the lux levels and controls strategy indicated. Where lux levels /uniformity cannot be achieved with the layout indicated the contractor shall amend the layouts accordingly to meet the performance requirements.
5. Lighting levels have been determined in line with the CIBSE guidelines and SLL code for lighting.
6. Emergency lighting shall be provided in all escape routes and other risk areas in line with BS5266 and BS EN 50172.
7. Illuminated emergency exit signs shall be provided along all escape routes and all legends shall comply with the requirements of BS EN 5499-4 & ISO 7010.
8. Contractor to provide all necessary switches, PIR sensors (separate or integrated) and lighting controls to allow the controls strategy as indicated to be provided.

P1	21.09.21	Preliminary Issue	GC	PW	PW
Rev	Date	Description	By	Check	App.

COPYRIGHT: THE COPYRIGHT OF THIS DRAWING IS VESTED IN CLANCY CONSULTING.
IT SHALL NOT BE USED WITHOUT PERMISSION BY ANYONE FOR ANY PURPOSE.
DO NOT SCALE THIS DRAWING ELECTRONICALLY OR MANUALLY.
WORK TO FIGURED DIMENSIONS ONLY.
ALL DIMENSIONS ARE IN MILLIMETRES UNLESS STATED OTHERWISE.
DO NOT TURN ON LAYERS THAT HAVE BEEN TURNED OFF.
DO NOT THAW LAYERS THAT HAVE BEEN FROZEN.
DRAWING MUST BE PRINTED IN BLACK AND WHITE ONLY.

Client	Lapwine Ltd		
Project	105 Princess Street Manchester		
Office	Altrincham		
Discipline	Electrical		
Title	Fourth Floor Indicative Lux Levels & Lighting Controls Strategy		
Scale @ A1	1:50	Status	Preliminary



www.clancy.co.uk

Project No.	Originator	Building/Zone	Level
7_7478	CCL	XX	04
Type	Discipline	Drawing No.	Revision
DR	E	300215	P1

Legend:

100 lux floor 0.4 uniformity	150 lux floor 0.4 uniformity	200 lux floor 0.4 uniformity	300 lux floor 0.4 uniformity	300 lux task - 200 lux ambient 0.6 task uniformity	500 lux task - 300 lux ambient 0.6 task uniformity
---------------------------------	---------------------------------	---------------------------------	---------------------------------	---	---

Controls key:

Manual switching	Occupancy sensor, daylight control and dimmable (presence/dimming/daylight sensing)
Occupancy sensor (presence)	Manual switching, occupancy sensor and dimmable (absence/dimming)
Manual switching and occupancy sensor (absence)	Manual switching, occupancy sensor, daylight control and dimmable (absence/dimming/daylight sensing)
Occupancy sensor (presence) and dimmable	Manual switching, daylight control and dimmable (absence/dimming/daylight sensing)