Main Building External Lighting
P02

Paterson Redevelopment Project

23 Sep 2021 | For Information | P02

PRP-ARUP-ZZ-ZZ-SK-E-0075

ARUP

LEGEND



EX1
Whitecroft Mirage LED IP65
4000k
2500lm
DALI driver
'E' suffix denotes integral emergency



EX2
Whitecroft Kolo Hood IP65
4000k
1008lm
DALI driver



EX3
Thorn Contrast Medium
4000k
3887lm
Optics TBC
DALI driver

Downlight mounted on underside of link bridge

Dashed red line indicates extent of building overhang. Downlights to be recessed into underside of soffit boarding out.

Refer to *PRP-ARUP-ZZ-ZZ-SK-E-0069 FM Compound Redesign - External Lighting* for external lighting to the FM compound and adjacent landscaping.

Wall wash luminaires mounted on vertical face to provide illumination to signage. Optics TBC.

Dashed red line indicates extent of building overhang. Downlights to be recessed into underside of soffit boarding out.

WILMSLOW ROAD

