

SAP 2012 Overheating Assessment

Calculated by Stroma FSAP 2012 program, produced and printed on 23 November 2021

Property Details: Plot 1

Dwelling type:	End-terrace House
Located in:	England
Region:	West Pennines
Cross ventilation possible:	Yes
Number of storeys:	3
Front of dwelling faces:	North
Overshading:	Average or unknown
Overhangs:	None
Thermal mass parameter:	Calculated 307.7
Night ventilation:	False
Blinds, curtains, shutters:	
Ventilation rate during hot weather (ach):	4 (Windows open half the time)

Overheating Details:

Summer ventilation heat loss coefficient:	400.47	(P1)
Transmission heat loss coefficient:	104.5	
Summer heat loss coefficient:	504.95	(P2)

Overhangs:

Orientation:	Ratio:	Z_overhangs:
North (Front Windows)	0	1
West (Side)	0	1
South (Rear)	0	1
South (RL)	0	1

Solar shading:

Orientation:	Z blinds:	Solar access:	Overhangs:	Z summer:	
North (Front Windows)	1	0.9	1	0.9	(P8)
West (Side)	1	0.9	1	0.9	(P8)
South (Rear)	1	0.9	1	0.9	(P8)
South (RL)	1	1	1	1	(P8)

Solar gains:

Orientation		Area	Flux	g_	FF	Shading	Gains
North (Front Windows)	0.9 x	9.38	73.49	0.63	0.8	0.9	281.42
West (Side)	0.9 x	10.14	108.47	0.63	0.8	0.9	449.01
South (Rear)	0.9 x	9.87	106.3	0.63	0.8	0.9	428.31
	1 x	3.17	172.15	0.63	0.8	1	247.54
Total							1406.28 (P3/P4)

Internal gains:

	June	July	August
Internal gains	511.6	489.86	499.08
Total summer gains	2026.53	1896.14	1727.03 (P5)
Summer gain/loss ratio	4.01	3.76	3.42 (P6)
Mean summer external temperature (West Pennines)	14.7	16.4	16.3
Thermal mass temperature increment	0	0	0
Threshold temperature	18.71	20.16	19.72 (P7)
Likelihood of high internal temperature	Not significant	Not significant	Not significant

SAP 2012 Overheating Assessment

Assessment of likelihood of high internal temperature: Not significant