

sample

kampus listed buildings

11 01 2019

sample sign-off 01.01 • brickwork cleaning**description:**

brickwork to be cleaned via non abrasive DOFF super heated water system. cleaning work to only be carried out to areas that have been subject to heavier staining for light touch approach.

confirmed via condition 33a (CDN/19/0029) + 6a (CDN/19/0028) approvals on 11.01.2019

location:

existing brickwork - all elevations + both buildings.

image:

fig01: cleaning sample undertaken to minshull house @ ground floor