

Building Outline Information

Architect's Drawing No.

1703-EXA-00-ZZ-DR-L-231

Date

09-04-21

B&F PROJECT NUMBER: 4006

NOTES

- LIGHTING TO BE CONTROLLED VIA TIMECLOCK & PHOTOCELL.
- SPARE DUTY TO BE TERMINATED IN DRAW PIT OUTSIDE OF BUILDING FOR FUTURE.

LEGEND

- UNDERGROUND PVC DUCT - SIZE AS SHOWN
- 50x50mm L&P TRUNKING
- ⊠ DRAW PIT 600x600
- 'E' DENOTES 3 HR INTEGRAL EMERGENCY
- PP ⊠ POP UP POWER POINT

LUMINAIRE PARTS LIST					
INDEX	MANUFACTURER	LUMINAIRE TYPE	CONNECTED LOAD	COMMENTS	IMAGE
A	SPURLITE LTD	WALL MOUNTED LED LUMINAIRE	9W	WALL MOUNTED	
A1	SPURLITE LTD	RECESSED LED SQUARE LUMINAIRE	9W	SQUARE RECESSED	
A2	SPURLITE LTD	RECESSED LED CIRCULAR LUMINAIRE	9W	CIRCULAR RECESSED	
B	SPURLITE LTD	PRETTUS XTP POLISHED-OPAL 10W 1000x 400x 60mm	10 W	RECESSED	
C	SPURLITE LTD	SLIMLINE LOW PROFILE LED SURFACE MOUNTED	11W / M	INTERNAL/EXTERNAL CANOPYS	
D	SPURLITE LTD	HARM 04 5W 20LM 3000K 60RA	5 W	GROUND RECESSED	
F	SPURLITE LTD	JORY S FLOOD 807 245LM 5W 3000K 60RA	5 W	GROUND MOUNTED ON A PIPES (SPACING 10M)	
G	SPURLITE LTD	JORY S FLOOD 1020 150lm 5W 3000K 60RA	5 W	GROUND MOUNTED ON A PIPES (SPACING 10M)	
H1	SPURLITE LTD	SLIMLINE LOW PROFILE LED SURFACE MOUNTED	11W / M	FULL PERIMETER OF BENCH	
H2	SPURLITE LTD	SLIMLINE LOW PROFILE LED SURFACE MOUNTED	11W / M	BRIDGE EDGE OF BENCH	
I	SPURLITE LTD	SLIMLINE LOW PROFILE LED SURFACE MOUNTED	11W / M	ON STAIRCASE	
	SPURLITE LTD	FESTOON LIGHTING	20W PER 10M	SURPASSES FESTOON	
	SPURLITE LTD	FABRY LIGHTS	7.2W PER STRING	SUSTAINED FABRY LIGHTS	
J	SPURLITE LTD	HARM 01 5W 20LM 3000K 60RA	5 W	GROUND RECESSED	

C03	CONSTRUCTION ISSUE	GP	22.04.21
C02	CONSTRUCTION ISSUE	GP	07.11.19
C01	CONSTRUCTION ISSUE	GP	16.08.19
P01	PRELIMINARY ISSUE	DS	26.03.19
Rev	Description	Drawn	Date

Briggs & Forrester Living Ltd

Bembridge House
Bembridge Drive
Kingsthorpe
Northampton

NN2 6LZ

www.briggsandforrester.co.uk
Registered in England No. 1887941

Tel: (01604) 720072



Client:

Mount Anvil



Project:

Kampus
Manchester

Drawing Title:

EXTERNAL LIGHTING LAYOUT
LEVEL 02

Scale:

1:200 @ A1

Checked:

DS

Drawing Number:

4006-BAF-ZZ-02-DR-E-(63)-014

Rev:

C03

Suitability:

S4

Drawing Status:

CONSTRUCTION

This drawing is copyright and may not be reproduced either in part or full without written permission from Briggs & Forrester Group Ltd.
DO NOT SCALE OFF THIS DRAWING



VC 658367