STORM SEWER DESIGN by the Modified Rational Method

Design Criteria for Storm

Pipe Sizes STANDARD Manhole Sizes STANDARD

FSR Rainfall Model - England and Wales

Return Period (years)	100	PIMP (%)	100
M5-60 (mm)	18.000	Add Flow / Climate Change (%)	0
Ratio R	0.355	Minimum Backdrop Height (m)	0.200
Maximum Rainfall (mm/hr)	50	Maximum Backdrop Height (m)	1.500
Maximum Time of Concentration (mins)	30	Min Design Depth for Optimisation (m)	1.200
Foul Sewage (l/s/ha)	0.000	Min Vel for Auto Design only (m/s)	1.00
Volumetric Runoff Coeff.	0.750	Min Slope for Optimisation (1:X)	500

Designed with Level Soffits

Time Area Diagram for Storm

Time (mins)	Area (ha)	Time (mins)	Area (ha)
0-4	0.016	4-8	0.001

Total Area Contributing (ha) = 0.017

Total Pipe Volume (m³) = 0.529

Network Design Table for Storm

PN	Length (m)	Fall (m)	Slope (1:X)	I.Area (ha)	T.E. (mins)	Base Flow (l/s)	k (mm)	HYD SECT	DIA (mm)	Section Type	Auto Design
S1.000	13.290	0.133	99.9	0.002	4.00	0.0	0.600	o	100	Pipe/Conduit	
S1.001	4.555	0.258	17.7	0.002	0.00	0.0	0.600	o	100	Pipe/Conduit	
S2.000	8.726	0.087	100.3	0.001	4.00	0.0	0.600	o	100	Pipe/Conduit	
S1.002	8.127	0.081	100.3	0.001	0.00	0.0	0.600	o	100	Pipe/Conduit	
S3.000	13.030	0.130	100.2	0.003	4.00	0.0	0.600	o	100	Pipe/Conduit	
S3.001	4.708	0.342	13.8	0.004	0.00	0.0	0.600	o	100	Pipe/Conduit	
S4.000	8.446	0.168	50.3	0.001	4.00	0.0	0.600	o	100	Pipe/Conduit	

Network Results Table

PN	Rain (mm/hr)	T.C. (mins)	US/IL (m)	Σ I.Area (ha)	Σ Base Flow (l/s)	Foul (l/s)	Add Flow (l/s)	Vel (m/s)	Cap (l/s)	Flow (l/s)
S1.000	50.00	4.29	80.805	0.002	0.0	0.0	0.0	0.77	6.0	0.3
S1.001	50.00	4.33	80.672	0.004	0.0	0.0	0.0	1.85	14.5	0.5
S2.000	50.00	4.19	80.501	0.001	0.0	0.0	0.0	0.77	6.0	0.2
S1.002	50.00	4.51	80.414	0.007	0.0	0.0	0.0	0.77	6.0	0.9
S3.000	50.00	4.28	80.805	0.003	0.0	0.0	0.0	0.77	6.0	0.3
S3.001	50.00	4.32	80.675	0.007	0.0	0.0	0.0	2.09	16.4	0.9
S4.000	50.00	4.13	80.501	0.001	0.0	0.0	0.0	1.09	8.6	0.1

©1982-2020 Innovyze

Network Design Table for Storm

PN	Length (m)	Fall (m)	Slope (1:X)	I.Area (ha)	T.E. (mins)	Base Flow (l/s)	k (mm)	HYD SECT	DIA (mm)	Section Type	Auto Design
S1.003	6.454	0.563	11.5	0.003	0.00	0.0	0.600	o	100	Pipe/Conduit	

Network Results Table

PN	Rain (mm/hr)	T.C. (mins)	US/IL (m)	Σ I.Area (ha)	Σ Base Flow (l/s)	Foul (l/s)	Add Flow (l/s)	Vel (m/s)	Cap (l/s)	Flow (l/s)
S1.003	50.00	4.55	80.333	0.017	0.0	0.0	0.0	2.30	18.0	2.3

©1982-2020 Innovyze

Area Summary for Storm

Pipe Number	PIMP Type	PIMP Name	PIMP (%)	Gross Area (ha)	Imp. Area (ha)	Pipe Total (ha)
1.000	User	-	100	0.002	0.002	0.002
1.001	User	-	100	0.002	0.002	0.002
2.000	User	-	100	0.001	0.001	0.001
1.002	User	-	100	0.001	0.001	0.001
3.000	User	-	100	0.003	0.003	0.003
3.001	User	-	100	0.004	0.004	0.004
4.000	User	-	100	0.001	0.001	0.001
1.003	User	-	100	0.003	0.003	0.003
				Total	Total	Total
				0.017	0.017	0.017

Free Flowing Outfall Details for Storm

Outfall Pipe Number	Outfall Name	C. Level (m)	I. Level (m)	Min I. Level (m)	D,L (mm)	W (mm)
S1.003	S	80.780	79.770	0.000	0	0

Simulation Criteria for Storm

Volumetric Runoff Coeff	0.750	Additional Flow - % of Total Flow	0.000
Areal Reduction Factor	1.000	MADD Factor * 10m³/ha Storage	2.000
Hot Start (mins)	0	Inlet Coeffiecient	0.800
Hot Start Level (mm)	0	Flow per Person per Day (l/per/day)	0.000
Manhole Headloss Coeff (Global)	0.500	Run Time (mins)	60
Foul Sewage per hectare (l/s)	0.000	Output Interval (mins)	1

Number of Input Hydrographs 0 Number of Offline Controls 0 Number of Time/Area Diagrams 0
Number of Online Controls 1 Number of Storage Structures 0 Number of Real Time Controls 0

Synthetic Rainfall Details

Rainfall Model	FSR	Profile Type	Summer
Return Period (years)	100	Cv (Summer)	0.750
Region	England and Wales	Cv (Winter)	0.840
M5-60 (mm)	18.000	Storm Duration (mins)	30
Ratio R	0.355		

©1982-2020 Innovyze

Online Controls for Storm

Orifice Manhole: S8, DS/PN: S1.003, Volume (m³): 1.0

Diameter (m) 0.052 Discharge Coefficient 0.600 Invert Level (m) 80.333

Volume Summary (Static)

Length Calculations based on Centre-Centre

Pipe Number	USMH Name	Manhole Volume (m³)	Pipe Volume (m³)	Storage Structure Volume (m³)	Total Volume (m³)
S1.000	S1	0.127	0.104	0.000	0.232
S1.001	S2	0.165	0.036	0.000	0.201
S2.000	S3	0.127	0.069	0.000	0.196
S1.002	S4	0.152	0.064	0.000	0.216
S3.000	S5	0.127	0.102	0.000	0.230
S3.001	S6	0.164	0.037	0.000	0.201
S4.000	S7	0.127	0.066	0.000	0.194
S1.003	S8	0.888	0.051	0.000	0.939
Total		1.877	0.529	0.000	2.406

Volume Summary (Static)

Length Calculations based on True Length

Pipe Number	USMH Name	Manhole Volume (m³)	Pipe Volume (m³)	Storage Structure Volume (m³)	Total Volume (m³)
S1.000	S1	0.127	0.100	0.000	0.227
S1.001	S2	0.165	0.031	0.000	0.196
S2.000	S3	0.127	0.064	0.000	0.191
S1.002	S4	0.152	0.057	0.000	0.209
S3.000	S5	0.127	0.098	0.000	0.225
S3.001	S6	0.164	0.030	0.000	0.194
S4.000	S7	0.127	0.059	0.000	0.187
S1.003	S8	0.888	0.046	0.000	0.934
Total		1.877	0.484	0.000	2.362

©1982-2020 Innovyze

100 year Return Period Summary of Critical Results by Maximum Level (Rank 1) for Storm

Simulation Criteria

Areal Reduction Factor	1.000	Additional Flow - % of Total Flow	0.000
Hot Start (mins)	0	MADD Factor * 10m³/ha Storage	2.000
Hot Start Level (mm)	0	Inlet Coeffiecient	0.800
Manhole Headloss Coeff (Global)	0.500	Flow per Person per Day (l/per/day)	0.000
Foul Sewage per hectare (l/s)	0.000		

Number of Input Hydrographs 0 Number of Offline Controls 0 Number of Time/Area Diagrams 0
Number of Online Controls 1 Number of Storage Structures 0 Number of Real Time Controls 0

Synthetic Rainfall Details

Rainfall Model	FSR	M5-60 (mm)	18.000
Region	England and Wales	Ratio R	0.354
Cv (Summer)	0.750		
Cv (Winter)	0.840		

Margin for Flood Risk Warning (mm) 300.0 DVD Status OFF
Analysis Timestep Fine Inertia Status OFF
DTS Status ON

Profile(s)	Summer and Winter
Duration(s) (mins)	15, 30, 60, 120, 240, 360, 480, 960, 1440
Return Period(s) (years)	100
Climate Change (%)	30

PN	US/MH Name	Storm	Return Period	Climate Change	First (X) Surcharge	First (Y) Flood	First (Z) Overflow	Overflow Act.	Water Level (m)	Surcharged Depth (m)	Flooded Volume (m³)
S1.000	S1	15 Winter	100	+30%	100/15 Winter				80.917	0.012	0.000
S1.001	S2	15 Winter	100	+30%	100/15 Summer				80.912	0.140	0.000
S2.000	S3	15 Winter	100	+30%	100/15 Summer				80.910	0.309	0.000
S1.002	S4	15 Winter	100	+30%	100/15 Summer				80.907	0.393	0.000
S3.000	S5	15 Winter	100	+30%	100/15 Winter				80.911	0.006	0.000
S3.001	S6	15 Winter	100	+30%	100/15 Summer				80.905	0.130	0.000
S4.000	S7	15 Winter	100	+30%	100/15 Summer				80.897	0.296	0.000
S1.003	S8	15 Winter	100	+30%	100/15 Summer				80.895	0.462	0.000

PN	US/MH Name	Flow / Cap.	Overflow (l/s)	Half Drain Time (mins)	Pipe Flow (l/s)	Status	Level Exceeded
S1.000	S1	0.18			1.0	SURCHARGED	
S1.001	S2	0.13			1.6	SURCHARGED	
S2.000	S3	0.07			0.4	FLOOD RISK	
S1.002	S4	0.29			1.6	FLOOD RISK	
S3.000	S5	0.24			1.3	SURCHARGED	
S3.001	S6	0.20			2.9	SURCHARGED	
S4.000	S7	0.04			0.4	FLOOD RISK	
S1.003	S8	0.26			4.1	FLOOD RISK	

©1982-2020 Innovyze