

sample

kampus listed buildings

10 12 2019

sample sign-off 07.03 • air bricks

description:

MVHR system supply and exhaust terminations within existing brickwork.

Cast iron double air brick - Britannia AIR 2 (225 x 150mm), painted black, mortared in and aligned to nearest brick course.

sample approved via email on 10.12.19 and also reviewed under conditions 33e and 33h (Listed building conditions 6e and 6e respectively).

location:

both buildings/all elevations

image:

