

METHOD STATEMENT

Date: May 2022

Issued by: Contracts Dept

Client: Bruntwood

Location: Longsight community Centre

Works: Plastering

STEP NUMBER	ACTION TO BE TAKEN
One	COVID-19 • Prior to work commencing all operatives must read the Covid-19 risk assessment and site operating procedures. To ensure that any additional control measures relating to the task are implemented • If any of the control measures are breached, work must stop and specific control measures put into place before work can continue. • Key points to remember at all times are: ○ Social Distancing – stay 2 metres apart ○ If 2m cannot be achieved face coverings must worn, keep this to short duration and complete a close working permit ○ Wear face coverings in communal areas and when entering and exiting the building ○ Regularly wash your hands for 20 seconds with soap and water OR use hand sanitizer provided ○ Do not come to site if you or someone you live with have symptoms of Covid-19 ○ Don't share tools if completely unavoidable ensure that they are cleaned before and after every use with antibacterial products) ○ Don't shake hands with other people
Two	• To inform anyone who may be affected by the work any dangers or hazards present. • To erect signs and/or barriers as required.

Amspec Ltd
Kilshaw Street, Wigan, WN58EA

t 01942 621342 w. www.amspec.co.uk Company No. 4379106

Three	Make sure you have the correct materials for the job and the correct quantity to complete the works.
Four	The safe use of all tools and equipment in accordance with risk assessment, ensure all tools required are in good working order.
Five	Cover any surfaces, which are to be protected against the work being carried out.
Six	- Hack off cracked and de-bonded wall plaster place all waste materials in waste bags and/ or in neat waste piles away from walk through areas. - Or ensure the plasterboard wall is prepared and joints have fibre tape applied in accordance with manufacturers recommendations
Seven	- Remove all loose particles and dust from exposed brickwork prior to applying render - Ensure plasterboard surface is free from dust particles
Eight	All beads to be cut to lengths and fixed with galvanised nails. Any scratch coat will be allowed to dry before the application of final coat which will be ruled level and finished with either wooden float or steel trowel.
Nine	- Care will be taken to ensure the correct mix as well as a good supply of clean water for mixing materials - Apply plaster mix to the wall finish at approximate thickness of 3mm
Ten	Clean work site and remove all packaging, tools and equipment

REFER TO ANY MANUFACTURES INFORMATION AS REQUIRED

Amspec Ltd
Kilshaw Street, Wigan, WN58EA

t 01942 621342 w. www.amspec.co.uk Company No. 4379106

TRAINING DECLARATION

RA Ref. No:	Plastering	Related MS	
-------------	------------	------------	--

1. I have been shown, trained and understand the safe system of work procedures of the above task/activity.
2. I agree to follow the safe system of work documented at all times.
3. I have been made aware and understand the risks associated with this task, and the consequences if this risk assessment is not adhered to.

Signature		Date	
Signature		Date	
Signature		Date	
Signature		Date	
Signature		Date	