




KEY PLAN:

SERVICE YARD PLAN VIEW

NOTES:

1) PIPEWORK SHOWN IN RED FOR VISIBILITY, TO BE LAGGED WITH GREY COVERING TO MATCH EXISTING CLADDING

2) NOISE FROM PROPOSED ASHP SHALL NOT EXCEED 5 dB ABOVE BACKGROUND NOISE LEVEL AT NEAREST RECEPTOR

P05	MC	TA	JM	17.06.21	ACOUSTIC FENCE ADDITION
P04	MC	NL	JM	14.06.21	COLOURED PIPERUN & ASHP DIMENSIONS
P03	MC	NL	JM	11.06.21	REISSUED FOR PLANNING APPLICATION
P02	MC	NL	JM	20.05.21	REISSUED FOR PLANNING APPLICATION
P01	MC	MP	JM	17.05.21	ISSUE FOR PLANNING APPLICATION
REV	BY	CHKD	APPRD	DATE	REVISION NOTES

SCALE AT A0: VARIOUS (AS LABELLED)

CLIENT:
AMERESCO

PROJECT:
WHYTHENSHAWE FORUM

DRAWING TITLE:
ASHP SYSTEM GENERAL ARRANGEMENT

DRAWING NAME:
WF1002-RMS-EL-01-ZZ-DR-M-1.301