






System: Aluprof MB-78EI Fire Rated System	
Type	ES-26 (A) FR
Location	Light well (Level 2)
QTY	1no.
Fire Rating	60 / 60
Hardware	Butt Hinges Only AOV Actuator - Supplied and Fitted By Britplas
Glazed	Internally
Opens	Side Hung - Open Out
Cill	None
Colour	RAL 7022 Matt (Interpon D SL822G)
Notes	Actuator to be Fitted on site to Allow Window to be Opened to 60° To Achieve 1.5m² Free Area

System: Kawneer AA720 Window System	
Type	ES-23
Location	Light well (Levels 3 - 8)
QTY	6no.
Hardware	None
Glazed	Internally
Opens	Fixed
Cill	None
Colour	RAL 7022 Matt (Interpon D SL822G)
Notes	-

This drawing (or any part thereof) may not be copied, transmitted or disclosed to any third party or unauthorized person without the prior written permission of Britplas.
Patent Publication No. 2446730A.
This drawing is to be read in conjunction with all other relevant drawings prepared by consultants and sub-contractors.
Do not scale from this drawing. Work only to printed dimensions.
Report any discrepancies to the Architect or representatives thereof.

Notes:
Suitable Primary/ Secondary Steelwork not by Britplas. Steelwork/ Concrete structure tolerance +/-18mm in any direction Non-accumulative.

Glazing :
F1 - 43mm thick 60 / 60 FIRE RATED GLASS
6mm low E toughened glass - Outer
12mm Argon with Steel spacer - Cavity
25mm Polflam EI60 - Inner

G1 - 32.8mm DGU
8mm HST Cool-ite Extreme 70-33 II Tgh'd - Outer
16mm Argon Cavity with Black Spacer Bar - Cavity
8.8mm Clear Laminated - Inner
U = 1.0, LT = 68.3%, G = 0.33, Rw(C, Ctr) = 38(-2, -6) dB

POINTING
Intumescent Mastic (For Fire Rated) / Standard Mastic (Non-Fire Rated), colour **RAL 7022** (or nearest equivalent), to be applied as shown by Britplas

EPDM
EPDM by Britplas to Non Fire Rated Frames

RECEIVED

14-JAN-2021
Gilbert-Ash
BOUCHER ROAD

Rev.	Description.	Date	Initials
C1	Construction Issue	14/01/21	AH
A2	Window and structure amended	08/09/20	AH
A1	Approval Issue	22/06/20	SD

Project Title

Moxy Hotel

Drawing Title

Window Schedule 03

FOR CONSTRUCTION

britplas
Unit 18 Kingsland Grange,
Woolston, Warrington,
Cheshire, WA1 4RW.
Tel - (+44) 01925 824317
Fax - (+44) 01925 284110

Britplas Commercial Ltd		
Project No.	Scale	DWG Sheet Size
6602	1:25	A3
Drawn By	Checked By	Date
DG	AH	09-06-20

Drawing Number	Rev.
BP-6602-E102	C1