


GENERAL NOTES

- 1.10 THESE DRAWINGS ARE RIBA STAGE 2+ DESIGN INTENT DRAWINGS. THE CONTRACTOR SHALL BE RESPONSIBLE FOR DEVELOPING THESE DRAWINGS TO RIBA STAGE 4 LEVEL OF DETAIL FOR FORMAL SIGN OFF BEFORE INSTALLATION ON SITE.
- 2.10 THE CONTRACTOR SHALL TAKE FULL DESIGN RESPONSIBILITY FOR THE ALL M&E DESIGN ON THE PROJECT.
- 3.10 FINAL ROOM COUNTS TO BE CONFIRMED AT A LATER STAGE. ALLOCATION OF GUESTROOM TYPE A AND B INDICATIVE FOR INFORMATION PURPOSES. THESE SHALL BE CONFIRMED POST CONTRACT AWARD.

VENTILATION SERVICES NOTES

- 1.00 ALL DUCTWORK SIZES NOTED ARE INTERNAL SIZES.
- 2.00 ACCESS GATES SHALL BE PROVIDED IN DUCTS TO ALL FIRE DAMPERS WHERE RELEVANT.
- 3.00 FIRE STOPPING SHALL BE PROVIDED ON SLAB PENETRATIONS WHERE REQUIRED.
- 4.00 CONTRACTOR TO REFER TO IN2 ENGINEERING MECHANICAL SPECIFICATION FOR FURTHER DETAIL.
- 5.00 CONTRACTOR TO REFER TO IN2 ENGINEERING M2000 SERIES DRAWINGS FOR ASSOCIATED VENTILATION DRAWINGS.
- 6.00 ALL PROPOSED DUCTWORK SIZES INDICATED ON THIS DRAWING ARE PURELY INDICATIVE TO AID IN TENDERING. THE CONTRACTOR SHALL ACCEPT FULL DESIGN RESPONSIBILITY.

VENTILATION DUCTWORK REFERENCE KEY

	EXTRACT DUCTWORK		
	SUPPLY DUCTWORK		
	FRESH AIR DUCTWORK		
	FRESH AIR DUCTWORK		
	DUCTWORK RISE / FALL	-	TO / FROM ABOVE
	DUCTWORK RISE / FALL	-	TO / FROM BELOW

ITEM KEY	DESCRIPTION	ITEM TAG
XX l/s	WALL MOUNTED SUPPLY DISC VALVE	SG.X.X.XX
XX l/s	EXTRACT DISC VALVE	EG.X.X.XX
XXX l/s	VOLUME CONTROL DAMPER	VCD.X.X.XX
	MOTORISED FIRE SMOKE DAMPER	MFSD.X.X.XX
	CROSS TALK ATTENUATOR	ATT.X.X.XX

SCOPE REFERENCE KEY

SCOPE KEY:	AS PER SCOPE	SCOPE TYPE DESCRIPTION	REF: DRAWINGS
	GUESTROOM TYPE A	OPENED BATHROOM	E-00 & M00 TYPICAL GUESTROOM DRAWINGS
	GUESTROOM TYPE B	INTERNAL REFURB BATHROOM	E-00 & M00 TYPICAL GUESTROOM DRAWINGS
	MINIMAL MEP SCOPE	MINIMAL MEP SCOPE	ELEC & MECH SPECIFICATION
	NO MEP SCOPE	NOT IN PROJECT WORKS	

