



The Hut Group

KING STREET TOWN HOUSE

Environmental noise survey report





The Hut Group

KING STREET TOWN HOUSE

Environmental noise survey report

REPORT (REV 02) PUBLIC

PROJECT NO. 70065247-R01-AC

DATE: APRIL 2021

WSP

8 First Street

Manchester

M15 4RP

Phone: +44 161 200 5000

WSP.com

QUALITY CONTROL

Issue/revision	First issue	Revision 1	Revision 2	Revision 3
Remarks	First Issue	Amendment to Table 6-1	Minor amendments	
Date	10 Dec 2020	12 Jan 2021	8 April 2021	
Prepared by	Una Brown	Una Brown	Una Brown	
Signature				
Checked by	Mark Hinds	Mark Hinds	Hannah Jones	
Signature				
Authorised by	Mark Hinds	Mark Hinds	Una Brown	
Signature				
Project number	70065247	70065247	70065247	
Report number	70065247-R01-AC	70065247-R01-AC-rev01	70065247-R01-AC-rev02	
File reference				

CONTENTS

1	INTRODUCTION	1
2	SITE DESCRIPTION	1
3	CRITERIA	2
3.1	MANCHESTER CITY COUNCIL CRITERIA	2
3.1.1	EXTERNAL PLANT NOISE LIMITS	2
3.1.2	EMERGENCY PLANT NOISE LIMITS	2
3.1.3	MAXIMUM OPERATIONAL NOISE LIMITS	2
3.1.4	INTERNAL AMBIENT NOISE LEVELS	2
3.2	BS4142:2014 METHODS FOR RATING AND ASSESSING INDUSTRIAL AND COMMERCIAL SOUND (+A1:2019)	3
4	ENVIRONMENTAL NOISE SURVEY	3
4.1	OVERVIEW	3
4.2	WEATHER CONDITIONS	4
4.3	MEASUREMENT EQUIPMENT & PERSONNEL	4
4.4	MEASUREMENT RESULTS	4
5	EXTERNAL PLANT	7
5.1	PLANT NOISE LIMITS	7
5.1.1	EMERGENCY PLANT	8
5.2	ASSESSMENT	8
5.2.1	PLANT NOISE	8
5.2.2	EMERGENCY PLANT NOISE	8
6	OPERATIONAL NOISE	10

6.1	CRITERIA	10
7	CONCLUSION	11

APPENDICES

APPENDIX A

SUMMARY OF UNATTENDED NOISE MONITORING TO DETERMINE
REPRESENTATIVE BACKGROUND NOISE LEVEL

APPENDIX B

SUMMARY OF NOISE MONITORING EQUIPMENT

APPENDIX C

TECHNICAL GLOSSARY

APPENDIX D

LIMITATIONS

1 INTRODUCTION

WSP has been appointed to undertake an environmental noise survey for the proposed refurbishment and new rooftop extension of King Street Townhouse (KSTH), Manchester.

The proposed development consists of the refurbishment of KSTH to change from a 40 key to 38 key hotel. In addition, a new roof top bar and terrace is proposed at Level 8 and the Level 7 pool and spa area is to be renovated.

An environmental noise survey has been carried out to determine the background sound levels (L_{A90} , dB) at the nearest noise sensitive receptors. The measured background sound levels have been used to set limits from any proposed building services and due to operational noise from events within the hotel in line with Manchester City Council's requirements.

The report sets out the survey methodology, results of the measurements and assessment.

2 SITE DESCRIPTION

The site is located, in the centre of Manchester and is bounded by Kennedy Street to the west and Booth Street to the east. The nearest noise-sensitive receptors are considered to be 16-24 Kennedy Street (highlighted in blue), also a THG development. No. 24 Kennedy Street is currently a private dwelling; however, it is currently vacant and is to become a luxury aparthotel, with 20 Kennedy Street becoming a hotel and 16 Kennedy providing office, training and meeting accommodation.

The adjacent building is Massey Chambers (2-6 Booth Street), with residential apartments located above. There are also a number of existing office buildings close to KSTH (highlighted in green).

Figure 2-1 shows the location of the existing hotel along with the nearest noise sensitive receptors and location of the unattended noise monitoring equipment.

Figure 2-1 – Layout showing site location and measurement positions



3 CRITERIA

3.1 MANCHESTER CITY COUNCIL CRITERIA

3.1.1 EXTERNAL PLANT NOISE LIMITS

Manchester City Council's *Planning & Noise Technical Guidance (December 2015)* requires that:

Externally mounted ancillary plant, equipment and servicing shall be selected and/or acoustically treated in accordance with a scheme designed so as to achieve a rating level of 5 dB (L_{Aeq}) below the typical background (L_{A90}) level at the nearest noise sensitive location.

It notes that the rating level is to be determined based on the methodology set out in BS 4142:2014.

3.1.2 EMERGENCY PLANT NOISE LIMITS

For emergency plant items, that will only operate outside an emergency for short periods to be tested, a higher noise limit is typically permitted. It is understood that MCC permit a level 10 dB above the existing background sound level (L_{A90}) at the nearest noise sensitive location.

The current proposal is that the existing generator will be relocated from basement level to the roof. Other than testing, it will operate in an emergency and to provide business continuity (e.g. in the event of a power cut).

Rick Knightley and Graeme Souter from MCC were contacted by email regarding the criteria that would apply to this generator and they confirmed that:

- Based on the description of usage of plant for emergency/ standby use, the 10 dB above criterion would apply.
- Testing and servicing of the equipment is to be restricted to Monday to Friday between 10:00-16:00 hrs only. In addition, occupiers of the neighbouring residential apartments at The Chambers building should be notified 5 days prior to the testing being carried out.
- The noise impact assessment should take account of the upper floors of the neighbouring residential apartments who rely on opening windows.

3.1.3 MAXIMUM OPERATIONAL NOISE LIMITS

MCC specifies that:

Entertainment noise (L_{Aeq}) should be controlled to 10 dB below the background noise level (L_{A90}) without the entertainment noise present, in each octave band at the nearest noise sensitive location.

3.1.4 INTERNAL AMBIENT NOISE LEVELS

For hotel guestrooms and offices MCC do not typically specify internal ambient noise levels. These are typically designed to specific operator requirements.

3.2 BS4142:2014 METHODS FOR RATING AND ASSESSING INDUSTRIAL AND COMMERCIAL SOUND (+A1:2019)

BS 4142:2014 *Methods for rating and assessing industrial and commercial sound* (+A1:2019, herein referred to as BS4142:2014) provides typical guidance for assessing noise emissions from new items of building services plant against the existing background noise level at the nearest noise sensitive receptors.

It states that if the noise rating level is ≥ 10 dB higher than the existing background noise level (L_{A90} dB), it provides a likely indication of a significant adverse impact. If the level is 5 dB above the existing background noise level, it provides a likely indication of an adverse impact. Where the level doesn't exceed the background noise level it is an indication of having a low impact.

It also identifies that where noise contains 'attention catching features' such as bangs, whistles, etc or is intermittent, penalties should be applied in the noise assessment.

4 ENVIRONMENTAL NOISE SURVEY

4.1 OVERVIEW

At positions L1 and L2, unattended noise monitoring equipment was installed on the roof of KTSH and left to continually record sound levels from 11:00 hrs on Thursday 24 September 2020 until 09:45 hrs on Tuesday 29 September 2020. The equipment installed at position L2 didn't record after 17:15 hrs on Saturday 26 September 2020. However, comparing the results with those at position L3, there is very little variation in background sound level. As a result the measurement duration is considered sufficient to obtain representative results.

At positions L1 and L2, the microphones were located approximately 1.5 m above roof level and at least 1 m from any other reflective surface.

At position L3 on Figure 2-1, unattended noise monitoring equipment was left to continually record sound levels from 11:45 hrs on Friday 16 October 2020 until 11:15 hrs on Monday 19 October 2020. The microphone was extended from a third floor window of 24 Kennedy Street, approximately 1 m from the façade.

The measurement positions were chosen as they provided a safe and secure location for the equipment and, are considered to be reasonably representative of the nearest noise sensitive receptors.

At position L4, unattended noise monitoring equipment was left to continually record sound levels for between Wednesday 18 March 2020 and Friday 27 March 2020. The UK lockdown resulting from the COVID-19 pandemic came into force during the evening of Monday 23 March 2020 and therefore measurements after this date are not be considered representative of the typical acoustic climate and have been excluded.

The dominant noise source noted during equipment set-up and collection was traffic along Booth Street, Kennedy Street and the surrounding roads, along with noise from existing external plant on the surrounding buildings. At position L1, noise from existing roof top plant items on KTSH dominated.

4.2 WEATHER CONDITIONS

For measurements made between 18 and 23 March, generally, the weather remained dry, though there was intermittent light rain on 18 March, with temperatures ranging from 5-10 °C. The wind speed was typically <5 m/s.

For the measurements between 24 and 29 September, generally, the weather remained dry, though there was intermittent rain on 29 September, with temperatures ranging from 9-12 °C. The wind speed was typically <5 m/s.

For the measurements between 16 and 19 October, generally, the weather remained dry throughout the duration of the survey, with temperatures ranging from 8-11 °C. The wind speed was typically <5 m/s.

Weather conditions during all surveys were considered suitable for obtaining representative background sound levels.

4.3 MEASUREMENT EQUIPMENT & PERSONNEL

Details of the measurement equipment are provided in Appendix B.

Unattended noise monitoring equipment at position L4 was installed by Chris Clayden and collected by Simon Faircloth.

Unattended noise monitoring equipment at positions L1-L3 was installed and collected by Chris Clayden.

4.4 MEASUREMENT RESULTS

A summary of the ambient noise levels measured is provided in Table 4-1

Table 4-1 – Summary of ambient noise levels at measurement position L1

Position (see Fig 2-1)	Date	<i>L</i> _{Aeq,16hrs} (dB) Daytime (07:00-23:00)	<i>L</i> _{Aeq,8hrs} (dB) Night (23:00-07:00)	<i>L</i> _{AFmax} (dB) ² Daytime (07:00-23:00)	<i>L</i> _{AFmax} (dB) ² Night (23:00-07:00)
L1	24/09/20	60 ¹	60	71	69
	25/09/20	61	60	81	66
	26/09/20	61	60	83	68
	27/09/20	60	60	68	71
	28/09/20	61	60	71	73
	29/09/20	61 ¹	-	69	-
L2	24/09/20	56	54	73	71
	25/09/20	59	54	82	66
	26/09/20	56 ¹	-	82	-

Position (see Fig 2-1)	Date	$L_{Aeq,16hrs}$ (dB) Daytime (07:00-23:00)	$L_{Aeq,8hrs}$ (dB) Night (23:00-07:00)	L_{AFmax} (dB) ² Daytime (07:00-23:00)	L_{AFmax} (dB) ² Night (23:00-07:00)
L3	16/10/20	58 ¹	57	90	84
	17/10/20	57	56	82	79
	18/10/20	57	57	86	81
	19/10/20	62 ¹	-	98	-
L4	18/03/20	59 ¹	59	84	86
	19/03/20	60	60	88	86
	20/03/20	59	58	83	84
	21/03/20	58	56	87	86
	22/03/20	57	59	80	85
	23/03/20 ³	58	57	83	84

¹Partial measurement period due to equipment set-up/ collection ²Highest recorded L_{AFmax} .

³Announcement that UK is to enter Covid-19 lockdown.

The representative background sound levels ($L_{A90,T}$, dB) have been determined based the guidance in MCC's *Planning & Noise Technical Guidance (December 2015.)*

The arithmetic average of each octave band, for each time period over the duration of the survey has been calculated. The minimum of the averages has then been used to determine the representative background sound level. Full details of the measured L_{90} levels during each 15 minute period at night and 1-hour period during the day are provided in Appendix A. Table 4-2 presents the lowest average octave band background sound levels for the day and night-time period.

Table 4-2 – Daytime and night-time background sound levels

Position	Period	Representative background sound level ($L_{90,T}$ dB) at each octave band centre frequency (Hz)								Overall A-weighted level (dB)
		63	125	250	500	1k	2k	4k	8k	
L1	Daytime 07:00-23:00	60	55	57	56	56	51	43	33	59 ($L_{A90,1hr}$)
	Night-time 23:00-07:00	59	55	57	56	56	51	44	34	59 ($L_{A90,15mins}$)
L2	Daytime 07:00-23:00	57	53	52	50	50	43	34	24	53 ($L_{A90,1hr}$)
	Night-time 23:00-07:00	56	53	51	50	49	42	34	24	52 ($L_{A90,15mins}$)

		Representative background sound level ($L_{90,T}$ dB) at each octave band centre frequency (Hz)								
Position	Period	63	125	250	500	1k	2k	4k	8k	Overall A-weighted level (dB)
L3	Daytime 07:00-23:00	56	58	52	47	50	47	41	30	54 ($L_{A90,15mins}$)
	Night-time 23:00-07:00	56	57	51	47	51	47	41	30	54 ($L_{A90,15mins}$)
L4	Daytime 07:00-23:00	54	51	52	49	48	44	35	23	52 ($L_{A90,1hr}$)
	Night-time 23:00-07:00	54	51	51	49	48	44	35	22	52 ($L_{A90,15mins}$)

5 EXTERNAL PLANT

5.1 PLANT NOISE LIMITS

As noted previously, MCC requires that:

Externally mounted ancillary plant, equipment and servicing shall be selected and/or acoustically treated in accordance with a scheme designed so as to achieve a rating level of 5 dB (L_{Aeq}) below the typical background (L_{A90}) level at the nearest noise sensitive location.

It notes that the rating level is to be determined based on the methodology set out in BS 4142:2014, taking account of any penalties due to tonality, intermittency etc.

Based on the representative background sound levels in Table 4-2, the resultant rating level from building services plant associated with the development should not exceed the limits at the nearest noise sensitive receptors. The nearest noise sensitive receptors are considered to be 16-24 Kennedy Street, apartments at 2-6 Booth Street and the office buildings opposite the site on Kennedy Street and Booth Street.

The representative background sound levels at position L3 have been used to set limits at 16-24 Kennedy Street. The measurements at position L2 have been used to set limits for the apartments located in 2-6 Booth Street, located along the Kennedy Street elevation. The measurements at position L4 have been used to set limits along Booth Street.

These limits are cumulative and include contribution from all plant associated with this development.

Table 5-1 – Rating noise level limits for external plant, 1m from noise sensitive receptor

NSR location	Period	Maximum rating noise level from external plant, 1m from façade of nearest noise sensitive receptor $L_{Ar, Tr}$ (dB)
NSR 1, Booth Street offices	Daytime (07:00-23:00)	47
	Night-time (23:00-07:00)	47
NSR 2, 2-6 Booth Street apartments (Kennedy Street elevation)	Daytime (07:00-23:00)	48
	Night-time (23:00-07:00)	47
NSR 3, 16-24 Kennedy Street	Daytime (07:00-23:00)	49
	Night-time (23:00-07:00)	49

5.1.1 EMERGENCY PLANT

As per section 3.1.2, noise from emergency plant shall not exceed the limits in Table 5-2.

Table 5-2 – Rating noise level limits for emergency plant, 1m from noise sensitive receptor

NSR location	Period	Maximum rating noise level from emergency plant, 1m from façade of nearest noise sensitive receptor L_{Aeq} (dB)
NSR 1, Booth Street offices	Daytime (07:00-23:00)	62
	Night-time (23:00-07:00)	62
NSR 2, 2-6 Booth Street apartments (Kennedy Street elevation)	Daytime (07:00-23:00)	63
	Night-time (23:00-07:00)	64
NSR 3, 16-24 Kennedy Street	Daytime (07:00-23:00)	64
	Night-time (23:00-07:00)	64

Testing of emergency plant shall be in line with the requirements of MCC as detailed in Section 3.1.2.

5.2 ASSESSMENT

5.2.1 PLANT NOISE

The majority of the external plant proposed is existing and will be remaining in a similar position as it is currently.

There are a number of outdoor condensing units located on the roof at Level 7, along Booth Street. A louvred screen surrounds the existing condensers and they are completely open to the air on top.

These units are to be relocated to a new plant deck that will sit directly above their existing location. A louvred screen shall be provided around them, as per the current arrangement. As the condensers are not getting any closer to the nearest noise sensitive receptors and are no less screened, this is considered to be a like-for-like arrangement and will not be considered in the assessment of any new plant.

Any new external plant is expected to be minimal and will be reviewed once final selections and locations are known. Once details are finalised, a detailed assessment of noise from external plant, including any low level louvres, will be carried out. If required, attenuation measures will be provided to meet the limits specified in Table 5-1.

The assessment, along with any on-site measurements of the final installed plant, shall be submitted to MCC to discharge any applicable planning conditions.

5.2.2 EMERGENCY PLANT NOISE

As per Section 3.1.2 the current proposal is to relocate the existing basement generator to roof level. The generator will be located within a louvred enclosure to provide visual screening, though

depending on air flow requirements and any attenuation measures required, this may be acoustically rated.

An initial assessment of the resultant noise level at the nearest NSRs is provided in Figure 2-1. This assumes a non-acoustically rated louvre enclosure at this stage.

Table 5-3 – Initial assessment of noise from emergency generator

Item	NSR 1 Office Booth Street	NSR 2 Apartments 2-6 Booth Street ¹	NSR 3 16-24 Kennedy Street ²
Generator sound pressure level at 7 m	68 dBA	68 dBA	68 dBA
Distance attenuation	-8 dB (20 log 17/7)	-5 dB (20 log 12/7)	-10 dB (20 log 22/7)
Screening ³	0	-9 dB (pd=0.431)	-7 (pd=0.196)
Estimated attenuation provided by weather louvre 50 % free area ⁴	-3 dB	-3 dB	-3 dB
Calculated resultant Lp at NSR	57 dBA	51 dBA	48 dBA
Criterion	≤ 62 dBA	≤ 62 dBA	≤ 64 dBA

¹Closest mansard roof window

²Based on closest window of existing building

³Attenuation at 125 Hz, assumes 3 m per floor where NSR is lower than KSTH roof

⁴Considered worst-case. Attenuation expected to be >11 dB if acoustic louvre used

The calculated level at the apartments at 2-6 Booth Street (NSR 2) is 1 dB below the representative background sound level (L_{A90} dB). Based on the guidance provided in BS4142:2014 this gives a positive indication of 'low impact' on the receptor.

6 OPERATIONAL NOISE

6.1 CRITERIA

As noted previously, MCC requires that:

Entertainment noise (L_{Aeq}) should be controlled to 10 dB below the background noise level (L_{A90}) without the entertainment noise present, in each octave band at the nearest noise sensitive location.

This criterion applies to any operational noise (e.g. amplified music from the new bar) associated with the development.

Based on the representative background noise levels as presented in Table 4-2, operational noise associated with the development should not exceed the levels presented in Table 6-1 below.

Table 6-1 – Maximum operational noise limits 1m from the nearest noise sensitive receptors.

NSR Location	Period	Octave band maximum operational noise levels (L_{eq} dB) 1m from façade of nearest noise sensitive receptor (Hz)								dBA
		63	125	250	500	1k	2k	4k	8k	
NSR 1, Offices, Booth Street	Daytime 07:00 to 23:00	44	41	42	39	38	34	24	13	42
	Night-time 23:00 to 07:00	44	41	41	39	38	34	25	12	42
NSR 2 Apartments, 2-6 Booth Street	Daytime 07:00 to 23:00	47	43	42	40	40	33	24	14	43
	Night-time 23:00 to 07:00	46	43	41	40	39	32	24	14	42
NSR 3, 16-24 Kennedy Street	Daytime 07:00 to 23:00	46	48	42	37	40	37	31	20	44
	Night-time 23:00 to 07:00	46	47	41	37	41	37	31	20	44

As the design develops, maximum internal and external operational noise limits for any new spaces proposed as part of the development will be determined based on the sound insulation performance of the building envelope such that noise egress from it does not exceed these limits.

The cumulative level from amplified music within each space, including any external terraces, will be considered.

7 CONCLUSION

An environmental noise survey has been carried out at King Street Townhouse, 24 Kennedy Street and 2-6 Booth Street, Manchester, to support the planning application for the refurbishment and new rooftop extension of King Street Townhouse.

The results have been used to determine the existing representative background sound level at the nearest noise sensitive receptors and set limits for external plant noise and operational noise (e.g. amplified music from event spaces) associated with the development.

A plant noise assessment will be required once final plant selections and locations are known.

An initial assessment of the relocated emergency generator has been undertaken which indicates that the specified criteria is capable of being met at the nearest noise sensitive receptors

The specification of any new or refurbished elements of the building envelope (e.g. windows, roof) will take account of the expected internal noise levels in the event space, which may involve amplified music. A detailed assessment of the sound insulation requirements and noise egress will be undertaken as the design progresses, and internal limits set so that the MCC criteria are met.

Appendix A

SUMMARY OF UNATTENDED NOISE MONITORING TO DETERMINE REPRESENTATIVE BACKGROUND NOISE LEVEL




Table A-1 – Measured octave band daytime $L_{90,1hr}$ levels (07:00 to 23:00) Position L1

Date	Time	Measured $L_{90,1hr}$ (dB) at each octave band centre frequency (Hz)								dBA
		63	125	250	500	1 k	2 k	4 k	8 k	
24/09/20	11:00	60.9	55.8	57.2	56.5	56.4	51	43.9	33.9	59.7
	12:00	60.7	55.7	57.2	56.3	56.2	50.8	43.6	33.4	59.5
	13:00	60.5	55.5	57	56.2	56.1	50.5	43.1	32.8	59.4
	14:00	60.8	55.6	57.1	56.5	56.3	50.8	43.7	33.5	59.6
	15:00	60.6	55.6	56.9	56.2	56.1	50.7	43.5	33.5	59.4
	16:00	60.3	55.2	56.8	56	55.9	50.5	43.3	33.1	59.2
	17:00	60.1	55.2	56.7	56	56	50.3	42.9	32.4	59.2
	18:00	59.7	54.9	56.4	56	56.1	50.4	43.2	33.1	59.2
	19:00	59.6	55.2	56.4	55.9	56	50.5	43.6	33.7	59.2
	20:00	59.4	54.9	56.5	55.9	56	50.5	43.4	33.5	59.2
	21:00	59.4	54.6	56.5	55.9	55.9	50.5	43.3	33.4	59.1
	22:00	59.4	54.8	56.4	56	56.1	50.6	43.5	33.5	59.3
25/09/20	07:00	61.4	56.4	57.5	56.6	56.7	51.3	44.1	33.8	59.9
	08:00	62.4	57.6	57.5	56.8	56.7	51.3	44.1	33.6	60
	09:00	62.4	57.3	57.7	56.8	56.7	51.3	44	33.7	60
	10:00	62	57.3	57.6	56.7	56.5	51.3	44.1	33.6	59.9
	11:00	61.9	57.2	57.7	56.8	56.6	51.2	43.8	33.1	59.9
	12:00	61.7	57	57.7	56.9	56.6	51.2	43.6	32.7	60
	13:00	61.8	57	57.6	56.8	56.5	50.9	43.3	32.3	59.8
	14:00	61.8	56.9	57.6	56.8	56.5	50.9	43.3	32.6	59.8
	15:00	61.9	56.6	57.6	56.8	56.6	50.9	43.5	32.9	59.9
	16:00	61.2	56.1	57.3	56.6	56.4	50.7	43.4	33	59.7
	17:00	61.2	55.9	57.2	56.6	56.4	50.8	43.6	33.1	59.7
	18:00	60.4	55.6	56.9	56.4	56.4	50.8	43.5	33.2	59.6
	19:00	59.8	55.1	56.8	56.2	56.2	50.8	43.8	33.5	59.5
	20:00	59.6	55.1	56.6	56.2	56.2	50.7	43.5	33.4	59.4
	21:00	59.6	55.1	56.6	56.1	56.2	50.7	43.5	33.4	59.4
	22:00	59.4	54.7	56.5	56.1	56.3	50.8	43.6	33.6	59.4

Date	Time	Measured $L_{90,1hr}$ (dB) at each octave band centre frequency (Hz)								dBA
		63	125	250	500	1 k	2 k	4 k	8 k	
26/09/20	07:00	59.5	55.4	56.7	56.4	56.3	50.9	43.6	33	59.6
	08:00	59.6	55.6	56.7	56.5	56.4	51	43.5	33	59.6
	09:00	59.5	55.5	56.7	56.4	56.5	50.9	43.4	32.9	59.6
	10:00	59.7	55.4	56.8	56.4	56.4	50.9	43.5	32.9	59.6
	11:00	60	55.7	57	56.6	56.6	50.9	43.5	32.8	59.8
	12:00	60	55.7	56.9	56.5	56.5	50.8	43.5	32.9	59.7
	13:00	60.1	55.7	56.9	56.5	56.5	50.8	43.5	33	59.7
	14:00	60.3	55.7	57	56.5	56.4	50.9	43.5	33.1	59.6
	15:00	60.2	55.6	56.8	56.2	56.2	50.8	43.6	33.2	59.5
	16:00	60.2	55.4	56.7	56.2	56.2	50.8	43.6	33.4	59.4
	17:00	60.1	55.6	56.8	56.3	56.3	50.9	43.8	33.4	59.5
	18:00	60.1	55.6	56.8	56.3	56.2	50.8	43.6	33	59.5
	19:00	59.9	55.5	56.8	56.4	56.5	50.9	43.7	33.3	59.7
	20:00	60.2	56	56.8	56.4	56.4	50.8	43.4	32.9	59.6
	21:00	59.9	55.5	56.7	56.4	56.4	50.7	43.5	33	59.6
	22:00	60.1	55.4	56.7	56.3	56.3	50.7	43.4	33.1	59.5
27/09/20	07:00	60	55.5	56.8	56.6	56.5	51.1	44	34	59.8
	08:00	60.1	55.6	56.8	56.6	56.5	51.1	43.9	33.8	59.7
	09:00	60.3	55.8	56.9	56.7	56.7	51.1	43.9	33.9	59.9
	10:00	59.8	55.5	56.8	56.4	56.5	51	43.8	33.6	59.7
	11:00	59.7	55.6	56.7	56.2	56.3	50.8	43.6	33.3	59.5
	12:00	59.6	55.5	56.8	56.2	56.2	50.7	43.6	33.3	59.4
	13:00	59.5	55.2	56.7	56.2	56.2	50.7	43.3	33	59.4
	14:00	59.5	55.2	56.7	56.2	56.2	50.5	43.2	32.9	59.4
	15:00	59.5	55.4	56.7	56.2	56.2	50.5	43.2	33	59.4
	16:00	59.4	55.1	56.4	56	56	50.3	43	32.7	59.2
	17:00	59.4	55.1	56.5	56.1	56.1	50.4	43.1	32.9	59.3
	18:00	59.3	55.2	56.6	56.1	56.1	50.5	43.4	33.3	59.3
	19:00	59.1	55	56.6	56.1	56	50.5	43.4	33.4	59.2

Date	Time	Measured $L_{90,1hr}$ (dB) at each octave band centre frequency (Hz)								dBA
		63	125	250	500	1 k	2 k	4 k	8 k	
	20:00	59.4	55.2	56.6	56.2	56.2	50.6	43.6	33.6	59.4
	21:00	59.8	55.1	56.6	56.2	56.3	50.8	43.7	33.6	59.5
	22:00	59.8	55.3	56.5	56.1	56.3	50.7	43.7	33.7	59.4
28/09/20	07:00	62.7	57.5	58	56.9	56.7	51.4	44.3	34	60.1
	08:00	63.9	58.3	58.2	57	56.7	51.6	44.3	34.3	60.2
	09:00	63.1	58.3	58	56.9	56.7	51.4	44.3	34.3	60.1
	10:00	62.2	57.6	57.9	57.1	56.9	51.5	44.2	34.3	60.2
	11:00	62.1	57.5	57.8	57	56.8	51.3	44.2	34.2	60.1
	12:00	62.1	57.3	57.7	57	56.7	51.2	44	34.1	60
	13:00	61.6	56.8	57.8	56.8	56.6	51.1	43.8	34	59.9
	14:00	61.2	56.5	57.6	56.5	56.5	50.9	43.8	34.1	59.8
	15:00	61	56.5	57.6	56.5	56.4	50.9	43.9	34.4	59.7
	16:00	60.7	56.3	57.5	56.4	56.4	50.8	43.8	34.7	59.7
	17:00	60.4	56	57.5	56.4	56.4	50.8	44	35	59.7
	18:00	59.9	55.5	56.8	56	56.2	50.8	44	35.2	59.4
	19:00	59.3	55.3	56.8	56	56.3	51	44.4	35.5	59.5
	20:00	59.1	54.9	56.7	56.1	56.3	50.9	44.2	35.3	59.5
	21:00	58.9	54.7	56.7	56.1	56.4	50.9	44.2	35.3	59.5
	22:00	59.2	54.6	56.9	56.3	56.5	51.1	44.2	35.4	59.7
29/09/20	07:00	60.6	55.9	57.3	56.4	56.5	51.1	44.3	35	59.8
	08:00	60.9	56.2	57.3	56.5	56.5	51.2	44.5	35.1	59.8
	09:00	61.1	56.5	57.3	56.5	56.4	51.2	44.5	35.2	59.8

Table A-2 – Arithmetic average octave band daytime $L_{90,1hr}$ levels Position L1

Time	Arithmetic average of measured $L_{90,1hr}$ (dB) at each octave band centre frequency (Hz)								
	63	125	250	500	1k	2k	4k	8k	dBA
07:00	60.8	56.1	57.3	56.6	56.5	51.2	44.1	34.0	59.8
08:00	61.4	56.7	57.3	56.7	56.6	51.2	44.1	34.0	59.9
09:00	61.3	56.7	57.3	56.7	56.6	51.2	44.0	34.0	59.9
10:00	60.9	56.5	57.3	56.7	56.6	51.2	43.9	33.6	59.9
11:00	60.9	56.4	57.3	56.6	56.5	51.0	43.8	33.5	59.8
12:00	60.8	56.2	57.3	56.6	56.4	50.9	43.7	33.3	59.7
13:00	60.7	56.0	57.2	56.5	56.4	50.8	43.4	33.0	59.6
14:00	60.7	56.0	57.2	56.5	56.4	50.8	43.5	33.2	59.6
15:00	60.6	55.9	57.1	56.4	56.3	50.8	43.5	33.4	59.6
16:00	60.4	55.6	56.9	56.2	56.2	50.6	43.4	33.4	59.4
17:00	60.2	55.6	56.9	56.3	56.2	50.6	43.5	33.4	59.5
18:00	59.9	55.4	56.7	56.2	56.2	50.7	43.5	33.6	59.4
19:00	59.5	55.2	56.7	56.1	56.2	50.7	43.8	33.9	59.4
20:00	59.5	55.2	56.6	56.2	56.2	50.7	43.6	33.7	59.4
21:00	59.5	55.0	56.6	56.1	56.2	50.7	43.6	33.7	59.4
22:00	59.6	55.0	56.6	56.2	56.3	50.8	43.7	33.9	59.5
Lowest	59.5	55.0	56.6	56.1	56.2	50.6	43.4	33.0	59.4

Table A-3 - Measured octave band night-time $L_{90,15 \text{ min}}$ levels (23:00 to 07:00) Position L1

Date	Time	Measured $L_{90,15 \text{ mins}}$ (dB) at each octave band centre frequency (Hz)								
		63	125	250	500	1k	2k	4k	8k	dBA
24/09/20	23:00	59.6	55.6	56.6	56	56.1	50.6	43.6	33.5	59.3
	23:15	59.6	55.4	56.7	56.2	56.1	50.7	43.6	33.7	59.4
	23:30	59.2	55	56.4	55.9	56.1	50.7	43.7	33.8	59.3
	23:45	59.2	55.1	56.4	55.9	56.1	50.5	43.5	33.6	59.2
	00:00	59.2	54.9	56.4	55.9	56	50.7	43.6	33.8	59.2
	00:15	59.1	55	56.5	55.9	56	50.8	43.7	33.8	59.3
	00:30	59.1	54.9	56.5	56	56	50.7	43.7	34.2	59.3
	00:45	58.8	54.4	56.5	55.9	56	50.8	43.8	34.1	59.3
	01:00	58.5	54.2	56.4	55.8	55.9	50.6	43.6	33.8	59.1
	01:15	58.7	54.4	56.4	55.9	55.9	50.6	43.7	34.1	59.2
	01:30	58.6	54.2	56.3	55.8	55.9	50.6	43.7	34	59.1
	01:45	58.5	54.2	56.4	55.9	56	50.7	43.8	34.1	59.2
	02:00	58.5	54.2	56.3	55.9	56	50.7	43.7	34	59.2
	02:15	58.6	54.3	56.5	55.9	56	50.7	43.8	34	59.2
	02:30	58.7	54.3	56.4	55.9	55.9	50.7	43.7	33.8	59.2
	02:45	58.6	54.3	56.4	55.9	55.9	50.6	43.7	33.8	59.2
	03:00	58.6	54.3	56.4	55.9	56	50.6	43.6	33.7	59.2
	03:15	58.7	54.3	56.4	55.9	56	50.5	43.4	33.4	59.2
	03:30	58.8	54.3	56.4	56	56.2	50.6	43.5	33.5	59.3
	03:45	58.9	54.5	56.5	56	56.2	50.7	43.6	33.5	59.4
	04:00	59.1	54.5	56.6	56	56.2	50.6	43.5	33.3	59.3
	04:15	58.9	54.3	56.6	56	56.2	50.7	43.6	33.5	59.4
	04:30	58.8	54.4	56.5	56	56.1	50.7	43.5	33.3	59.3
	04:45	58.8	54.6	56.6	56.1	56.3	50.7	43.5	33.4	59.4
	05:00	58.8	54.6	56.6	56.1	56.3	50.7	43.6	33.4	59.4
	05:15	59.6	55.3	56.8	56.2	56.3	50.7	43.6	33.4	59.5
	05:30	60	55.7	56.8	56.2	56.3	50.7	43.5	33.3	59.5
	05:45	60.5	56.3	57	56.3	56.5	50.9	43.6	33.3	59.7

Date	Time	Measured $L_{90,15\text{mins}}$ (dB) at each octave band centre frequency (Hz)								
		63	125	250	500	1k	2k	4k	8k	dBA
	06:00	60.8	56.4	57.2	56.9	56.7	51.6	44.2	33.8	60.1
	06:15	60.5	56.2	57.1	56.4	56.5	51	43.8	33.6	59.7
	06:30	60.6	55.8	57.3	56.5	56.6	50.9	43.8	33.6	59.8
	06:45	61.2	56.3	57.5	56.7	56.7	51.2	44.1	33.8	60
25/09/20	23:00	59.6	54.7	56.6	56.3	56.4	50.8	43.7	33.6	59.5
	23:15	59.3	54.7	56.7	56.3	56.5	50.9	43.8	33.7	59.6
	23:30	59	54.5	56.6	56.2	56.4	50.8	43.6	33.4	59.5
	23:45	58.9	54.4	56.5	56.2	56.3	50.7	43.5	33.3	59.4
	00:00	59	54.4	56.5	56.2	56.3	50.7	43.5	33.2	59.4
	00:15	58.8	54.2	56.4	56.2	56.4	50.7	43.5	33.3	59.5
	00:30	58.9	54.4	56.5	56.2	56.3	50.7	43.5	33.2	59.4
	00:45	58.9	54.6	56.5	56.2	56.3	50.8	43.5	33.1	59.5
	01:00	58.8	54.4	56.5	56.2	56.3	50.8	43.6	33.2	59.5
	01:15	58.7	54.5	56.6	56.2	56.3	50.8	43.5	33.2	59.5
	01:30	58.7	54.4	56.4	56.2	56.4	50.7	43.5	33.2	59.5
	01:45	58.9	54.5	56.5	56.2	56.4	50.8	43.6	33.4	59.5
	02:00	58.8	54.5	56.4	56.2	56.5	50.8	43.6	33.4	59.6
	02:15	58.9	54.6	56.6	56.1	56.4	50.7	43.5	33.3	59.5
	02:30	58.9	54.5	56.5	56.2	56.4	50.7	43.5	33.1	59.5
	02:45	58.8	54.5	56.5	56.2	56.4	50.7	43.4	33.1	59.5
	03:00	58.7	54.4	56.6	56	56.2	50.6	43.3	33	59.3
	03:15	58.8	54.8	56.7	56.1	56.2	50.7	43.4	33.2	59.4
	03:30	58.7	54.6	56.5	56.1	56.1	50.6	43.4	33.1	59.3
	03:45	59	54.7	56.6	56.1	56.1	50.6	43.2	32.9	59.3
	04:00	58.8	54.7	56.6	56.1	56.2	50.6	43.2	32.8	59.4
	04:15	58.7	54.6	56.7	56.1	56.1	50.6	43.2	32.8	59.3
	04:30	58.8	54.5	56.6	56.2	56	50.7	43.3	32.8	59.3
	04:45	58.8	54.8	56.6	56.1	56.1	50.6	43.2	32.8	59.3
	05:00	58.8	54.5	56.7	56.1	56.1	50.6	43.2	32.7	59.3

Date	Time	Measured $L_{90,15\text{mins}}$ (dB) at each octave band centre frequency (Hz)								
		63	125	250	500	1k	2k	4k	8k	dBA
	05:15	58.9	54.7	56.6	56.2	56.1	50.6	43.2	32.7	59.3
	05:30	58.9	54.5	56.5	56.2	56.1	50.7	43.3	32.8	59.3
	05:45	59.2	54.8	56.7	56.3	56.2	50.7	43.2	32.8	59.4
	06:00	59.5	55.4	56.9	57.1	56.5	51.4	43.7	33.1	59.9
	06:15	59.4	55	56.8	56.2	56.2	50.8	43.4	32.9	59.4
	06:30	59.6	55.5	56.8	56.3	56.3	50.9	43.5	33	59.5
	06:45	60	55.5	56.9	56.5	56.5	51.1	43.7	33.1	59.7
26/09/20	23:00	60.4	56	56.7	56.2	56.2	50.6	43.4	33.1	59.4
	23:15	59.8	55.9	56.7	56.2	56.2	50.6	43.4	33	59.4
	23:30	59.7	55.5	56.6	56.2	56.1	50.7	43.5	33.2	59.4
	23:45	59.6	55.1	56.5	56.2	56.1	50.6	43.5	33.3	59.3
	00:00	59.6	55.2	56.6	56.1	56.1	50.5	43.4	33.2	59.3
	00:15	59.9	55.3	56.6	56.2	56.1	50.5	43.5	33.3	59.3
	00:30	59.7	55.7	56.6	56.2	56.1	50.6	43.5	33.5	59.3
	00:45	59.7	55.7	56.5	56.2	56.1	50.6	43.4	33.2	59.3
	01:00	59.5	55.1	56.5	56.1	56.1	50.6	43.6	33.4	59.3
	01:15	59.6	55.4	56.6	56.1	56.1	50.6	43.5	33.4	59.3
	01:30	59.6	55.4	56.6	56.1	56.1	50.6	43.5	33.4	59.3
	01:45	59.7	55.7	56.6	56.1	56.1	50.7	43.6	33.6	59.3
	02:00	59.5	55.5	56.5	56.2	56.2	50.7	43.7	33.7	59.4
	02:15	59.6	55.5	56.5	56.1	56.2	50.7	43.6	33.5	59.4
	02:30	59.6	55.5	56.5	56.2	56.2	50.6	43.5	33.5	59.4
	02:45	59.5	55.5	56.5	56.2	56.3	50.7	43.5	33.4	59.5
	03:00	59.4	55.6	56.5	56.2	56.3	50.7	43.6	33.5	59.5
	03:15	59.2	55.2	56.4	56.2	56.4	50.7	43.6	33.7	59.5
	03:30	59.2	55	56.6	56.1	56.4	50.7	43.6	33.6	59.5
	03:45	59.2	55.1	56.5	56.2	56.3	50.7	43.5	33.5	59.4
	04:00	59.2	55	56.4	56.1	56.3	50.7	43.5	33.5	59.4
	04:15	59.2	55.1	56.4	56.1	56.3	50.7	43.5	33.4	59.4

Date	Time	Measured $L_{90,15\text{mins}}$ (dB) at each octave band centre frequency (Hz)								
		63	125	250	500	1k	2k	4k	8k	dBA
	04:30	59.2	55.1	56.5	56.1	56.3	50.7	43.4	33.4	59.4
	04:45	59.2	55.1	56.5	56.2	56.3	50.8	43.6	33.5	59.5
	05:00	59.2	55.1	56.5	56.2	56.3	50.8	43.6	33.5	59.5
	05:15	59.3	55.2	56.4	56.2	56.4	50.8	43.6	33.5	59.5
	05:30	59.8	55.4	56.7	56.4	56.5	50.9	43.8	33.8	59.7
	05:45	59.9	55.4	56.6	56.3	56.4	50.8	43.7	33.7	59.6
	06:00	60.1	55.7	56.6	57.1	56.7	51.7	44.2	34.1	60.1
	06:15	59.5	54.8	56.6	56.3	56.4	50.9	43.9	33.9	59.6
	06:30	60	55.5	56.8	56.5	56.6	51	43.9	34	59.8
	06:45	60.4	55.5	56.9	56.6	56.5	51.1	43.9	33.9	59.8
27/09/20	23:00	59.6	54.8	56.5	56.1	56.2	50.8	43.8	33.8	59.4
	23:15	59.4	55.1	56.5	56.1	56.2	50.8	43.7	33.9	59.4
	23:30	59.5	55.6	56.5	56.1	56.1	50.7	43.5	33.6	59.3
	23:45	59.1	55	56.5	56.1	56.2	50.9	43.9	33.9	59.4
	00:00	58.7	54.5	56.5	56.2	56.3	50.9	44	34.2	59.5
	00:15	58.6	54.4	56.5	56.1	56.3	50.9	44	34.1	59.5
	00:30	59.4	54.7	56.6	56.2	56.3	51	43.9	34.1	59.5
	00:45	59.9	55.3	56.6	56.2	56.3	51	43.9	34.2	59.5
	01:00	60.1	55.2	56.6	56.2	56.4	51	44	34.2	59.6
	01:15	60	55.2	56.6	56.1	56.2	50.9	43.9	34	59.4
	01:30	59.9	55.3	56.6	56	56.2	50.9	43.9	34.1	59.4
	01:45	59.9	55.4	56.7	56.2	56.3	50.9	43.9	34.1	59.5
	02:00	59.9	55	56.7	56.3	56.3	50.9	43.8	34.2	59.5
	02:15	60.1	55.3	56.7	56.4	56.5	51	43.8	34	59.7
	02:30	60.1	55.3	56.8	56.4	56.4	50.9	43.7	33.7	59.6
	02:45	60.2	55.6	56.8	56.5	56.5	51.1	44	34.2	59.7
	03:00	60.1	55.5	56.7	56.5	56.4	51.1	44	34.2	59.7
	03:15	60.2	55.4	56.8	56.5	56.4	51.1	44	34.1	59.7
	03:30	60.3	55.4	56.8	56.6	56.4	51.2	44	34.2	59.7

Date	Time	Measured $L_{90,15\text{mins}}$ (dB) at each octave band centre frequency (Hz)								
		63	125	250	500	1k	2k	4k	8k	dBA
	03:45	60.2	55.6	56.8	56.5	56.5	51.1	44	34.2	59.7
	04:00	60.2	55.5	56.8	56.4	56.4	51.1	43.9	34	59.7
	04:15	60.2	55.4	56.8	56.5	56.4	51.1	43.9	34	59.7
	04:30	60.3	55.6	56.8	56.4	56.4	51.1	44	34.1	59.7
	04:45	60.3	55.6	56.9	56.6	56.5	51.2	43.9	34	59.8
	05:00	60.4	55.8	57	56.6	56.5	51.2	44	34	59.8
	05:15	60.5	55.6	57	56.6	56.5	51.2	44	34	59.8
	05:30	60.2	55.7	57	56.7	56.6	51.2	44.1	34.1	59.9
	05:45	60.9	56.2	57.3	56.8	56.7	51.4	44.3	34.1	60
	06:00	61.7	56.5	57.4	57.2	56.8	52.1	44.6	34.4	60.3
	06:15	61.9	56.9	57.4	56.7	56.6	51.4	44.4	34.2	60
	06:30	62	57	57.7	56.6	56.5	51.4	44.3	34.1	59.9
	06:45	62	57	58	56.8	56.6	51.4	44.3	34	60
28/09/20	23:00	59	54.7	56.9	56.3	56.5	51.1	44.3	35.4	59.7
	23:15	59	54.8	56.9	56.5	56.6	51.2	44.4	35.5	59.8
	23:30	59.1	54.8	56.8	56.3	56.5	51	44.1	35.3	59.7
	23:45	58.9	54.5	56.7	56.3	56.4	51	44	35.2	59.6
	00:00	58.7	54.7	56.7	56.2	56.5	51	44.2	35.3	59.6
	00:15	58.8	54.5	56.7	56.2	56.4	50.9	44.1	35.3	59.6
	00:30	58.7	54.5	56.7	56.3	56.5	51	44.2	35.3	59.7
	00:45	58.7	54.6	56.7	56.2	56.5	50.9	44.1	35.2	59.6
	01:00	58.7	54.4	56.7	56.2	56.4	50.8	44	35.1	59.5
	01:15	58.7	54.6	56.8	56.2	56.5	50.9	44.1	35.1	59.6
	01:30	58.8	54.6	56.7	56.2	56.5	51	44.2	35.1	59.6
	01:45	58.8	54.5	56.7	56.1	56.3	50.9	44.1	35.1	59.5
	02:00	58.6	54.5	56.7	56.2	56.2	50.9	44.1	35.1	59.5
	02:15	58.8	54.8	56.8	56.2	56.2	50.9	44.1	35.1	59.5
	02:30	58.7	54.6	56.6	56.2	56.2	50.8	44	35	59.4
	02:45	58.6	54.6	56.6	56.2	56.2	51	44.1	35.1	59.5

Date	Time	Measured $L_{90,15\text{mins}}$ (dB) at each octave band centre frequency (Hz)								
		63	125	250	500	1k	2k	4k	8k	dBA
	03:00	58.6	54.7	56.6	56.1	56.2	51	44.2	35.1	59.5
	03:15	58.4	54.4	56.3	55.8	55.9	50.8	44	35	59.2
	03:30	58.3	54.4	56.3	55.8	55.9	50.6	43.9	34.8	59.1
	03:45	58.3	54.3	56.4	55.8	55.8	50.5	43.6	34.5	59.1
	04:00	58.2	54.2	56.3	55.8	55.9	50.6	43.8	34.7	59.1
	04:15	58.3	54.2	56.3	55.8	55.9	50.8	44	34.9	59.2
	04:30	58.4	54.2	56.3	55.8	55.9	50.7	43.9	34.7	59.2
	04:45	58.4	54.3	56.3	55.8	55.9	50.7	44	34.8	59.2
	05:00	58.4	54.3	56.4	55.9	56	50.7	44	34.8	59.2
	05:15	58.9	54.8	56.4	55.9	56	50.7	44	34.8	59.2
	05:30	59.3	55	56.4	55.9	55.9	50.6	43.8	34.7	59.2
	05:45	60	55.4	56.6	56.3	56.4	51	44.2	34.9	59.6
	06:00	60.6	55.8	56.8	56.8	56.6	51.5	44.4	35.1	59.9
	06:15	60.7	55.9	56.9	56.3	56.4	51	44.3	35	59.6
	06:30	60.7	55.9	57	56.3	56.4	51.1	44.3	35.1	59.7
	06:45	60.8	55.9	57.2	56.4	56.5	51.2	44.4	35.2	59.8

Table A-4 - Arithmetic average octave band night-time $L_{90,15\text{min}}$ levels Position L1

Time	Measured $L_{90,1\text{hr}}$ (dB) at each octave band centre frequency								
	63 Hz	125 Hz	250 Hz	500 Hz	1 kHz	2 kHz	4 kHz	8 kHz	dBA
23:00	59.6	55.2	56.7	56.2	56.3	50.8	43.8	33.9	59.5
23:15	59.4	55.2	56.7	56.3	56.3	50.8	43.8	34.0	59.5
23:30	59.3	55.1	56.6	56.1	56.2	50.8	43.7	33.9	59.5
23:45	59.1	54.8	56.5	56.1	56.2	50.7	43.7	33.9	59.5
00:00	59.0	54.7	56.5	56.1	56.2	50.8	43.7	33.9	59.5
00:15	59.0	54.7	56.5	56.1	56.2	50.8	43.8	34.0	59.5
00:30	59.2	54.8	56.6	56.2	56.2	50.8	43.8	34.1	59.5
00:45	59.2	54.9	56.6	56.1	56.2	50.8	43.7	34.0	59.5
01:00	59.1	54.7	56.5	56.1	56.2	50.8	43.8	33.9	59.5
01:15	59.1	54.8	56.6	56.1	56.2	50.8	43.7	34.0	59.5

Time	Measured $L_{90,1hr}$ (dB) at each octave band centre frequency								
	63 Hz	125 Hz	250 Hz	500 Hz	1 kHz	2 kHz	4 kHz	8 kHz	dBA
01:30	59.1	54.8	56.5	56.1	56.2	50.8	43.8	34.0	59.5
01:45	59.2	54.9	56.6	56.1	56.2	50.8	43.8	34.1	59.5
02:00	59.1	54.7	56.5	56.2	56.2	50.8	43.8	34.1	59.5
02:15	59.2	54.9	56.6	56.1	56.3	50.8	43.8	34.0	59.4
02:30	59.2	54.8	56.6	56.2	56.2	50.7	43.7	33.8	59.4
02:45	59.1	54.9	56.6	56.2	56.3	50.8	43.7	33.9	59.4
03:00	59.1	54.9	56.6	56.1	56.2	50.8	43.7	33.9	59.4
03:15	59.1	54.8	56.5	56.1	56.2	50.8	43.7	33.9	59.4
03:30	59.1	54.7	56.5	56.1	56.2	50.7	43.7	33.8	59.4
03:45	59.1	54.8	56.6	56.1	56.2	50.7	43.6	33.7	59.4
04:00	59.1	54.8	56.5	56.1	56.2	50.7	43.6	33.7	59.5
04:15	59.1	54.7	56.6	56.1	56.2	50.8	43.6	33.7	59.5
04:30	59.1	54.8	56.5	56.1	56.1	50.8	43.6	33.7	59.5
04:45	59.1	54.9	56.6	56.2	56.2	50.8	43.6	33.7	59.6
05:00	59.1	54.9	56.6	56.2	56.2	50.8	43.7	33.7	60.1
05:15	59.4	55.1	56.6	56.2	56.3	50.8	43.7	33.7	59.6
05:30	59.6	55.3	56.7	56.3	56.3	50.8	43.7	33.7	59.7
05:45	60.1	55.6	56.8	56.4	56.4	51.0	43.8	33.8	59.8
06:00	60.5	56.0	57.0	57.0	56.7	51.7	44.2	34.1	59.5
06:15	60.4	55.8	57.0	56.4	56.4	51.0	44.0	33.9	59.5
06:30	60.6	55.9	57.1	56.4	56.5	51.1	44.0	34.0	59.5
06:45	60.9	56.0	57.3	56.6	56.6	51.2	44.1	34.0	59.5
Minimum	59.0	54.7	56.5	56.1	56.1	50.7	43.6	33.7	59.4

Table A-5 – Measured octave band daytime $L_{90,1hr}$ levels (07:00 to 23:00) Position L2

Date	Time	Measured $L_{90,1hr}$ (dB) at each octave band centre frequency (Hz)								dBA
		63	125	250	500	1 k	2 k	4 k	8 k	
24/09/20	11:00	59.4	55.1	53.6	52.3	51.4	45.2	36.9	25.8	54.9
	12:00	59.3	55	53.6	52.3	51.4	45.3	36.8	25.4	54.9
	13:00	59	55	53.5	52.2	51.3	45	36.1	24.6	54.8
	14:00	59.5	55.4	53.4	51.9	50.4	44.5	36	24.6	54.3
	15:00	59.1	55.1	53.4	51.8	50.2	44.4	36.1	24.9	54.1
	16:00	58.4	54.4	53	51.6	50.7	44.8	36	24.8	54.3
	17:00	58.1	54.5	53	51.5	50.3	44.3	35.4	23.8	54
	18:00	57.9	54.5	52.8	51.3	49.8	43.8	35.2	24.1	53.6
	19:00	56.3	54.1	52.2	51.1	50.1	43.9	35.6	25.2	53.6
	20:00	56.2	53.8	51.7	50.5	49.8	43.4	34.5	24.2	53.2
	21:00	55.7	53.1	51.4	50.1	49.7	43.3	34.3	23.8	53
	22:00	55.8	52.8	51.2	50	49.6	43.2	34.2	23.8	52.9
25/09/20	07:00	59.9	55.7	54.1	52.3	51.3	45.3	36.5	25.7	55
	08:00	61	56.4	54.4	52.9	51.8	46.1	37.5	25.8	55.5
	09:00	61.5	56.7	54.5	52.8	51.5	45.7	37.4	25.7	55.3
	10:00	61.3	56.5	54.4	52.7	51.3	45.8	37.2	25.7	55.2
	11:00	61	56.9	54.7	52.9	51.6	45.9	37.2	25.2	55.5
	12:00	60.7	56.7	54.7	53	51.8	45.7	36.6	24.7	55.5
	13:00	60.7	56.4	54.6	52.9	51.6	45.5	36.2	24.1	55.4
	14:00	60.8	56.8	54.8	53.1	51.6	45.4	36.3	24.4	55.4
	15:00	61	57	54.9	53.1	51.5	45.3	36.3	24.9	55.4
	16:00	60.5	56.2	54.3	52.7	51.2	44.8	35.9	24.9	55
	17:00	60.1	55.7	54.1	52.4	51	44.6	36	24.9	54.8
	18:00	59.1	55.1	53.5	52.1	51	44.6	35.7	24.8	54.6
	19:00	57.3	54.5	53	51.8	51	44.7	36	25.2	54.4
	20:00	57.9	54.9	52.8	51.3	50.4	44	35.1	24.9	53.9
	21:00	57.5	54.5	52.3	51	50.2	43.7	34.6	24.5	53.6
	22:00	57.6	53.9	51.9	50.6	49.9	43.4	34.5	24.4	53.3

Date	Time	Measured $L_{90,1hr}$ (dB) at each octave band centre frequency (Hz)								dBA
		63	125	250	500	1 k	2 k	4 k	8 k	
26/09/20	07:00	57.8	54.7	52.6	51.2	49.9	43.3	35.1	24.8	53.6
	08:00	58.5	55.1	52.8	51.2	49.5	43.2	35.2	24.5	53.4
	09:00	58.1	55.1	52.8	51.2	49.6	43.6	35.2	24.4	53.5
	10:00	58	55.3	52.9	51.4	50.1	44	35.5	24.5	53.9
	11:00	58.3	55.3	53.2	51.6	50.4	44.1	35.4	24.5	54.1
	12:00	58.6	55.2	53.3	51.7	50.6	44.2	35.6	24.8	54.2
	13:00	58.7	55.2	53.2	51.7	50.6	44.3	35.6	24.9	54.2
	14:00	59	55.1	53.3	51.9	50.9	44.6	35.7	25	54.5
	15:00	58.8	55.2	53.3	52	51	44.8	36	25.1	54.6
	16:00	58.5	55.1	53.2	51.9	50.8	44.6	36	25.2	54.4

Table A-6 – Arithmetic average octave band daytime $L_{90,1hr}$ levels Position L2

Time	Arithmetic average of measured $L_{90,1hr}$ (dB) at each octave band centre frequency (Hz)								
	63	125	250	500	1k	2k	4k	8k	dBA
07:00	58.9	55.2	53.4	51.8	50.6	44.3	35.8	25.3	54.3
08:00	59.8	55.8	53.6	52.1	50.7	44.7	36.4	25.2	54.5
09:00	59.8	55.9	53.7	52.0	50.6	44.7	36.3	25.1	54.4
10:00	59.7	55.9	53.7	52.1	50.7	44.9	36.4	25.1	54.5
11:00	59.6	55.8	53.8	52.3	51.1	45.1	36.5	25.2	54.8
12:00	59.5	55.6	53.9	52.3	51.3	45.1	36.3	25.0	54.9
13:00	59.5	55.5	53.8	52.3	51.2	44.9	36.0	24.5	54.8
14:00	59.8	55.8	53.8	52.3	51.0	44.8	36.0	24.7	54.7
15:00	59.6	55.8	53.9	52.3	50.9	44.8	36.1	25.0	54.7
16:00	59.1	55.2	53.5	52.1	50.9	44.7	36.0	25.0	54.6
17:00	59.1	55.1	53.6	52.0	50.7	44.5	35.7	24.4	54.4
18:00	58.5	54.8	53.2	51.7	50.4	44.2	35.5	24.5	54.1
19:00	56.8	54.3	52.6	51.5	50.6	44.3	35.8	25.2	54.0
20:00	57.1	54.4	52.3	50.9	50.1	43.7	34.8	24.6	53.6
21:00	56.6	53.8	51.9	50.6	50.0	43.5	34.5	24.2	53.3
22:00	56.7	53.4	51.6	50.3	49.8	43.3	34.4	24.1	53.1

Time	Arithmetic average of measured $L_{90,1hr}$ (dB) at each octave band centre frequency (Hz)								
	63	125	250	500	1k	2k	4k	8k	dBA
Lowest	56.6	53.4	51.6	50.3	49.8	43.3	34.4	24.1	53.1

Table A-7 - Measured octave band night-time $L_{90,15 \text{ min}}$ levels (23:00 to 07:00) Position L2

Date	Time	Measured $L_{90,15mins}$ (dB) at each octave band centre frequency (Hz)								
		63	125	250	500	1k	2k	4k	8k	dBA
24/09/20	23:00	59.6	55.6	56.6	56	56.1	50.6	43.6	33.5	59.3
	23:15	59.6	55.4	56.7	56.2	56.1	50.7	43.6	33.7	59.4
	23:30	59.2	55	56.4	55.9	56.1	50.7	43.7	33.8	59.3
	23:45	59.2	55.1	56.4	55.9	56.1	50.5	43.5	33.6	59.2
	00:00	59.2	54.9	56.4	55.9	56	50.7	43.6	33.8	59.2
	00:15	59.1	55	56.5	55.9	56	50.8	43.7	33.8	59.3
	00:30	59.1	54.9	56.5	56	56	50.7	43.7	34.2	59.3
	00:45	58.8	54.4	56.5	55.9	56	50.8	43.8	34.1	59.3
	01:00	58.5	54.2	56.4	55.8	55.9	50.6	43.6	33.8	59.1
	01:15	58.7	54.4	56.4	55.9	55.9	50.6	43.7	34.1	59.2
	01:30	58.6	54.2	56.3	55.8	55.9	50.6	43.7	34	59.1
	01:45	58.5	54.2	56.4	55.9	56	50.7	43.8	34.1	59.2
	02:00	58.5	54.2	56.3	55.9	56	50.7	43.7	34	59.2
	02:15	58.6	54.3	56.5	55.9	56	50.7	43.8	34	59.2
	02:30	58.7	54.3	56.4	55.9	55.9	50.7	43.7	33.8	59.2
	02:45	58.6	54.3	56.4	55.9	55.9	50.6	43.7	33.8	59.2
	03:00	58.6	54.3	56.4	55.9	56	50.6	43.6	33.7	59.2
	03:15	58.7	54.3	56.4	55.9	56	50.5	43.4	33.4	59.2
	03:30	58.8	54.3	56.4	56	56.2	50.6	43.5	33.5	59.3
	03:45	58.9	54.5	56.5	56	56.2	50.7	43.6	33.5	59.4
	04:00	59.1	54.5	56.6	56	56.2	50.6	43.5	33.3	59.3
	04:15	58.9	54.3	56.6	56	56.2	50.7	43.6	33.5	59.4
	04:30	58.8	54.4	56.5	56	56.1	50.7	43.5	33.3	59.3
	04:45	58.8	54.6	56.6	56.1	56.3	50.7	43.5	33.4	59.4
	05:00	58.8	54.6	56.6	56.1	56.3	50.7	43.6	33.4	59.4

Date	Time	Measured $L_{90,15\text{mins}}$ (dB) at each octave band centre frequency (Hz)								
		63	125	250	500	1k	2k	4k	8k	dBA
	05:15	59.6	55.3	56.8	56.2	56.3	50.7	43.6	33.4	59.5
	05:30	60	55.7	56.8	56.2	56.3	50.7	43.5	33.3	59.5
	05:45	60.5	56.3	57	56.3	56.5	50.9	43.6	33.3	59.7
	06:00	60.8	56.4	57.2	56.9	56.7	51.6	44.2	33.8	60.1
	06:15	60.5	56.2	57.1	56.4	56.5	51	43.8	33.6	59.7
	06:30	60.6	55.8	57.3	56.5	56.6	50.9	43.8	33.6	59.8
	06:45	61.2	56.3	57.5	56.7	56.7	51.2	44.1	33.8	60
25/09/20	23:00	59.6	54.7	56.6	56.3	56.4	50.8	43.7	33.6	59.5
	23:15	59.3	54.7	56.7	56.3	56.5	50.9	43.8	33.7	59.6
	23:30	59	54.5	56.6	56.2	56.4	50.8	43.6	33.4	59.5
	23:45	58.9	54.4	56.5	56.2	56.3	50.7	43.5	33.3	59.4
	00:00	59	54.4	56.5	56.2	56.3	50.7	43.5	33.2	59.4
	00:15	58.8	54.2	56.4	56.2	56.4	50.7	43.5	33.3	59.5
	00:30	58.9	54.4	56.5	56.2	56.3	50.7	43.5	33.2	59.4
	00:45	58.9	54.6	56.5	56.2	56.3	50.8	43.5	33.1	59.5
	01:00	58.8	54.4	56.5	56.2	56.3	50.8	43.6	33.2	59.5
	01:15	58.7	54.5	56.6	56.2	56.3	50.8	43.5	33.2	59.5
	01:30	58.7	54.4	56.4	56.2	56.4	50.7	43.5	33.2	59.5
	01:45	58.9	54.5	56.5	56.2	56.4	50.8	43.6	33.4	59.5
	02:00	58.8	54.5	56.4	56.2	56.5	50.8	43.6	33.4	59.6
	02:15	58.9	54.6	56.6	56.1	56.4	50.7	43.5	33.3	59.5
	02:30	58.9	54.5	56.5	56.2	56.4	50.7	43.5	33.1	59.5
	02:45	58.8	54.5	56.5	56.2	56.4	50.7	43.4	33.1	59.5
	03:00	58.7	54.4	56.6	56	56.2	50.6	43.3	33	59.3
	03:15	58.8	54.8	56.7	56.1	56.2	50.7	43.4	33.2	59.4
	03:30	58.7	54.6	56.5	56.1	56.1	50.6	43.4	33.1	59.3
	03:45	59	54.7	56.6	56.1	56.1	50.6	43.2	32.9	59.3
	04:00	58.8	54.7	56.6	56.1	56.2	50.6	43.2	32.8	59.4
	04:15	58.7	54.6	56.7	56.1	56.1	50.6	43.2	32.8	59.3

Date	Time	Measured $L_{90,15\text{mins}}$ (dB) at each octave band centre frequency (Hz)								
		63	125	250	500	1k	2k	4k	8k	dBA
	04:30	58.8	54.5	56.6	56.2	56	50.7	43.3	32.8	59.3
	04:45	58.8	54.8	56.6	56.1	56.1	50.6	43.2	32.8	59.3
	05:00	58.8	54.5	56.7	56.1	56.1	50.6	43.2	32.7	59.3
	05:15	58.9	54.7	56.6	56.2	56.1	50.6	43.2	32.7	59.3
	05:30	58.9	54.5	56.5	56.2	56.1	50.7	43.3	32.8	59.3
	05:45	59.2	54.8	56.7	56.3	56.2	50.7	43.2	32.8	59.4
	06:00	59.5	55.4	56.9	57.1	56.5	51.4	43.7	33.1	59.9
	06:15	59.4	55	56.8	56.2	56.2	50.8	43.4	32.9	59.4
	06:30	59.6	55.5	56.8	56.3	56.3	50.9	43.5	33	59.5
	06:45	60	55.5	56.9	56.5	56.5	51.1	43.7	33.1	59.7

Table A-8 - Arithmetic average octave band night-time $L_{90,15\text{min}}$ levels Position L2

Time	Measured $L_{90,1\text{hr}}$ (dB) at each octave band centre frequency								
	63 Hz	125 Hz	250 Hz	500 Hz	1 kHz	2 kHz	4 kHz	8 kHz	dBA
23:00	56.5	53.3	51.4	50.1	49.5	43.0	34.2	24.2	52.8
23:15	56.8	53.5	51.9	50.5	49.7	43.2	34.4	24.1	53.1
23:30	56.6	53.4	51.8	50.3	49.7	43.2	34.7	24.3	53.1
23:45	56.3	53.0	51.2	50.0	49.5	43.1	34.1	24.0	52.8
00:00	56.3	53.1	51.2	49.9	49.3	42.8	33.9	23.9	52.6
00:15	56.1	52.9	51.1	49.9	49.3	42.8	34.1	24.0	52.6
00:30	56.1	52.9	51.1	49.8	49.3	42.9	34.5	24.2	52.6
00:45	56.2	53.0	51.0	49.9	49.3	42.8	34.2	24.3	52.6
01:00	55.9	52.8	51.0	49.8	49.2	42.8	34.1	24.0	52.6
01:15	56.0	52.8	51.0	49.8	49.2	42.7	34.1	24.1	52.5
01:30	55.8	52.8	51.2	49.8	49.0	42.4	34.0	24.1	52.4
01:45	55.8	52.7	50.9	49.7	48.8	42.2	33.9	24.1	52.2
02:00	56.0	52.8	51.0	49.8	49.0	42.5	34.0	24.2	52.4
02:15	56.1	52.7	50.9	49.7	49.0	42.5	34.0	24.2	52.4
02:30	56.2	52.9	51.2	49.9	48.9	42.4	34.1	24.2	52.4
02:45	56.1	52.8	51.2	49.9	49.0	42.5	34.1	24.2	52.4

Time	Measured $L_{90,1hr}$ (dB) at each octave band centre frequency								
	63 Hz	125 Hz	250 Hz	500 Hz	1 kHz	2 kHz	4 kHz	8 kHz	dBA
03:00	56.0	53.0	51.1	49.8	48.8	42.2	33.9	24.0	52.3
03:15	56.1	52.8	51.1	49.7	48.6	42.1	33.8	23.8	52.2
03:30	56.3	53.0	51.2	49.8	48.7	42.2	33.9	23.7	52.2
03:45	56.5	52.9	51.4	49.8	48.8	42.2	33.8	23.8	52.3
04:00	56.4	53.2	51.4	49.8	48.7	42.3	33.7	23.7	52.3
04:15	56.7	53.2	51.4	50.0	49.0	42.5	33.9	23.8	52.5
04:30	56.5	53.0	51.3	50.0	48.9	42.4	33.9	23.7	52.4
04:45	56.5	53.1	51.3	50.0	49.1	42.6	34.0	23.8	52.5
05:00	56.5	53.1	51.3	50.0	49.1	42.6	33.9	23.7	52.5
05:15	56.5	53.5	51.5	50.0	48.7	42.2	33.7	23.6	52.4
05:30	57.0	53.6	51.7	50.2	48.9	42.3	33.7	23.6	52.5
05:45	57.3	53.8	51.8	50.3	49.2	42.6	33.9	23.7	52.7
06:00	58.4	54.6	52.2	50.7	49.5	43.0	34.2	23.8	53.1
06:15	58.8	55.1	53.3	52.5	50.8	45.7	36.5	26.0	54.7
06:30	58.6	54.8	52.8	51.3	50.1	43.7	35.2	25.0	53.7
06:45	58.5	55.1	53.2	51.6	50.3	44.0	35.6	25.1	54.0
Minimum	55.8	52.7	50.9	49.7	48.6	42.1	33.7	23.6	52.1

Table A-9 – Measured octave band daytime $L_{90,1hr}$ levels (07:00 to 23:00) Position L3

Date	Time	Measured $L_{90,1hr}$ (dB) at each octave band centre frequency (Hz)								dBA
		63	125	250	500	1 k	2 k	4 k	8 k	
16/10/20	12:00	57.9	58.3	53.5	49.4	50.8	47.6	40.8	29.6	54.8
	13:00	58	58.4	53.4	49.2	50.7	47.5	40.7	29.5	54.7
	14:00	57.8	58.3	53.3	49	50.7	47.4	40.7	29.4	54.6
	15:00	57.8	58.4	53.4	49	50.7	47.3	40.6	29.5	54.6
	16:00	57.8	58.5	53.2	48.8	50.6	47.3	40.7	29.4	54.5
	17:00	57.7	58.4	53.5	49.3	50.8	47.5	40.9	29.8	54.8
	18:00	57.2	58.2	53.2	49.1	50.6	47.3	40.9	29.9	54.6
	19:00	57.3	58.2	52.8	48.1	50.5	47.1	40.7	29.8	54.3
	20:00	57.1	57.9	52.3	47.8	50.4	47.1	40.7	29.9	54.2
	21:00	56.6	57.7	52	47.5	50.6	47.1	40.8	29.9	54.2
	22:00	56.6	57.5	51.8	47.9	51.1	47.3	41.0	30.3	54.5
17/10/20	07:00	56.7	57.7	52	47.4	50.9	47.3	40.9	30.2	54.4
	08:00	57.0	57.9	52.1	47.5	50.7	47.3	41.0	30.3	54.3
	09:00	57.1	57.8	52.3	47.6	50.5	47.2	40.9	30.3	54.2
	10:00	57.2	58	52.3	47.9	50.5	47.4	40.9	30.3	54.3
	11:00	57.3	58.1	52.5	47.9	50.4	47.4	41.0	30.4	54.3
	12:00	57.	57.9	52.4	47.8	50.4	47.2	40.9	30.2	54.2
	13:00	57.0	58	52.6	48	50.5	47.3	41.1	30.4	54.3
	14:00	57.2	58.1	52.6	48.3	50.6	47.3	41.0	30.2	54.4
	15:00	57.2	58.1	52.8	48.3	50.5	47.3	41.1	30.5	54.4
	16:00	57.1	58.0	52.7	48.5	50.5	47.3	41.1	30.6	54.4
	17:00	57.0	58.0	52.9	49.0	50.8	47.4	41.1	30.2	54.6
	18:00	57.1	58.1	52.7	48.6	50.6	47.3	41.0	30.2	54.5
	19:00	57.0	58	52.8	48.8	50.7	47.4	41.0	30.1	54.5
	20:00	57.1	57.9	52.3	48.1	50.5	47.3	40.8	29.8	54.3
	21:00	56.7	57.8	52.0	47.7	50.5	47.2	40.7	29.7	54.2
	22:00	56.6	57.5	51.8	48	51.1	47.4	40.9	30.1	54.5
18/10/20	07:00	56.4	57.7	51.7	46.9	50.4	47	40.8	30	54.0

Date	Time	Measured $L_{90,1hr}$ (dB) at each octave band centre frequency (Hz)								dBA
		63	125	250	500	1 k	2 k	4 k	8 k	
	08:00	56.5	57.7	51.8	47.2	50.1	47	40.7	30	53.9
	09:00	56.9	57.9	52.3	47.5	50.3	47.2	40.8	30.2	54.1
	10:00	56.7	57.9	52.4	47.4	50.3	47.1	40.7	29.9	54.1
	11:00	56.8	57.9	52.4	47.9	50.5	47.2	40.8	30.1	54.3
	12:00	56.9	58.0	52.4	47.7	50.5	47.1	40.8	30.1	54.2
	13:00	56.9	58.1	52.5	47.7	50.4	47.1	40.9	30.2	54.2
	14:00	57.2	58.2	52.6	48	50.4	47.1	40.9	30.2	54.2
	15:00	57.1	58.1	52.6	47.9	50.4	47.1	40.8	30.1	54.2
	16:00	57.1	58.0	52.3	47.9	50.5	47.2	40.8	29.9	54.3
	17:00	57.1	58.1	52.4	48.0	50.6	47.2	40.8	29.9	54.3
	18:00	56.8	57.9	52.3	47.5	50.4	47.0	40.8	30.1	54.1
	19:00	56.6	57.9	51.9	47.1	50.2	46.9	40.6	30	53.9
	20:00	56.7	57.8	51.6	46.8	50.2	46.9	40.6	29.8	53.8
	21:00	56.3	57.7	51.6	47.0	51.1	47.0	40.7	30.4	54.3
	22:00	56.1	57.6	51.4	46.7	51.5	47.1	40.6	30.2	54.5
19/10/20	07:00	58.1	58.6	53.8	49.1	51.1	47.5	41	30.4	54.9
	08:00	58.7	58.7	54	49.9	51.3	47.9	41.5	30.9	55.3
	09:00	58.4	58.5	53.8	49.4	51	47.8	41.2	30.6	55.0
	10:00	58.3	58.4	53.7	49.6	51	47.8	41.1	30.6	55.0

Table A-10 – Arithmetic average octave band daytime $L_{90,1hr}$ levels Position L3

	Time	Arithmetic average of measured $L_{90,1hr}$ (dB) at each octave band centre frequency (Hz)								
		63	125	250	500	1k	2k	4k	8k	dBA
	07:00	57.1	58.0	52.5	47.8	50.8	47.3	40.9	30.2	54.4
	08:00	57.4	58.1	52.6	48.2	50.7	47.4	41.1	30.4	54.5
	09:00	57.5	58.1	52.8	48.2	50.6	47.4	41.0	30.4	54.4
	10:00	57.4	58.1	52.8	48.3	50.6	47.4	40.9	30.3	54.5
	11:00	57.1	58.0	52.5	47.9	50.5	47.3	40.9	30.3	54.3
	12:00	57.3	58.1	52.8	48.3	50.6	47.3	40.8	30.0	54.4
	13:00	57.3	58.2	52.8	48.3	50.5	47.3	40.9	30.0	54.4
	14:00	57.4	58.2	52.8	48.4	50.6	47.3	40.9	29.9	54.4
	15:00	57.4	58.2	52.9	48.4	50.5	47.2	40.8	30.0	54.4
	16:00	57.3	58.2	52.7	48.4	50.5	47.3	40.9	30.0	54.4
	17:00	57.3	58.2	52.9	48.8	50.7	47.4	40.9	30.0	54.6
	18:00	57.0	58.1	52.7	48.4	50.5	47.2	40.9	30.1	54.4
	19:00	57.0	58.0	52.5	48.0	50.5	47.1	40.8	30.0	54.2
	20:00	57.0	57.9	52.1	47.6	50.4	47.1	40.7	29.8	54.1
	21:00	56.5	57.7	51.9	47.4	50.7	47.1	40.7	30.0	54.2
	22:00	56.4	57.5	51.7	47.5	51.2	47.3	40.8	30.2	54.5
	Lowest	56.4	57.5	51.7	47.4	50.4	47.1	40.7	29.8	54.0

Table A-11 - Measured octave band night-time $L_{90,15 \text{ min}}$ levels (23:00 to 07:00) Position L3

Date	Time	Measured $L_{90,15 \text{ mins}}$ (dB) at each octave band centre frequency (Hz)								
		63	125	250	500	1k	2k	4k	8k	dBA
16/10/20	23:00	56.5	57.4	51.5	47.2	51.1	47.3	40.9	30.1	54.4
	23:15	56.4	57.6	51.8	47.6	51.2	47.3	41	30.2	54.5
	23:30	56.3	57.3	51.8	47.4	51	47.2	40.8	29.8	54.3
	23:45	56.2	57.4	51.3	47	51	47.1	40.8	29.8	54.2
	00:00	56.2	57.4	51.5	47.2	51.2	47.3	41.1	30.6	54.4
	00:15	56	57.4	51.1	46.6	50.9	46.9	40.6	29.8	54.1
	00:30	56.1	57.4	51.1	46.5	50.7	46.8	40.6	29.9	54
	00:45	55.9	57.3	50.9	46.4	50.8	47	40.7	30.1	54
	01:00	55.9	57.3	51	46.3	50.8	47	40.7	30.2	54
	01:15	56	57.3	50.9	46.4	50.8	47	40.7	30.1	54
	01:30	56	57.3	50.9	46.4	50.9	47	40.8	30	54.1
	01:45	56	57.2	50.9	46.4	51	47.2	40.8	30.1	54.2
	02:00	56	57.2	51	46.4	51.1	47.2	40.9	30.1	54.2
	02:15	55.9	57.2	51	46.4	51	47.1	40.7	29.9	54.2
	02:30	56.1	57.3	51.3	46.7	51.1	47.2	40.9	30.2	54.3
	02:45	55.9	57.2	51	46.5	51.1	47.1	40.8	30.1	54.2
	03:00	55.9	57.3	50.9	46.4	51.1	47.2	40.8	30.1	54.2
	03:15	56	57.4	51.1	46.5	51.2	47.2	40.9	30.1	54.3
	03:30	55.9	57.4	51	46.5	51.2	47.1	40.8	30.1	54.3
	03:45	56	57.3	51	46.5	51.2	47.2	40.8	30.1	54.3
	04:00	56.1	57.4	51.1	46.8	51.2	47.2	40.9	30.1	54.3
	04:15	56	57.3	51	46.8	51.1	47.3	40.8	30	54.3
	04:30	56	57.3	51.1	46.7	51	47.3	40.8	30.1	54.3
	04:45	55.9	57.4	51.1	46.7	51	47.3	40.8	30	54.3
	05:00	56	57.4	51	46.7	51	47.2	40.9	30.2	54.2
	05:15	56	57.4	51.1	46.8	51	47.3	40.9	30.3	54.3
	05:30	56	57.4	51	46.7	51	47.3	40.9	30.3	54.3
	05:45	56.1	57.4	51.3	46.8	51.1	47.4	40.9	30.3	54.4

Date	Time	Measured $L_{90,15\text{mins}}$ (dB) at each octave band centre frequency (Hz)								
		63	125	250	500	1k	2k	4k	8k	dBA
	06:00	56.5	57.8	52.1	47.8	51.5	47.9	41.2	30.5	54.9
	06:15	56.4	57.7	52	47.4	51.3	47.5	41	30.3	54.6
	06:30	56.5	57.7	51.8	47.4	51.2	47.4	41.1	30.3	54.5
	06:45	56.5	57.7	52.1	47.8	51.5	47.6	41.1	30.3	54.8
17/10/20	23:00	56.4	57.4	51.5	47.5	51.1	47.4	41.1	30.3	54.4
	23:15	56.2	57.3	51.5	47.3	51	47.4	41.1	30.4	54.4
	23:30	56.1	57.3	51.3	46.8	50.6	47.2	40.7	29.8	54.1
	23:45	56.1	57.3	51.3	46.9	50.7	47.1	40.8	30	54.1
	00:00	56	57.3	51.3	47	50.9	47.3	40.8	30	54.2
	00:15	56	57.3	51.2	46.9	50.9	47.4	40.9	30.2	54.3
	00:30	56	57.3	51.2	47	50.8	47.2	40.8	30.1	54.2
	00:45	56	57.2	51.2	47	50.8	47.1	40.8	30.2	54.1
	01:00	56	57.2	51.2	46.8	50.9	47.3	40.9	30.1	54.2
	01:15	55.9	57.3	51.2	46.7	50.8	47.1	40.8	30.2	54.1
	01:30	56	57.2	51.2	46.7	50.9	47.2	40.9	30.3	54.2
	01:45	56	57.4	51.2	46.7	50.9	47.2	40.9	30.3	54.2
	02:00	56	57.4	51.3	46.8	50.9	47.2	40.9	30.4	54.2
	02:15	55.8	57.2	51.1	46.7	50.9	47.2	41	30.4	54.2
	02:30	56	57.3	51.2	46.7	50.9	47.3	40.9	30.1	54.2
	02:45	55.9	57.2	51.2	46.8	50.9	47.3	41	30.3	54.2
	03:00	55.9	57.2	51.1	46.7	50.9	47.3	41	30.2	54.2
	03:15	55.9	57.2	51.2	46.7	50.8	47.3	40.9	30.3	54.2
	03:30	56	57.2	51	46.7	50.9	47.3	41	30.3	54.2
	03:45	55.8	57.2	51.1	46.7	50.9	47.3	41	30.3	54.2
	04:00	55.8	57.1	51	46.7	51	47.3	40.9	30.2	54.2
	04:15	55.8	57.1	51.1	46.7	51	47.3	40.9	30.3	54.2
	04:30	55.9	57.2	51	46.7	50.9	47.3	40.9	30.3	54.2
	04:45	55.9	57.3	51.2	46.7	51	47.3	40.9	30.2	54.3
	05:00	55.9	57.2	51.1	46.7	50.9	47.3	40.9	30.2	54.2

Date	Time	Measured $L_{90,15\text{mins}}$ (dB) at each octave band centre frequency (Hz)								
		63	125	250	500	1k	2k	4k	8k	dBA
	05:15	56	57.3	51.2	46.9	51.1	47.4	41	30.4	54.4
	05:30	55.9	57.2	51	46.7	51	47.3	40.9	30.2	54.2
	05:45	56	57.2	51.1	46.8	51	47.3	41	30.4	54.3
	06:00	56.2	57.6	52.3	48.3	51.5	47.9	41.2	30.5	54.9
	06:15	56.2	57.5	51.7	47.2	51.1	47.4	41	30.2	54.4
	06:30	56.3	57.7	51.7	47.2	51.1	47.5	41	30.2	54.5
	06:45	56.5	57.7	51.7	47.2	51.1	47.4	41	30.4	54.4

Table A-12 - Arithmetic average octave band night-time $L_{90,15\text{min}}$ levels Position L3

Time	Measured $L_{90,1\text{hr}}$ (dB) at each octave band centre frequency								
	63 Hz	125 Hz	250 Hz	500 Hz	1 kHz	2 kHz	4 kHz	8 kHz	dBA
23:00	56.5	57.4	51.5	47.4	51.1	47.4	41.0	30.2	54.4
23:15	56.3	57.5	51.7	47.5	51.1	47.4	41.1	30.3	54.4
23:30	56.2	57.3	51.6	47.1	50.8	47.2	40.8	29.8	54.2
23:45	56.2	57.4	51.3	47.0	50.9	47.1	40.8	29.9	54.2
00:00	56.1	57.4	51.4	47.1	51.1	47.3	41.0	30.3	54.3
00:15	56.0	57.4	51.2	46.8	50.9	47.2	40.8	30.0	54.2
00:30	56.1	57.4	51.2	46.8	50.8	47.0	40.7	30.0	54.1
00:45	56.0	57.3	51.1	46.7	50.8	47.1	40.8	30.2	54.1
01:00	56.0	57.3	51.1	46.6	50.9	47.2	40.8	30.2	54.1
01:15	56.0	57.3	51.1	46.6	50.8	47.1	40.8	30.2	54.1
01:30	56.0	57.3	51.1	46.6	50.9	47.1	40.9	30.2	54.1
01:45	56.0	57.3	51.1	46.6	51.0	47.2	40.9	30.2	54.2
02:00	56.0	57.3	51.2	46.6	51.0	47.2	40.9	30.3	54.2
02:15	55.9	57.2	51.1	46.6	51.0	47.2	40.9	30.2	54.2
02:30	56.1	57.3	51.3	46.7	51.0	47.3	40.9	30.2	54.3
02:45	55.9	57.2	51.1	46.7	51.0	47.2	40.9	30.2	54.2
03:00	55.9	57.3	51.0	46.6	51.0	47.3	40.9	30.2	54.2
03:15	56.0	57.3	51.2	46.6	51.0	47.3	40.9	30.2	54.2
03:30	56.0	57.3	51.0	46.6	51.1	47.2	40.9	30.2	54.2

Time	Measured $L_{90,1hr}$ (dB) at each octave band centre frequency								
	63 Hz	125 Hz	250 Hz	500 Hz	1 kHz	2 kHz	4 kHz	8 kHz	dBA
03:45	55.9	57.3	51.1	46.6	51.1	47.3	40.9	30.2	54.3
04:00	56.0	57.3	51.1	46.8	51.1	47.3	40.9	30.2	54.3
04:15	55.9	57.2	51.1	46.8	51.1	47.3	40.9	30.2	54.3
04:30	56.0	57.3	51.1	46.7	51.0	47.3	40.9	30.2	54.2
04:45	55.9	57.4	51.2	46.7	51.0	47.3	40.9	30.1	54.3
05:00	56.0	57.3	51.1	46.7	51.0	47.3	40.9	30.2	54.2
05:15	56.0	57.4	51.2	46.9	51.1	47.4	41.0	30.4	54.3
05:30	56.0	57.3	51.0	46.7	51.0	47.3	40.9	30.3	54.2
05:45	56.1	57.3	51.2	46.8	51.1	47.4	41.0	30.4	54.3
06:00	56.4	57.7	52.2	48.1	51.5	47.9	41.2	30.5	54.9
06:15	56.3	57.6	51.9	47.3	51.2	47.5	41.0	30.3	54.5
06:30	56.4	57.7	51.8	47.3	51.2	47.5	41.1	30.3	54.5
06:45	56.5	57.7	51.9	47.5	51.3	47.5	41.1	30.4	54.6
Minimum	55.9	57.2	51.0	46.6	50.8	47.0	40.7	29.8	54.1

Table A-13 – Measured octave band daytime $L_{90,1hr}$ levels (07:00 to 23:00) Position L4

Date	Time	Measured $L_{90,1hr}$ (dB) at each octave band centre frequency (Hz)								dBA
		63	125	250	500	1 k	2 k	4 k	8 k	
18/02/20	14:00	58	55	53.4	51	49.8	45.5	38.3	26	54.0
	15:00	57.9	54.6	53.2	50.8	49.5	45.3	37.9	25.6	53.7
	16:00	57.9	54.7	53.3	50.7	49.4	45.1	37.8	25.4	53.7
	17:00	57.2	54.2	53	50.5	49.4	45	37.8	25.6	53.5
	18:00	56.6	53.2	52.8	50.3	49.2	45	37.8	25.9	53.3
	19:00	55.6	52.4	52.2	50.2	49	44.7	37.7	25.9	53.1
	20:00	54.9	51.7	51.9	49.6	48.7	44.4	37.4	25.3	52.7
	21:00	54.8	51.2	51.7	49.5	48.5	44.3	37.2	25	52.6
	22:00	54.5	51.3	52	49.5	48.4	44.2	37.2	24.9	52.5
19/03/20	07:00	58	54.3	53.4	50.8	49.5	45.3	38	25.9	53.8
	08:00	58.8	55.1	53.7	51.6	50.1	45.8	38.5	26.4	54.4
	09:00	58.7	55.6	53.9	51.6	50.1	45.7	38.1	25.4	54.4
	10:00	58	55.1	53.6	50.9	49.5	45	37.1	24.1	53.8
	11:00	57.5	54.1	53.2	50.7	49.2	44.6	36.3	23	53.4
	12:00	57.4	54.2	53	50.9	49.2	44.7	36.3	23.1	53.5
	13:00	57.8	53.8	53	50.6	49.1	44.2	35.7	23.5	53.2
	14:00	57.1	53.8	52.7	50.3	48.8	43.9	35.2	22	52.9
	15:00	56.8	53.5	52.3	50.1	48.6	43.7	35.2	21.9	52.7
	16:00	57.1	53.7	52.6	50.2	48.9	44	35.5	22.3	53.0
	17:00	56.1	53	52.3	49.9	48.6	43.7	35.2	22	52.6
	18:00	55.6	52.5	52.1	49.6	48.6	43.9	35.5	22.3	52.6
	19:00	54.8	51.8	52.1	49.9	48.8	44.4	37.1	24.7	52.8
	20:00	54.7	51.7	52.2	49.5	48.6	44.3	37	24.8	52.7
	21:00	54.6	51	51.9	49.2	48.5	44.2	37	24.7	52.5
	22:00	54.6	50.7	51.6	48.9	48.3	44	36.9	24.3	52.2
20/03/20	07:00	58.2	54.6	53.5	50.9	49.6	45.2	37.7	25.2	53.8
	08:00	59.1	55.5	54	51.3	50	45.5	38	25.4	54.2
	09:00	58.1	54.9	53.8	51	49.7	45.3	37.6	24.9	53.9

Date	Time	Measured $L_{90,1hr}$ (dB) at each octave band centre frequency (Hz)								dBA
		63	125	250	500	1 k	2 k	4 k	8 k	
	10:00	58	54.7	53.5	51	49.5	45.5	37.2	24.3	53.8
	11:00	57.3	53.9	53.2	50.9	49.4	45.2	36.8	23.4	53.7
	12:00	57.2	53.7	53.1	50.9	49.2	44.5	36.1	23.1	53.4
	13:00	57	53.8	53	50.7	49.1	44.3	36	22.9	53.3
	14:00	56.9	53.8	53.1	50.6	49.2	44.5	36.9	22.9	53.4
	15:00	56.9	53.6	52.9	50.3	49	44.3	37.6	22.9	53.2
	16:00	56.7	53.7	52.8	50.3	49.1	44.4	37.5	23.2	53.2
	17:00	56.3	53.1	52.8	50.3	49.1	44.3	36.3	23.3	53.1
	18:00	55.7	52.9	52.5	50	48.8	44.1	36.1	23.1	52.9
	19:00	55.3	52.8	52.3	49.9	48.8	44.2	36.4	23.4	52.8
	20:00	54.8	52.3	52.3	49.7	48.6	44.1	36.5	23.8	52.7
	21:00	54.7	52.1	52.1	49.5	48.6	44.2	36.8	24.3	52.6
	22:00	54.6	51.7	52.3	49.5	48.6	44.2	36.9	24.4	52.6
21/03/20	07:00	54.7	51.8	51.9	49.8	48.6	44.1	36.6	24	52.6
	08:00	55.3	52.5	52.3	49.9	48.8	44.3	36.8	24.1	52.9
	09:00	55.1	52.1	52.1	49.5	48.7	44	36.1	23.1	52.6
	10:00	55.5	52.4	52.4	49.5	48.6	43.7	35.6	22.4	52.5
	11:00	55.4	52.6	52.2	49.4	48.6	43.4	34.9	21.9	52.4
	12:00	55.2	51.9	52.1	49.4	48.4	43.2	34.8	21.7	52.3
	13:00	55.5	52.1	52.1	49.2	48.1	42.8	34.3	21.4	52.0
	14:00	55.2	52.2	51.9	49	47.9	42.4	33.7	21.4	51.8
	15:00	54.9	51.7	51.7	49.1	48.1	42.9	34.3	21.8	52.0
	16:00	54.7	51.2	51.5	48.8	48	43.1	34.9	22	51.9
	17:00	54.5	51.3	51.4	48.8	48.2	43.5	35.6	22.7	52.0
	18:00	53.9	51	51.3	48.8	48.1	43.6	35.6	22.7	52.0
	19:00	53.7	51.1	51.3	48.7	48.1	43.6	35.8	23	52.0
	20:00	54.1	51.7	51.2	48.6	48.1	43.6	36	23.2	52.0
	21:00	54.5	52	51.5	49	48.3	43.9	36.1	23.3	52.2
	22:00	54.9	52.6	51.5	49	48.2	43.9	36.1	23.4	52.2

Date	Time	Measured $L_{90,1hr}$ (dB) at each octave band centre frequency (Hz)								dBA
		63	125	250	500	1 k	2 k	4 k	8 k	
22/03/20	07:00	53.3	50.3	51.3	48.8	48	43.6	36	23.2	51.9
	08:00	53.8	51.2	51.3	49	48	43.5	35.8	22.9	52
	09:00	54.2	51.6	51.5	49.1	48.1	43.5	35.8	22.8	52.1
	10:00	54.4	52	51.5	49.1	48.2	43.6	35.7	22.7	52.1
	11:00	54.5	51.9	51.7	49	48.3	43.6	35.8	22.6	52.2
	12:00	54.6	51.5	51.6	48.9	48	43.4	35.5	22.3	52
	13:00	54.1	51.3	51.5	48.7	48.1	43.4	35.3	22	51.9
	14:00	53.9	51.2	51.4	48.4	47.9	43.1	35	21.6	51.7
	15:00	53.3	50.5	51.3	48.4	48	43.3	35.3	22	51.8
	16:00	53	50.2	51.2	48.3	47.9	43.3	35.3	22.1	51.7
	17:00	52.9	50.2	51.1	48.1	47.8	43.3	35.4	22.3	51.6
	18:00	53.1	50.3	51.2	48.2	47.8	43.3	35.8	23.1	51.6
	19:00	53.3	50.7	51.5	48.7	47.9	43.5	36.1	23.6	51.9
	20:00	53.5	50.8	51.4	48.7	47.8	43.4	35.9	23.3	51.8
	21:00	53.8	50.8	51.6	48.7	47.9	43.4	36	23.5	51.9
	22:00	54	50.9	52.2	48.9	48	43.5	36.1	23.6	52.1
23/03/20	07:00	58.9	54.3	53.6	50.5	49.4	44.7	36.7	23.8	53.5
	08:00	59.4	55.2	53.7	51	49.8	45.1	36.9	23.8	53.9
	09:00	58.9	54.7	53.5	50.9	49.6	44.8	36.5	23.4	53.7
	10:00	58.4	54.6	53.5	50.7	49.5	44.8	36.6	23.7	53.6
	11:00	58.4	53.8	52.9	50.2	49.3	44.5	36.4	23.1	53.3
	12:00	58.4	52.7	52.3	49.5	48.7	43.8	35.6	22.4	52.6
	13:00	58.4	52.4	52	49.4	48.6	43.7	35.2	21.8	52.5
	14:00	58.1	52.4	52.1	49.5	48.6	43.7	35.1	21.9	52.5
	15:00	58.7	52.1	52.1	49.2	48.3	43.4	34.7	21.3	52.3
	16:00	58.9	51.8	51.7	48.8	48	43.3	34.9	21.4	52
	17:00	58.3	51.7	51.5	48.6	47.9	43.3	35	21.6	51.9
	18:00	58.5	51.3	51.6	48.4	47.9	43.3	35.2	22	51.8
	19:00	56.6	50.6	51.3	48.4	47.9	43.3	35.5	22.4	51.8

Date	Time	Measured $L_{90,1hr}$ (dB) at each octave band centre frequency (Hz)								dBA
		63	125	250	500	1 k	2 k	4 k	8 k	
	20:00	54.5	50.1	51.3	48.3	48.1	43.3	35.4	22.4	51.8
	21:00	54.2	50	51.2	48.4	48.1	43.3	35.5	22.5	51.8
	22:00	54.7	49.9	51.2	48.5	47.9	43.3	35.5	22.6	51.7

Table A-14 – Arithmetic average octave band daytime $L_{90,1hr}$ levels Position L4

	Time	Arithmetic average of measured $L_{90,1hr}$ (dB) at each octave band centre frequency (Hz)								
		63	125	250	500	1k	2k	4k	8k	dBA
	07:00	56.1	52.8	52.5	50.1	48.9	44.6	37.1	24.6	53.0
	08:00	56.8	53.6	52.8	50.5	49.2	44.8	37.3	24.7	53.3
	09:00	56.5	53.6	52.8	50.3	49.2	44.6	36.9	24.1	53.2
	10:00	56.5	53.6	52.8	50.1	49.0	44.5	36.4	23.4	53.1
	11:00	56.2	53.1	52.6	50.0	48.9	44.2	36.0	22.7	52.9
	12:00	56.1	52.8	52.5	50.0	48.7	44.0	35.7	22.6	52.8
	13:00	56.1	52.8	52.4	49.8	48.6	43.7	35.3	22.5	52.6
	14:00	56.5	53.1	52.4	49.8	48.7	43.9	35.7	22.6	52.7
	15:00	56.4	52.7	52.3	49.7	48.6	43.8	35.8	22.6	52.6
	16:00	56.4	52.6	52.2	49.5	48.6	43.9	36.0	22.7	52.5
	17:00	55.9	52.3	52.0	49.4	48.5	43.9	35.9	22.9	52.5
	18:00	55.6	51.9	51.9	49.2	48.4	43.9	36.0	23.2	52.4
	19:00	54.9	51.6	51.8	49.3	48.4	44.0	36.4	23.8	52.4
	20:00	54.4	51.4	51.7	49.1	48.3	43.9	36.4	23.8	52.3
	21:00	54.4	51.2	51.7	49.1	48.3	43.9	36.4	23.9	52.3
	22:00	54.6	51.2	51.8	49.1	48.2	43.9	36.5	23.9	52.2
	Minimum	54.4	51.2	51.7	49.1	48.2	43.7	35.3	22.5	52.2

Table A-15 - Measured octave band night-time $L_{90,15 \text{ min}}$ levels (23:00 to 07:00) Position L4

Date	Time	Measured $L_{90,15 \text{ mins}}$ (dB) at each octave band centre frequency (Hz)								
		63	125	250	500	1k	2k	4k	8k	dBA
18/03/20	23:00	54.7	51.4	52.5	49.4	48.5	44.2	37.1	24.9	52.6
	23:15	55.4	51.8	52.8	49.8	48.7	44.3	37.3	25.1	52.9
	23:30	54.8	51.1	52.3	49.4	48.5	44.1	37.0	24.7	52.5
	23:45	54.6	51.1	52.5	49.3	48.3	44.1	37.1	24.8	52.5
	00:00	54.4	50.9	52.1	49.3	48.3	44.0	36.9	24.7	52.4
	00:15	54.2	51.0	52.0	49.2	48.2	43.9	36.9	24.7	52.3
	00:30	54.1	50.9	51.9	49.1	48.2	44.0	37.0	24.8	52.3
	00:45	54.1	51.0	51.7	49.2	48.3	44.1	37.1	24.9	52.3
	01:00	53.8	50.8	51.6	49.0	48.2	44.1	37.1	24.9	52.2
	01:15	54.1	50.8	51.8	49.0	48.2	44.0	37.1	24.8	52.2
	01:30	53.8	50.8	51.6	49.1	48.3	44.1	37.2	24.9	52.3
	01:45	54.4	51.0	51.5	49.0	48.3	44.1	37.1	24.9	52.3
	02:00	54.0	51.1	51.6	49.1	48.1	44.0	37.0	24.9	52.2
	02:15	54.4	51.2	51.6	49.2	48.0	43.9	37.0	24.7	52.2
	02:30	53.9	51.2	51.7	49.0	48.0	43.7	36.9	24.8	52.1
	02:45	54.4	51.3	51.4	48.8	47.9	43.7	37.0	24.8	52.0
	03:00	54.1	50.8	51.7	49.1	48.0	43.8	37.1	25.0	52.2
	03:15	54.2	51.0	51.7	49.2	48.0	43.8	37.1	25.0	52.2
	03:30	54.0	50.9	51.6	48.9	48.0	43.8	37.1	25.1	52.1
	03:45	54.1	51.0	51.5	49.0	48.1	44.0	37.2	25.2	52.2
	04:00	54.3	51.2	51.6	49.2	48.2	44.0	37.3	25.2	52.3
	04:15	54.2	51.1	51.4	49.0	48.1	43.9	37.2	25.2	52.2
	04:30	54.1	51.0	51.7	49.3	48.2	44.1	37.3	25.3	52.4
	04:45	54.0	51.3	51.7	49.3	48.3	44.2	37.3	25.3	52.4
	05:00	54.6	51.4	51.9	49.5	48.5	44.4	37.5	25.5	52.6
	05:15	54.4	51.1	51.8	49.4	48.4	44.2	37.4	25.2	52.5
	05:30	54.9	51.6	52.0	49.5	48.3	44.1	37.4	25.3	52.5
	05:45	54.9	51.7	52.1	49.4	48.4	44.2	37.3	25.3	52.5

Date	Time	Measured $L_{90,15\text{mins}}$ (dB) at each octave band centre frequency (Hz)								
		63	125	250	500	1k	2k	4k	8k	dBA
	06:00	55.8	52.1	52.4	49.6	48.5	44.4	37.4	25.4	52.7
	06:15	56.3	52.6	52.6	50.0	48.8	44.6	37.6	25.4	53.0
	06:30	56.6	52.8	52.8	50.1	48.9	44.6	37.6	25.4	53.1
	06:45	57.1	53.2	53.2	50.4	49.3	44.9	37.8	25.9	53.5
19/03/20	23:00	54.7	51.3	52.3	49.4	48.5	44.1	36.8	24.1	52.5
	23:15	55.3	51.3	52.1	49.6	48.6	44.1	36.6	23.8	52.6
	23:30	54.4	50.6	51.7	49.1	48.3	43.9	36.5	23.9	52.2
	23:45	54.6	50.5	51.5	48.9	48.3	43.9	36.5	23.9	52.2
	00:00	54.2	50.5	51.6	49.0	48.3	43.8	36.6	24.0	52.2
	00:15	54.3	50.6	51.6	49.1	48.4	44.0	36.7	24.3	52.3
	00:30	53.9	50.2	51.3	48.8	48.1	43.8	36.6	24.3	52.0
	00:45	54.0	50.5	51.5	48.9	48.2	43.9	36.7	24.4	52.1
	01:00	53.8	50.5	51.5	49.0	48.2	43.9	36.7	24.4	52.2
	01:15	54.2	50.7	51.4	48.9	48.2	43.9	36.7	24.5	52.1
	01:30	53.8	50.6	51.4	48.8	48.2	43.8	36.9	24.6	52.1
	01:45	53.9	50.6	51.5	49.0	48.2	43.9	36.9	24.6	52.2
	02:00	53.7	50.6	51.5	49.1	48.2	43.9	36.8	24.7	52.2
	02:15	53.7	50.6	51.3	49.2	48.2	43.9	36.8	24.6	52.2
	02:30	53.9	50.7	51.5	49.3	48.3	43.9	36.8	24.6	52.3
	02:45	53.9	50.8	51.5	49.3	48.3	43.9	36.8	24.5	52.3
	03:00	54.1	50.8	51.4	49.1	48.3	43.9	36.8	24.5	52.2
	03:15	54.1	50.8	51.5	49.3	48.3	43.9	36.8	24.6	52.3
	03:30	53.9	50.7	51.5	49.3	48.3	43.9	36.8	24.5	52.3
	03:45	54.0	50.8	51.5	49.2	48.4	43.9	36.8	24.4	52.3
	04:00	54.1	51.1	51.7	49.3	48.4	43.9	36.8	24.5	52.4
	04:15	54.0	51.0	51.7	49.4	48.3	44.0	36.9	24.7	52.4
	04:30	53.9	50.8	51.5	49.1	48.3	43.9	36.8	24.6	52.2
	04:45	54.6	51.4	52.1	49.6	48.5	44.2	37.0	24.8	52.6
	05:00	54.5	51.5	51.9	49.6	48.4	44.0	36.9	24.7	52.5

Date	Time	Measured $L_{90,15\text{mins}}$ (dB) at each octave band centre frequency (Hz)								
		63	125	250	500	1k	2k	4k	8k	dBA
	05:15	54.7	51.5	51.9	49.7	48.5	44.1	37.0	24.8	52.6
	05:30	56.0	52.5	52.9	50.3	49.0	44.5	37.3	25.0	53.1
	05:45	55.2	51.9	52.3	49.9	48.8	44.4	37.2	24.9	52.9
	06:00	56.3	52.2	52.7	50.4	49.2	44.8	37.7	25.5	53.3
	06:15	56.8	53.3	52.8	50.3	49.2	45.0	37.6	25.2	53.4
	06:30	57.3	53.3	53.2	50.3	49.4	50.4	43.3	25.3	55.4
	06:45	57.4	53.4	53.3	50.4	49.3	44.9	37.5	25.1	53.5
20/03/20	23:00	54.3	51.3	51.8	49.2	48.4	44.0	36.9	24.3	52.4
	23:15	54.6	51.3	52.4	49.3	48.6	44.2	37.0	24.6	52.6
	23:30	54.1	51.1	52.0	49.3	48.6	44.2	36.9	24.4	52.5
	23:45	53.8	50.7	51.9	49.1	48.3	44.0	36.7	24.3	52.3
	00:00	54.0	51.0	51.4	49.0	48.2	44.0	36.7	24.3	52.2
	00:15	53.8	51.0	51.5	49.1	48.3	44.0	36.7	24.3	52.3
	00:30	53.6	51.1	51.5	49.2	48.3	43.9	36.8	24.3	52.3
	00:45	53.7	51.0	51.4	49.0	48.3	44.1	36.9	24.5	52.3
	01:00	53.5	50.8	51.5	49.1	48.3	44.0	36.8	24.5	52.2
	01:15	53.8	50.9	51.7	49.2	48.3	44.0	36.8	24.5	52.3
	01:30	53.5	50.7	51.5	49.1	48.2	43.9	36.7	24.3	52.2
	01:45	53.8	50.9	51.6	49.1	48.2	44.0	36.7	24.4	52.2
	02:00	53.8	50.8	51.6	49.0	48.1	43.9	36.7	24.3	52.2
	02:15	53.8	50.9	51.5	48.9	48.1	43.9	36.6	24.2	52.1
	02:30	54.0	51.1	51.6	49.2	48.2	43.9	36.6	24.2	52.3
	02:45	53.8	50.9	51.6	49.2	48.2	43.9	36.5	24.0	52.2
	03:00	53.7	51.0	51.7	49.1	48.2	43.8	36.5	23.8	52.2
	03:15	53.9	51.0	52.0	49.2	48.2	43.9	36.5	23.8	52.3
	03:30	53.6	50.8	51.8	49.1	48.1	43.8	36.3	23.7	52.2
	03:45	53.9	51.1	51.8	49.2	48.2	43.9	36.4	23.7	52.3
	04:00	53.9	51.1	51.9	49.1	48.2	43.9	36.5	23.9	52.3
	04:15	53.4	51.1	51.7	49.0	48.1	43.8	36.5	23.9	52.2

Date	Time	Measured $L_{90,15\text{mins}}$ (dB) at each octave band centre frequency (Hz)								
		63	125	250	500	1k	2k	4k	8k	dBA
	04:30	54.3	51.3	51.8	49.2	48.2	43.8	36.5	23.9	52.3
	04:45	54.1	50.9	51.9	49.0	48.1	54.5	40.4	23.9	57.1
	05:00	53.8	51.3	51.9	49.2	48.2	43.9	36.5	23.9	52.3
	05:15	53.8	51.2	51.8	49.3	48.3	43.9	36.6	24.0	52.3
	05:30	54.1	51.2	51.8	49.4	48.4	44.1	36.7	24.1	52.4
	05:45	54.2	51.3	52.1	49.5	48.5	44.1	36.7	24.2	52.5
	06:00	54.4	51.6	51.9	49.5	48.5	44.2	36.8	24.1	52.5
	06:15	55.0	52.0	52.1	49.6	48.5	44.1	36.7	24.0	52.6
	06:30	54.6	51.7	52.0	49.6	48.6	44.2	36.8	24.1	52.6
	06:45	54.5	51.6	51.9	49.5	48.4	44.0	36.7	24.1	52.5
22/03/20	23:00	54.8	52.5	51.5	49.1	48.3	43.9	36.2	23.5	52.2
	23:15	54.1	51.6	51.2	48.8	48.1	43.8	36.1	23.4	52.0
	23:30	54.1	51.5	51.3	48.9	48.0	43.7	36.1	23.4	52.0
	23:45	54.2	51.6	51.3	48.8	48.1	43.7	36.1	23.4	52.0
	00:00	55.0	52.4	51.4	49.1	48.2	43.7	36.2	23.5	52.2
	00:15	53.8	51.7	51.5	49.1	48.2	43.8	36.3	23.6	52.2
	00:30	53.9	51.2	51.4	48.8	48.2	43.8	36.3	23.6	52.1
	00:45	53.3	50.7	51.3	48.9	48.1	43.8	36.2	23.6	52.0
	01:00	53.0	50.4	51.2	48.8	48.2	43.7	36.2	23.5	52.0
	01:15	53.1	50.6	51.3	48.6	48.1	43.7	36.2	23.5	52.0
	01:30	52.7	50.6	51.1	48.8	48.1	43.6	36.1	23.4	52.0
	01:45	52.8	50.5	51.2	48.7	48.0	43.6	36.1	23.5	51.9
	02:00	52.7	50.4	51.2	48.8	48.0	43.5	36.1	23.3	51.9
	02:15	52.7	50.3	51.2	48.9	47.9	43.6	36.1	23.3	51.9
	02:30	52.6	50.4	51.1	48.7	47.9	43.5	36.1	23.3	51.8
	02:45	52.6	50.1	51.1	48.7	48.0	43.6	36.1	23.3	51.9
	03:00	52.6	50.5	51.2	48.9	47.9	43.6	36.1	23.2	51.9
	03:15	52.6	50.4	51.0	48.8	48.0	43.6	36.1	23.3	51.9
	03:30	52.7	50.7	51.1	48.7	47.9	43.5	36.0	23.2	51.8

Date	Time	Measured $L_{90,15\text{mins}}$ (dB) at each octave band centre frequency (Hz)								
		63	125	250	500	1k	2k	4k	8k	dBA
	03:45	53.4	50.5	51.1	48.9	47.9	43.6	36.1	23.3	51.9
	04:00	53.2	50.3	51.2	48.9	48.0	43.7	36.2	23.4	52.0
	04:15	53.1	50.4	51.2	48.8	48.0	43.7	36.2	23.5	52.0
	04:30	52.8	50.7	51.3	49.0	48.1	43.7	36.1	23.4	52.1
	04:45	52.7	50.5	51.3	49.0	48.1	43.7	36.1	23.4	52.1
	05:00	52.7	50.4	51.1	48.5	47.8	43.5	36.0	23.2	51.8
	05:15	53.0	50.3	51.1	48.6	47.8	43.5	35.9	23.2	51.8
	05:30	52.7	50.5	51.2	48.7	47.9	43.5	35.9	23.2	51.8
	05:45	53.3	50.4	51.4	48.7	47.9	43.4	35.9	23.2	51.8
	06:00	53.2	50.2	51.2	48.7	47.9	43.5	35.9	23.3	51.8
	06:15	53.2	50.6	51.5	48.8	48.0	43.6	36.0	23.3	52.0
	06:30	53.3	50.5	51.2	48.8	48.0	43.6	36.0	23.4	51.9
	06:45	53.5	50.5	51.2	48.6	48.0	43.5	35.9	23.2	51.9
23/03/20	23:00	53.8	50.9	52.5	48.8	48.0	43.5	36.1	23.5	52.1
	23:15	53.9	50.9	52.3	48.7	48.0	43.6	36.1	23.4	52.1
	23:30	53.8	50.9	52.1	48.8	47.9	43.5	36.0	23.3	52.0
	23:45	53.9	51.0	52.1	48.8	48.0	43.6	36.2	23.5	52.1
	00:00	55.3	51.3	51.8	48.9	48.1	43.6	36.2	23.5	52.1
	00:15	54.4	51.4	52.0	48.9	48.0	43.5	36.0	23.3	52.1
	00:30	54.6	51.2	51.8	49.0	48.1	43.6	36.1	23.4	52.1
	00:45	54.4	51.2	51.7	48.7	48.1	43.7	36.1	23.4	52.1
	01:00	54.0	51.0	52.0	48.8	48.1	43.6	36.1	23.4	52.1
	01:15	53.6	50.8	52.1	48.8	48.1	43.7	36.2	23.5	52.1
	01:30	54.1	51.1	52.0	48.8	48.1	43.7	36.2	23.5	52.1
	01:45	54.0	50.8	51.8	48.6	48.1	43.7	36.2	23.5	52.0
	02:00	54.5	51.0	51.9	48.8	48.1	43.7	36.2	23.5	52.1
	02:15	54.5	50.8	51.8	48.8	48.1	43.8	36.2	23.6	52.1
	02:30	54.5	50.8	51.6	48.6	48.0	43.6	36.1	23.4	51.9
	02:45	54.1	51.1	52.0	48.8	48.2	43.8	36.3	23.6	52.2

Date	Time	Measured $L_{90,15mins}$ (dB) at each octave band centre frequency (Hz)								
		63	125	250	500	1k	2k	4k	8k	dBA
	03:00	54.5	50.8	51.8	48.7	48.1	43.8	36.2	23.5	52.1
	03:15	54.1	51.0	52.0	48.8	48.2	43.8	36.2	23.5	52.1
	03:30	55.1	51.2	52.2	49.2	48.3	43.9	36.4	23.7	52.4
	03:45	54.8	51.3	52.4	49.1	48.4	43.9	36.4	23.8	52.4
	04:00	55.1	51.2	52.2	49.1	48.5	43.9	36.3	23.6	52.4
	04:15	55.0	51.3	52.5	49.3	48.5	44.0	36.4	23.7	52.5
	04:30	55.5	51.2	52.1	49.0	48.1	43.7	36.2	23.5	52.2
	04:45	54.6	51.2	52.0	48.9	48.1	43.6	36.2	23.6	52.1
	05:00	55.2	51.5	52.4	49.2	48.2	43.7	36.3	23.6	52.3
	05:15	55.7	52.3	53.2	49.5	48.6	44.0	36.4	23.8	52.7
	05:30	55.5	52.3	52.5	49.3	48.3	43.8	36.3	23.7	52.4
	05:45	55.7	52.7	52.7	49.3	48.4	43.9	36.4	23.7	52.5
	06:00	56.4	52.2	52.9	49.4	48.4	43.9	36.4	23.8	52.6
	06:15	56.7	52.6	53.1	49.6	48.6	44.1	36.4	23.7	52.8
	06:30	57.2	52.6	52.9	49.5	48.7	44.1	36.4	23.6	52.8
	06:45	58.9	53.8	53.6	50.7	49.6	44.9	37.0	24.0	53.7

Table A-16 - Arithmetic average octave band night-time $L_{90,15min}$ levels Position L4


Time	Measured $L_{90,1hr}$ (dB) at each octave band centre frequency								
	63 Hz	125 Hz	250 Hz	500 Hz	1 kHz	2 kHz	4 kHz	8 kHz	dBA
23:00	54.7	51.3	52.0	49.1	48.3	43.8	36.5	23.8	52.3
23:15	54.8	51.2	52.0	49.1	48.3	43.9	36.4	23.9	52.3
23:30	54.5	50.9	51.8	49.0	48.2	43.8	36.4	23.8	52.2
23:45	54.4	50.9	51.8	48.9	48.1	43.7	36.4	23.8	52.1
00:00	54.7	51.1	51.6	48.9	48.1	43.7	36.4	23.8	52.1
00:15	54.3	51.0	51.6	48.9	48.1	43.7	36.4	23.8	52.1
00:30	54.3	50.8	51.5	48.9	48.1	43.7	36.4	23.9	52.1
00:45	54.1	50.8	51.4	48.8	48.1	43.7	36.4	23.9	52.0
01:00	53.8	50.6	51.5	48.8	48.1	43.7	36.4	23.9	52.0
01:15	54.0	50.7	51.5	48.7	48.0	43.7	36.4	23.9	52.0

Time	Measured $L_{90,1hr}$ (dB) at each octave band centre frequency								
	63 Hz	125 Hz	250 Hz	500 Hz	1 kHz	2 kHz	4 kHz	8 kHz	dBA
01:30	53.8	50.6	51.4	48.8	48.0	43.6	36.4	23.9	52.0
01:45	53.9	50.7	51.5	48.7	48.0	43.7	36.4	23.9	52.0
02:00	53.9	50.7	51.5	48.8	48.0	43.6	36.3	23.9	52.0
02:15	54.0	50.7	51.4	48.8	48.0	43.6	36.3	23.8	52.0
02:30	54.0	50.7	51.4	48.8	48.0	43.6	36.3	23.8	52.0
02:45	53.9	50.7	51.4	48.8	48.0	43.6	36.3	23.8	52.0
03:00	53.9	50.7	51.5	48.8	48.0	43.6	36.3	23.7	52.0
03:15	53.9	50.7	51.5	48.9	48.0	43.6	36.3	23.7	52.0
03:30	54.0	50.8	51.5	48.9	48.0	43.6	36.3	23.7	52.0
03:45	54.1	50.9	51.6	48.9	48.0	43.7	36.3	23.8	52.1
04:00	54.3	50.9	51.6	49.0	48.1	43.7	36.3	23.8	52.1
04:15	54.1	50.9	51.6	49.0	48.1	43.8	36.4	23.9	52.1
04:30	54.2	50.9	51.5	49.0	48.1	43.7	36.4	23.8	52.1
04:45	54.1	51.0	51.7	49.0	48.2	45.5	37.1	23.9	52.6
05:00	54.4	51.2	51.8	49.1	48.2	43.8	36.4	23.9	52.2
05:15	54.3	51.2	51.9	49.2	48.2	43.8	36.5	23.9	52.3
05:30	54.7	51.6	52.0	49.3	48.3	43.9	36.5	24.0	52.4
05:45	54.7	51.6	52.0	49.3	48.3	43.9	36.5	24.0	52.4
06:00	55.4	51.7	52.2	49.4	48.5	44.1	36.7	24.1	52.5
06:15	55.9	52.2	52.4	49.6	48.6	44.2	36.7	24.1	52.7
06:30	56.1	52.2	52.4	49.6	48.6	45.1	37.6	24.1	52.9
06:45	56.5	52.4	52.6	49.8	48.9	44.3	36.8	24.2	52.9
Minimum	53.8	50.6	51.4	48.7	48.0	43.5	35.2	21.9	52.0




Appendix B

SUMMARY OF NOISE MONITORING EQUIPMENT



Measurement position	Equipment	Make/Model	Serial No.	Calibration due
L1	Sound Level Meter	01dB-METRAVIB Solo Master	60531	8 September 2021
	Pre-amplifier	01dB-Stell PRE 21 S	16422	
	Microphone	Microtech Gefell GmbH MCE212	333438	
	Calibrator	01dB-Metavib Cal 21	31460	28 July 2021
L2	Sound Level Meter	01 dB CUBE	10621	14 May 2021
	Pre-amplifier	Acoem PRE 22	10635	
	Microphone	GRAS 40CD	207269	
	Calibrator	01 dB Metravib CAL 21	3434463	4 August 2021
L3	Sound Level Meter	01dB-METRAVIB Solo Master	65806	2 November 2021
	Pre-amplifier	01dB-Stell PRE 21 S	16461	
	Microphone	Microtech Gefell GmbH MCE212	166412	
	Calibrator	01dB-Metavib Cal 21	35054825	24 July 2021



Appendix C

TECHNICAL GLOSSARY

NOISE

Noise is defined as unwanted sound. Human ears are able to respond to sound in the frequency range 20 Hz (deep bass) to 20,000 Hz (high treble) and over the audible range of 0 dB (the threshold of perception) to 140 dB (the threshold of pain). The ear does not respond equally to different frequencies of the same magnitude, but is more responsive to mid-frequencies than to lower or higher frequencies. To quantify noise in a manner that approximates the response of the human ear, a weighting mechanism is used. This reduces the importance of lower and higher frequencies, in a similar manner to the human ear.

Furthermore, the perception of noise may be determined by a number of other factors, which may not necessarily be acoustic. In general, the impact of noise depends upon its level, the margin by which it exceeds the background level, its character and its variation over a given period of time. In some cases, the time of day and other acoustic features such as tonality or impulsiveness may be important, as may the disposition of the affected individual. Any assessment of noise should give due consideration to all of these factors when assessing the significance of a noise source.

The most widely used weighting mechanism that best corresponds to the response of the human ear is the 'A'-weighting scale. This is widely used for environmental noise measurement, and the levels are denoted as dB(A) or L_{Aeq} , L_{A90} etc, according to the parameter being measured.

The decibel scale is logarithmic rather than linear, and hence a 3 dB increase in sound level represents a doubling of the sound energy present. Judgement of sound is subjective, but as a general guide a 10 dB(A) increase can be taken to represent a doubling of loudness, whilst an increase in the order of 3 dB(A) is generally regarded as the minimum difference needed to perceive a change under normal listening conditions.

An indication of the range of sound levels commonly found in the environment is given in the following table.

Table 17 - Range of sound levels commonly found in the environment

Sound levels	Location
0 dB(A)	Threshold of hearing
20 to 30 dB(A)	Quiet bedroom at night
30 to 40 dB(A)	Living room during the day
40 to 50 dB(A)	Typical office
50 to 60 dB(A)	Inside a car
60 to 70 dB(A)	Typical high street
70 to 90 dB(A)	Inside factory
100 to 110 dB(A)	Burglar alarm at 1m away
110 to 130 dB(A)	Jet aircraft on take off
140 dB(A)	Threshold of pain

ACOUSTIC TERMINOLOGY

Terminology

Meaning

dB (decibel)	The scale on which sound pressure level is expressed. It is defined as 20 times the logarithm of the ratio between the root-mean-square pressure of the sound field and a reference pressure ($2 \times 10^{-5} \text{Pa}$).
dB(A)	A-weighted decibel. This is a measure of the overall level of sound across the audible spectrum with a frequency weighting (i.e. 'A' - weighting) to compensate for the varying sensitivity of the human ear to sound at different frequencies.
$L_{Aeq,T}$	L_{Aeq} is defined as the notional steady sound level which, over a stated period of time (T), would contain the same amount of acoustical energy as the A - weighted fluctuating sound measured over that period.
L_{Amax}	L_{Amax} is the maximum A - weighted sound pressure level recorded over the period stated. L_{Amax} is sometimes used in assessing environmental noise where occasional loud noises occur, which may have little effect on the overall L_{eq} noise level but will still affect the noise environment. Unless described otherwise, it is measured using the 'fast' sound level meter response.
L_{10} and L_{90}	If a non-steady noise is to be described it is necessary to know both its level and the degree of fluctuation. The L_n indices are used for this purpose, and the term refers to the level exceeded for n% of the time. Hence L_{10} is the level exceeded for 10% of the time, and the L_{90} is the level exceeded for 90% of the time.
Free-field Level	A sound field determined at a point away from reflective surfaces other than the ground with no significant contributions due to sound from other reflective surfaces. Generally as measured outside and away from buildings.
Façade Level	A sound field determined at a distance of 1m in front of a large sound reflecting object such as a building façade.

Appendix D

LIMITATIONS





This report has been prepared for the titled project or named part thereof and should not be used in whole or part and relied upon for any other project without the written authorisation of WSP UK Limited. WSP UK Limited accepts no responsibility or liability for the consequences of this document if it is used for a purpose other than that for which it was commissioned. Persons wishing to use or rely upon this report for other purposes must seek written authority to do so from the owner of this report and/ or WSP UK Limited and agree to indemnify WSP UK Limited for any and all loss or damage resulting therefrom. WSP UK Limited accepts no responsibility or liability for this document to any other party other than the person by whom it was commissioned.

The findings and opinions expressed are relevant to the dates of the site works and should not be relied upon to represent conditions at substantially later dates. Opinions included therein are based on information gathered during the study and from our experience. If additional information becomes available which may affect our comments, conclusions or recommendations WSP UK Limited reserve the right to review the information, reassess any new potential concerns and modify our opinions accordingly.



8 First Street
Manchester
M15 4RP

wsp.com

PUBLIC