



**MANCHESTER
CITY COUNCIL**

**Capital Programmes & Procurement
Corporate Services Directorate**

Telephone: +44 (0)161 600 7921

Mobile No. : 07789 984213

Anthony.johnson@manchester.gov.uk

Anthony Johnson Capital Programmes &
Procurement, Corporate Services
Directorate, Manchester City Council, PO
Box 532, Town Hall, Manchester, M60 2LA

Technical Support Team Planning,
Telephone: 0161 234 4516
planning@manchester.gov.uk
P O Box 532
Town Hall Manchester M60 2LA

Date: 15th April 2021

Our Ref: LP44862

Dear Sir /Madam,

Application Number: 129748/LO/2021

Proposal: Listed Building Consent for internal refurbishment and upgrade works including upgrading of security and connectivity services together with external works including the installation of security grills.

Location: Wythenshawe Hall , Wythenshawe Park, Nathans Road, Manchester, M23 0AB

Further to your letter of the 23rd March 2021, in response to my recent planning submission. You stated that you were unable to progress my proposal as the application is invalid or incomplete for the following reason(s):

1) You have submitted an existing CCTV layout around the Hall but it is unclear from the proposed works whether the intention is to alter the external CCTV system. If the position or locations of external CCTV equipment is being altered please provide a proposed drawing showing location and details of CCTV system to be installed and amend your application site edged red plan to include the area of these works.

If the external provision is being altered you may also need to submit a separate planning application for this element of the works

In response to the issue raised above I can confirm that the positions/location of the external CCTV cameras are remaining in their original positions as indicated on drawing 02-MCC ZZ-GF-DR-E-011-S2.

The existing temporary wiring feeding the cameras is currently installed down the corridors within the Hall running through doorways. The doors cannot be closed due to the cables obstructing the doors.

We are therefore proposing to divert the cables into a new proposed buried duct to feed the cameras in their current positions as shown on drawing 02-MCC ZZ-GF-DR-E-011-S2.

I would therefore be grateful if you could process my application for the proposed works.

We trust that the enclosed is acceptable, but if you have any queries please do not hesitate to contact the above named officer.

Yours sincerely
For and on behalf of
Manchester City Council

A handwritten signature in black ink, appearing to read 'A. Johnson', with a stylized flourish at the end.

Anthony Johnson
Senior Building Surveyor