


FIRE STRATEGY - KEY

Individual apartment to include stand alone BS5839 part 6 fire alarm

- FD 30s** Fire door with 30 mins fire rating and smoke seal
- SD** Smoke Detector
- SDH** Smoke Detector at high level with roof vent (where used to over 600mm)
- HD** Heat Detector fitted in kitchen
- Protected area to provide 60 mins fire protection



Tel : 0161 844 7263
Email: mail@graysarchitecture.co.uk
Client: Dappa Homes Ltd

Project: Whitehouse Club, Middleton, Crumpsall, M8 4JZ

Drawing Title: Proposed Second Floor Plan

Scale: 1:50 @ A1 Date: January 2020

Drawing No: 4050 / 212 Revision: C