



T 07899661874

M paulewardsservices@btinternet.com

Report: J007

Site no.: 42

Five Points Brewing Co

61 Mare Street, Hackney, London

E8 4RG

Measurement from 16/12/2020 13:35:56

Device type:	RASI300
Serialnumber:	128148
Firmwareversion:	1.07.65
Fuel:	Natural gas
O2 Ref:	0 %
CO2max:	11.9 %

Firing Position			High
O2	%	5.1	
CO	ppm	32	
Exc. Air	%	32	
T-air	°C	12.7	
Eff. NCV	%	92.1	

Gas Pressure	Mb	6.8
CO2	%	9.0
CO/CO2	%	0.0004
T-Stack	°C	146.5
Eff. GCV	%	83.5
Draft	mbar	0.504

Comment

Five Points Brewing - High Fire

16/12/2020

Date

Signature

Acceptance

