

LEGEND:

- WALL CONTROLLER SERVING FCU. GALVANISED CONDUIT DROP FROM H/L TO CONTROLLER WHERE EXPOSED.
- REFRIGERANT
- SUPPLY DUCT
- EXTRACT DUCT
- FCU
- SUPPLY GRILLE
- DOMESTIC COLD WATER
- ABOVE GROUND FOUL DRAINAGE

NOTE:

ALL NEW MEP EQUIPMENT AESTHETIC AND FIXING METHODS TO MATCH THE EXISTING CAT A INSTALLATION

REFRIGERANT PIPEWORK AND ASSOCIATED TRAY TO BE MODIFIED BY LANDLORD TO MOVE FCU ONTO VRF SYSTEM 2.

REFRIGERANT PIPEWORK ROUTED IN REDUNDANT LIFT SHAFT TO ROOF LEVEL CONDENSER

REFRIGERANT PIPEWORK ROUTED ON EXISTING TRAY

REFRIGERANT PIPEWORK AND ASSOCIATED TRAY TO BE MODIFIED BY LANDLORD TO MOVE FCU ONTO VRF SYSTEM 1

DUCTWORK TO BE MODIFIED

PUMPED CONDENSATE WASTE CONNECTIONS INTO EXISTING SYSTEM AT HIGH LEVEL

MITSUBISHI PKA-M35MHA DX UNIT TO SERVE COMMS ROOM COOLING

MODIFY FCU DUCTWORK

ROTATE FCU AND MODIFY DUCTWORK. EXTEND REFRIGERANT PIPE RUN AS NEEDED

ADDITIONAL FCU TO SERVE 6 PERSON MEETING ROOM. REFRIGERANT ROUTE TO BE EXTENDED TO SUIT

ADDITIONAL FCU TO SERVE MULTIPURPOSE ROOM. REFRIGERANT ROUTE TO BE EXTENDED TO SUIT

TARIFF STREET

HILTON STREET

BREWER STREET

INA LANE

Issue	16/03/20	FIRST ISSUE	TV	RT	RS
Date		Description	By	Chkd	Verfd

Project
FOURWAYS HOUSE

Client
CUNDALL
Architect
PS INTERIORS

Title
MECHANICAL ALTERATIONS

Drawing No.	SK-M-01	Drawing Status	S4 - FOR TENDER
-------------	---------	----------------	-----------------

Job No.	1030529	Scale	1:75
---------	---------	-------	------

Originator	TV	Checker	RT	Verified	RS	Issue	S4
------------	----	---------	----	----------	----	-------	----

CUNDALL

1 Carter Lane
London
EC4V 5ER
Telephone: +44 20 7438 1600

Website: www.cundall.com