



Method Statement for Fire Upgrade to existing doors.

Author:

Padraig O'Neill

Location of works: Manchester Jewish Museum

Brief Description: Method statement for the fire upgrade of existing doors to FD30 doors

Methodology:

- First carefully remove the panel face (one side)
- If a solid panel then carefully split the panel into two.
- If it cannot be split then replace the face timber with a timber of comparable thickness, quality and appearance.
- Make the aperture clean and square.
- Centrally locate 12.5mm 30 minute fire board.
- Bead the plasterboard in with a timber section no less than 15mm square, pinned in place with 50mm long steel pins inserted from both sides at 150mm centres at a 35 degree angle to the vertical.
- Re attach the existing face using adhesive or secret pinning.
- Re pin the panel perimeter to match the original removed beads.