

GENERAL NOTES

- 1.10 THESE DRAWINGS ARE RIBA STAGE 2+ DESIGN INTENT DRAWINGS. THE CONTRACTOR SHALL BE RESPONSIBLE FOR DEVELOPING THESE DRAWINGS TO RIBA STAGE 4 LEVEL OF DETAIL FOR FORMAL SIGN OFF BEFORE INSTALLATION ON SITE.
- 2.10 THE CONTRACTOR SHALL TAKE FULL DESIGN RESPONSIBILITY FOR THE ALL M&E DESIGN ON THE PROJECT.
- 3.10 FINAL ROOM COUNTS TO BE CONFIRMED AT A LATER STAGE. ALLOCATION OF GUESTROOM TYPE A AND B INDICATIVE FOR INFORMATION PURPOSES. THESE SHALL BE CONFIRMED POST CONTRACT AWARD.

VENTILATION SERVICES NOTES

- 1.00 ALL DUCTWORK SIZES NOTED ARE INTERNAL SIZES.
- 2.00 ACCESS GATES SHALL BE PROVIDED IN DUCTS TO ALL FIRE DAMPERS WHERE RELEVANT.
- 3.00 FIRE STOPPING SHALL BE PROVIDED ON SLAB PENETRATIONS WHERE REQUIRED.
- 4.00 CONTRACTOR TO REFER TO IN2 ENGINEERING MECHANICAL SPECIFICATION FOR FURTHER DETAIL.
- 5.00 CONTRACTOR TO REFER TO IN2 ENGINEERING M2000 SERIES DRAWINGS FOR ASSOCIATED VENTILATION DRAWINGS.
- 6.00 ALL PROPOSED DUCTWORK SIZES INDICATED ON THIS DRAWING ARE PURELY INDICATIVE TO AID IN TENDERING. THE CONTRACTOR SHALL ACCEPT FULL DESIGN RESPONSIBILITY.

VENTILATION DUCTWORK REFERENCE KEY

- EXTRACT DUCTWORK
- SUPPLY DUCTWORK
- FRESH AIR DUCTWORK
- FRESH AIR DUCTWORK
- DUCTWORK RISE / FALL - TO / FROM ABOVE
- DUCTWORK RISE / FALL - TO / FROM BELOW

ITEM KEY	DESCRIPTION	ITEM TAG
XX l/s	WALL MOUNTED SUPPLY DISC VALVE	SG.X.X.XX
XX l/s	EXTRACT DISC VALVE	EG.X.X.XX
XXX l/s	VOLUME CONTROL DAMPER	VCD.X.X.XX
	MOTORISED FIRE SMOKE DAMPER	MFSD.X.X.XX
	CROSS TALK ATTENUATOR	ATT.X.X.XX

SCOPE REFERENCE KEY

SCOPE KEY:	AS PER SCOPE	SCOPE TYPE DESCRIPTION	REF: DRAWINGS
	GUESTROOM TYPE A	OPENED BATHROOM	E-00 & M00 TYPICAL GUESTROOM DRAWINGS
	GUESTROOM TYPE B	INTERNAL REFURB BATHROOM	E-00 & M00 TYPICAL GUESTROOM DRAWINGS
	MINIMAL MEP SCOPE	MINIMAL MEP SCOPE	ELEC & MECH SPECIFICATION
	NO MEP SCOPE	NOT IN PROJECT WORKS	

