This document and its contents are the property of the Purchaser/Employer and Crookes Walker Consulting. They may not be copied or reproduced in any way, in part or whole, without prior written approval of both parties. Violations will result in legal action.
This drawing shall be read in conjunction with the CWC Mechanical and / or Electrical Specification(s).
DO NOT SCALE FROM THIS DRAWING

DESIGNERS RISK ASSESSMENT
REFER TO APPENDIX 1 OF M&E SPECIFICATION FOR DESIGNERS RISK ASSESSMENT SCHEDULE

DRAWING BACKGROUND(S):

COMPANY	DRAWING NUMBER	REV
SHEPPARD ROBSON	6702-20-100	E

LOUVRE TO REPLACE UPPER WINDOW PANE (GENERAL SUPPLY)
LOUVRE TO REPLACE UPPER WINDOW PANE (GENERAL EXTRACT)
LOUVRE TO REPLACE UPPER WINDOW PANE (GENERAL EXTRACT)
LOUVRE TO REPLACE UPPER WINDOW PANE (GENERAL SUPPLY)
LOUVRE AT H/L (TOILET EXTRACT)
VENTILATION STRATEGY FOR THE RETAIL UNITS IS TO PROVIDE GENERAL SUPPLY/EXTRACT & KITCHEN MAKE-UP AIR FROM LOUVRES WITHIN THE BUILDING FACADE IN THE LOCATION INDICTATED AND DUCTED KITCHEN EXTRACT TO ROOF LEVEL
VENTILATION STRATEGY FOR THIS RETAIL UNITS IS TO PROVIDE GENERAL SUPPLY/EXTRACT & FROM LOUVRES WITHIN THE BUILDING FACADE IN THE LOCATION INDICATED AND A RECIRCULATION KITCHEN EXTRACT SYSTEM WHICH DOES NOT REQUIRE A DUCTED EXTRACT TO ROOF
EXISTING 110mmØ RETAIL TENANT 03 ABOVE GROUND DRAINAGE CONNECTION AT LOW LEVEL
280mm MCWS SUPPLIES TO UNIT 3 RELOCATED FROM BASEMENT LEVEL AND TERMINATE WITHIN RISER AT GF LEVEL
EXISTING 110mmØ RETAIL TENANT 03 ABOVE GROUND DRAINAGE CONNECTION WITHIN RISER
CONDENSER WATER FLOW & RETURN CONNECTIONS FOR RETAIL TENANT 03 WITHIN RISER
LOUVRE TO REPLACE UPPER & LOWER WINDOW PANE (KITCHEN MAKEUP AIR IF REQUIRED)
LOUVRE TO REPLACE UPPER WINDOW PANE (GENERAL SUPPLY)
LOUVRE TO REPLACE UPPER WINDOW PANE (GENERAL EXTRACT)
RETAIL TENANT 01 KITCHEN EXTRACT RISER PROVISION TO ROOF
RETAIL TENANT 02 KITCHEN EXTRACT RISER PROVISION TO ROOF
VENTILATION STRATEGY FOR THE RETAIL UNITS IS TO PROVIDE GENERAL SUPPLY/EXTRACT AIR FROM LOUVRES WITHIN THE BUILDING FACADE IN THE LOCATION INDICATED
28mmØ MCWS SUPPLIES TO UNIT 4 RELOCATED FROM BASEMENT LEVEL AND TERMINATE WITHIN RISER AT GF LEVEL
EXISTING 110mmØ RETAIL TENANT 04 ABOVE GROUND DRAINAGE CONNECTION WITHIN RISER
VENTILATION STRATEGY FOR THE RETAIL UNITS IS TO PROVIDE GENERAL SUPPLY/EXTRACT & KITCHEN MAKE-UP AIR FROM LOUVRES WITHIN THE BUILDING FACADE IN THE LOCATION INDICTATED AND DUCTED KITCHEN EXTRACT TO ROOF LEVEL
EXISTING 110mmØ RETAIL TENANT 04 ABOVE GROUND DRAINAGE CONNECTION WITHIN RISER
LOUVRE AT H/L (TOILET EXTRACT)
LOUVRE TO REPLACE UPPER WINDOW PANE (GENERAL EXTRACT)
LOUVRE TO REPLACE UPPER WINDOW PANE (GENERAL SUPPLY)
LOUVRE TO REPLACE UPPER WINDOW PANE (GENERAL EXTRACT)
LOUVRE TO REPLACE UPPER WINDOW PANE (GENERAL SUPPLY)
ex. tunnel - location TBC

Rev	Date	Description	Eng
T2	24.02.21	UPDATED TO SUIT NEW LAYOUT	BH CW
T1	22.01.21	STAGE 4 TENDER ISSUE	BH CW
P1	17.12.20	DRAFT STAGE 3 ISSUE	BH CW

CWC crookes walker consulting
Alberton House, 3D St Mary's Parsonage
Manchester M3 2WJ
Tel: 0161 834 9999
The Plaza, Old Hall Street,
Liverpool L3 9QJ
Tel: 0151 600 5409
E-mail: admin@cwcon.co.uk
Website: www.cwcon.co.uk

Client
NOMA LTD
PARTNERSHIP ACTING
BY NOMA GP LTD

Project
HANOVER NOMA -
RETAIL SPACE

Drawing Title
GROUND FLOOR
MECHANICAL SERVICES

Status
STAGE 4

Project No.	Drawn	Scale / Paper Size
2167	BH	1:100 @ A0

Drawing No. 2167-GF-4001
Rev T2