

Design for Access 2

Laystall Street
1283/Da
26.03.20

OMI

Item	DFA2 Standard	Compliant with DFA2 N/A	Not Compliant with DFA2 but exceeds Part M Requirements	Not Compliant with DFA2	Notes
1.1.0	On Street Parking				
1.1.1	Designated parking bays on the highway for disabled people require a Traffic Regulation Order under the Traffic Regulation Act 1984.	N/A	N/A	N/A	
1.1.2	When parallel to the kerb, on-street designated parking bays should be 6600mm long and preferably 3600mm (minimum 2700mm) wide, as shown in diagram 1.1.	N/A	N/A	N/A	
1.1.3	When at an angle to the kerb, on-street designated parking bays should be 4200mm long and 3600mm wide.	N/A	N/A	N/A	
1.1.4	The bay should be clearly marked with the word 'DISABLED' as well as being clearly signed with the Blue Badge symbol. The signing and lining associated with this type of bay must comply with the Traffic Signs Regulations and General Directions 2002.	N/A	N/A	N/A	
1.1.5	The pole sign should clearly say whether payment is required.	N/A	N/A	N/A	
1.1.6	A dropped kerb should be provided to permit convenient access from the parking bay onto the pavement.	N/A	N/A	N/A	

Design for Access 2

Laystall Street
1283/Da
26.03.20

OMI

Item	DFA2 Standard	Compliant with DFA2 N/A	Not Compliant with DFA2 but exceeds Part M Requirements	Not Compliant with DFA2	Notes
1.1.7	Accessible parking bays should be located on pedestrian access routes.	N/A	N/A	N/A	
1.2.0	Off Street Parking				
1.2.1	In pedestrianised areas, car parking for disabled people should be within 50 metres of the destination.	N/A	N/A	N/A	
1.2.2	Individual bays and spaces should be wide enough to allow wheelchair transfer to and from the vehicle. The bay dimensions should be 4800mm x 2400mm with a minimum 1200mm 'safety zone' around the bay to maintain access to both the sides and the rear of the vehicle.	N/A	N/A	N/A	
1.2.3	For economy of space, parking bays can be located side by side with a shared space of 1200mm between the two bays, as shown in diagram 1.2.	N/A	N/A	N/A	
1.2.4	Where a covered area is involved, headroom should be no lower than 2600mm.	N/A	N/A	N/A	
1.2.5	The bays should be clearly marked with the Wheelchair Symbol on the surface as well as being clearly signed with the Blue Badge symbol.	N/A	N/A	N/A	
1.2.6	All designated parking bays for disabled people must be accessible from a safe independent pedestrian route.	N/A	N/A	N/A	

Design for Access 2

Laystall Street
1283/Da
26.03.20

OMI

Item	DFA2 Standard	Compliant with DFA2 N/A	Not Compliant with DFA2 but exceeds Part M Requirements	Not Compliant with DFA2	Notes
1.2.7	A dropped kerb should be provided to permit convenient access from the parking bay onto the pedestrian area.	N/A	N/A	N/A	
1.2.8	The surface of the parking space should be even and stable with any variation of surface profile not exceeding 5mm, that is, between paving, surface features and mix of different surfaces or finishes.	N/A	N/A	N/A	
1.2.9	Information, including payment terms, should be provided at the entrance to a car park to make it clear whether or not free parking is available to disabled motorists.	N/A	N/A	N/A	
1.2.10	The following ratio of accessible parking bays should be used for new developments: 1 - 10 bays must include 1 accessible bay 11 - 25 bays must include 2 accessible bays 26 - 50 bays must include 4 accessible bays 51 - 75 bays must include 8 accessible bays 76 - 100 bays must include 12 accessible bays 100 + parking bays must include 12% accessible bays.	N/A	N/A	N/A	
1.3.0	Multi Storey Car Parks				

Design for Access 2

Laystall Street
1283/Da
26.03.20

OMI

Item	DFA2 Standard	Compliant with DFA2 N/A	Not Compliant with DFA2 but exceeds Part M Requirements	Not Compliant with DFA2	Notes
1.3.1	The design of multi-storey car parks should meet the technical requirements in the previous section 1.2: Off-Street Parking.	N/A	N/A	N/A	
1.3.2	The dimensions of an enclosed parking space should be 4200mm x 5700mm. Headroom should be no lower than 2600mm.	N/A	N/A	N/A	
1.3.3	Car park entry and pay equipment should be capable of use without the driver leaving their vehicle, in terms of closeness of approach and simplicity of operation.	N/A	N/A	N/A	
1.3.4	Systems which rely only on intercoms should not be used.	N/A	N/A	N/A	
1.4.0	Garages, Secure and Enclosed Parking				
1.4.1	The access route should be level and preferably under cover.	N/A	N/A	N/A	
1.4.2	The dimensions of an enclosed parking space should be 4200mm x 5700mm. Headroom should be no lower than 2600mm.	N/A	N/A	N/A	
1.4.3	Where power-operated systems are fitted to the entrance to enclosed private parking or garages they should be remotely operable from inside a vehicle.	N/A	N/A	N/A	
1.5.0	Taxi Ranks				

Design for Access 2

Laystall Street
1283/Da
26.03.20

OMI

Item	DFA2 Standard	Compliant with DFA2 N/A	Not Compliant with DFA2 but exceeds Part M Requirements	Not Compliant with DFA2	Notes
1.5.1	Taxi ranks should have accessible seating, good lighting, shelter, and directional and other signage.	N/A	N/A	N/A	
1.5.2	Taxi ranks should be well signed throughout the City, should be on safe pedestrian routes which include dropped kerbs and tactile surfaces and, if possible, should be near to a controlled crossing.	N/A	N/A	N/A	
1.5.3	Taxi ranks should be located so that passengers can board at the near side (not the driver's side) of the taxicab.	N/A	N/A	N/A	
1.5.4	Barriers or bollards should not be located near taxi ranks where they would obstruct the use of taxicab ramps.	N/A	N/A	N/A	
2	Pedestrian Crossing, Dropped Kerbs and Tactile surfaces				
2.1.1	Uncontrolled crossings should have tactile paving which is buff or a colour (other than red) which provides a contrast with the surrounding footway surface.	N/A	N/A	N/A	

Design for Access 2

Laystall Street
1283/Da
26.03.20

OMI

Item	DFA2 Standard	Compliant with DFA2 N/A	Not Compliant with DFA2 but exceeds Part M Requirements	Not Compliant with DFA2	Notes
2.1.2	Tactile paving one tile deep (400mm) should be provided on the approach to dropped kerbs to span the width of the crossing. When the pedestrian crossing is in line with the direction of pedestrian movement the number of tiles should increase to three in depth (1200mm). When the crossing is away from a junction the tactile paving should be two tiles deep (800mm). See diagram 2.1.	N/A	N/A	N/A	
2.1.3	Tactile paving should generally be installed to provide a perpendicular crossing point to the kerb edge. When the crossing point is askew, skewed tactiles can be used to direct pedestrians to the line of walk.	N/A	N/A	N/A	
2.1.4	Crossing points should be located on the pedestrian line of walk, even if this is across a radius kerb.	N/A	N/A	N/A	
2.1.5	Pedestrian crossing points on segregated cycle tracks should be provided with a corduroy hazard warning surface.	N/A	N/A	N/A	
2.2.0	Controlled Crossings				
2.2.1	Signalised controlled crossings should have visual and audible signals for pedestrians, with red tactile paving and a white kerb edge.	N/A	N/A	N/A	
2.2.2	For standard 'L' shaped tactiles the tail should extend to the back of the footway or for 5000mm. See diagram 2.2a.	N/A	N/A	N/A	

Design for Access 2

Laystall Street
1283/Da
26.03.20



Item	DFA2 Standard	Compliant with DFA2 N/A	Not Compliant with DFA2 but exceeds Part M Requirements	Not Compliant with DFA2	Notes
2.2.3	For 'L' shaped tactiles on askew crossing points, tactile paving at the kerb edge should be two tiles (800mm) deep. If the crossing is in line with the direction of pedestrian flow, tactile paving at the kerb edge should be three tiles deep. See diagram 2.2b.	N/A	N/A	N/A	
2.2.4	Controls should be set at a height of 900mm from ground level.	N/A	N/A	N/A	
2.3.0	Refuge Islands				
2.3.1	Diagram 2.3a shows a refuge island arrangement when the island width is less than 2000mm. This narrow refuge should only be used where the width of the carriageway does not permit the use of a wider refuge. There are three rows of tactile.	N/A	N/A	N/A	
2.3.2	Diagram 2.3b shows a refuge island arrangement when the island width is greater than 2000mm. There are two separate rows of tactile each 2 tiles deep.	N/A	N/A	N/A	
2.3.3	Diagram 2.3c shows a refuge island arrangement for a staggered crossing facility. There are two rows of tactiles, two tiles deep, at each crossing point, and guardrails around the island.	N/A	N/A	N/A	
2.4.0	Raised Crossing				

Design for Access 2

Laystall Street
1283/Da
26.03.20

OMI

Item	DFA2 Standard	Compliant with DFA2 N/A	Not Compliant with DFA2 but exceeds Part M Requirements	Not Compliant with DFA2	Notes
2.4.1	When raising the level of the carriageway to that of the footway, the resulting surface of the traffic calming feature should be flush with that of the footway. Care should be taken in the design, particularly at road junctions.	N/A	N/A	N/A	
2.4.2	The gradient of the ramps at each side of the hump or plateau should be maximum 1 in 12 (8%).	N/A	N/A	N/A	
2.4.3	Guard railing should be provided to 'deflect' pedestrians when the crossing point is not on the line of walk.	N/A	N/A	N/A	
2.4.4	Tactile arrangements should be as described in sections 2.1: Uncontrolled Crossings and 2.2: Controlled Crossings.	N/A	N/A	N/A	
2.4.5	See diagram 2.4 for details of raised crossings.	N/A	N/A	N/A	
2.5.0	Metrolink Crossing				
2.5.1	For street running sections, the pedestrian crossing points should be treated in the same way as for carriageways, that is, controlled or uncontrolled crossings, with appropriate tactile paving and dropped kerbs, should be provided.	N/A	N/A	N/A	
2.6.0	Dropped Kerbs				
2.6.1	All pedestrian crossings should have a dropped kerb and tactile paving.	N/A	N/A	N/A	

Design for Access 2

Laystall Street
1283/Da
26.03.20



Item	DFA2 Standard	Compliant with DFA2 N/A	Not Compliant with DFA2 but exceeds Part M Requirements	Not Compliant with DFA2	Notes
2.6.2	Dropped kerbs should have a maximum 6mm upstand. Detailed design prior to the installation of tactile paving is shown in diagram 2.6. These design details also apply to vehicular crossovers and vehicular accesses.	N/A	N/A	N/A	
2.6.3	Gullies should not be located in the highway channel at dropped crossings and gradients should be sufficient to avoid ponding of water at the crossing.	N/A	N/A	N/A	
2.6.4	Consideration should be given to measures to prevent the obstruction of dropped kerbs on uncontrolled crossings by parked vehicles.	N/A	N/A	N/A	
2.7.0	Tactile Surfaces				
2.7.1	The nationally recommended tactile surfaces should be used for platform edges, segregated shared cycle tracks, guidance paths and information.				TBC by Landscape Architect
2.7.2	Where possible, pedestrians should be segregated from cyclists by a change in level on joint pedestrian/cycle routes.				TBC by Landscape Architect

Design for Access 2

Laystall Street
1283/Da
26.03.20



Item	DFA2 Standard	Compliant with DFA2 N/A	Not Compliant with DFA2 but exceeds Part M Requirements	Not Compliant with DFA2	Notes
2.7.3	A corduroy hazard warning surface should be used to alert people of hazards, for example, at steps, on level crossings and at the approach to on-street Metrolink platforms. Corduroy surfacing should also be used, on the cyclists' side, where a footway joins a segregated shared route for cyclists and pedestrians.				TBC by Landscape Architect
2.7.4	The profiles and plans of blister and hazard warning tactile surfaces are shown in diagram 2.7.				TBC by Landscape Architect
3.1.0	Access Routes				
3.1.1	Access routes should have a firm and smooth surface.	To be compliant			
3.1.2	Access routes should either be level or have the shallowest possible gradient. Any access route that has a gradient of 1 in 20 (5%) or steeper should conform to the recommendations for ramped access in section 6: Ramps.	To be compliant			
3.1.3	The joints between paving units should be flush with the surface. If this is not feasible, the joints should be no wider than 10mm, so long as they are completely filled, and no wider than 5mm if recessed.	To be compliant			

Design for Access 2

Laystall Street
1283/Da
26.03.20



Item	DFA2 Standard	Compliant with DFA2 N/A	Not Compliant with DFA2 but exceeds Part M Requirements	Not Compliant with DFA2	Notes
3.1.4	With the exception of tactile paving and hazard warning, undulations in the surface of paving on an access route should not exceed 5mm under a 3000mm straight edge.	To be compliant			
3.1.5	Drainage gratings should be positioned beyond the boundaries of the access route. Where this is not possible the gratings should be set flush with the surrounding surface.	To be compliant			
3.1.6	Kerb edges and upstands of 100mm and above should be defined by colour and luminance contrast.	To be compliant			
3.1.7	The cross fall gradient across an access route from building to pavement should not exceed 1 in 50 (2%) except when associated with a dropped kerb.	To be compliant			
3.1.8	Access routes should have a minimum unobstructed width of 2000mm, and 1800mm over a short distance to pass an obstruction, for example, a tree.			To be compliant with Doc M	
3.1.9	Access routes in shopping areas and the City Centre should have a minimum width of 3500mm and 1800mm over a short distance to pass an obstruction, for example, a tree.	N/A	N/A	N/A	
3.1.10	Footway widths at bus stops should have a minimum width of 3000mm and 1800mm over a short distance to pass an obstruction, for example, a tree.	N/A	N/A	N/A	

Design for Access 2

Laystall Street
1283/Da
26.03.20

OMI

Item	DFA2 Standard	Compliant with DFA2 N/A	Not Compliant with DFA2 but exceeds Part M Requirements	Not Compliant with DFA2	Notes
3.1.11	Access routes should not contain obstacles. Where an obstacle cannot be removed an alternative permanent route should be provided, where possible, and the obstacle should be identified with hazard warning. See section 4: Street Furniture.	To be compliant			
3.1.12	Where railings are provided they should have a lower rail set 100mm from the ground.	To be compliant			
3.1.13	Where there is no building line or railings, path edges should be defined with a 100mm upstand.	To be compliant			
3.1.14	The swing of entrance and exit doors and windows should not extend into an access route.	To be compliant			
3.1.15	Headroom of at least 2500mm should be provided between any footway and the underside of any projection from walls, buildings, canopies, signs, tree branches, etc.	To be compliant			
3.1.16	Street signs should use clear text against a contrasting background. See section 24: Signs and Wayfinding.	N/A	N/A	N/A	
3.1.17	See diagram 3 for details of Footways, Pathways and Access Routes.	N/A	N/A	N/A	

Design for Access 2

Laystall Street
1283/Da
26.03.20



Item	DFA2 Standard	Compliant with DFA2 N/A	Not Compliant with DFA2 but exceeds Part M Requirements	Not Compliant with DFA2	Notes
3.2.1	Highway works and other authorised work on the highway must be provided with warning signs and barriers, in accordance with Chapter 8 of the Traffic Signs Manual published by the Department for Transport, and the accompanying Code of Practice 'Safety at Street Works and Road Works'.				TBC by Main Contractor
3.2.2	Alternative safe crossings should be provided if existing dropped crossings are to be obstructed by the works.				TBC by Main Contractor
3.2.3	Hoardings, scaffolding and skips on public highways must be licensed by the City Council. If these create an obstruction the license should state the alternative access arrangements.				TBC by Main Contractor
4.1.1	Formal approval is needed from the City Council to place seats and tables on the public highway outside coffee bars, restaurants, and licensed premises. These areas should be clearly demarcated to ensure that they do not obstruct access routes.	N/A	N/A	N/A	TBC by Main Contractor
4.1.2	For those instances where formal approval is not required the guidance in this section should be taken into account as best practice.	N/A	N/A	N/A	TBC by Main Contractor
4.1.3	A-boards and other temporary features placed on the public highway are illegal and will be removed.				TBC

Design for Access 2

Laystall Street
1283/Da
26.03.20

OMI

Item	DFA2 Standard	Compliant with DFA2 N/A	Not Compliant with DFA2 but exceeds Part M Requirements	Not Compliant with DFA2	Notes
4.1.4	Temporary features which are placed on private forecourts, such as A-boards, paste tables, planters and market stalls, should be located so as not to obstruct access routes.	N/A	N/A	N/A	
4.1.5	Street furniture that cannot be removed from the footway, such as lighting columns, signposts, free standing advertisements, litter bins and seats, should be positioned in a zone not exceeding 275mm from the back of the footway or in a zone at the front of the footway starting 450mm from the kerb face. An obstacle-free route of minimum 1800mm should be retained.	To be compliant			
4.1.6	See diagram 4 for guidance on the location of street furniture.	N/A	N/A	N/A	
4.1.7	All street furniture should be clearly distinguishable from the background by careful choice of overall colour, or by the use of colour bands or clearly defined logos.	To be compliant			
4.1.8	Any posts or columns or other obstructions within a route should incorporate a band, 150mm deep, with its bottom edge 1500mm above ground level. The band should contrast in colour and luminance* with remainder of the post or column.	To be compliant			

Design for Access 2

Laystall Street
1283/Da
26.03.20



Item	DFA2 Standard	Compliant with DFA2 N/A	Not Compliant with DFA2 but exceeds Part M Requirements	Not Compliant with DFA2	Notes
4.1.9	Bollards should be at least 1000mm high and should not be linked with chains. Bollards also require a colour and luminance* contrast feature.	To be compliant			
4.1.10	Obstructions within a route should be avoided. However, where this is not possible, a sett paved textured surface should be placed around any obstacle or item of street furniture that cannot be removed from the line of walk, starting on the line of walk a minimum of 1000mm in front of the obstruction, and extending a minimum of 300mm to the side. Tree grilles are an acceptable alternative around trees, to a width of 1000mm.	To be compliant			
4.1.11	Hazard protection should be provided if an obstacle projects more than 100mm into a route and its lower edge is more than 300mm above the ground. Protection should take the form of a kerb or other solid barrier, which is colour and luminance* contrasted, and should not extend beyond the front edge of the object, nor be set back more than 100mm from its front edge.	To be compliant			
4.1.12	Spaces beneath steps, stairways and ramps should be blocked off and provided with a protective guard-rail, or with some other permanent feature, which is colour and luminance* contrasted, at least 900mm above ground level, to avoid collision with the underside.	To be compliant			

Design for Access 2

Laystall Street
1283/Da
26.03.20

OMI

Item	DFA2 Standard	Compliant with DFA2 N/A	Not Compliant with DFA2 but exceeds Part M Requirements	Not Compliant with DFA2	Notes
5	Seating				
5.1.1	Frequent resting places should be provided, not more than 50 metres apart, in pedestrian areas and at transport interchanges.	To be compliant			
5.1.2	Seats should be located in safe, clearly visible and well lit areas.	N/A	N/A	N/A	
5.1.3	Seats should be positioned off the footway, and should allow an area of 400mm in front of the seat.	N/A	N/A	N/A	
5.1.4	A firm wheelchair parking area 900mm wide should be provided on both sides of seating.	N/A	N/A	N/A	
5.1.5	The seat level should be 475-500mm from the ground. If a number of seats are to be provided, then some of these should be at a higher level.	N/A	N/A	N/A	
5.1.6	Seat width should be 500mm. Include a back support and arm rests on both sides of the sitting position.	N/A	N/A	N/A	
5.1.7	The seat colour and luminance* should contrast with the background.	N/A	N/A	N/A	
5.1.8	Use materials which do not significantly retain heat or cold. For example, some metals or plastics would be inappropriate.	N/A	N/A	N/A	
5.1.9	When seating forms an obstruction a tactile warning surface should be incorporated, in accordance with section 4: Street Furniture, whilst maintaining smooth access.	N/A	N/A	N/A	

Design for Access 2

Laystall Street
1283/Da
26.03.20

OMI

Item	DFA2 Standard	Compliant with DFA2 N/A	Not Compliant with DFA2 but exceeds Part M Requirements	Not Compliant with DFA2	Notes
6	Ramps				
6.1.1	The existence and location of a ramp should be clearly indicated.	To be compliant			
6.1.2	The preferred surface width of a ramp is 1800mm minimum.		To be compliant		
6.1.3	Stepped ramps should not be used.	To be compliant			
6.1.4	A ramp into or within a building should have a gradient not exceeding 1 in 20 (5%).		To be compliant		
6.1.5	No individual flight of a ramp should have a going (or horizontal distance) of more than 10 metres, or a rise of more than 500mm.	To be compliant			
6.1.6	No series of ramps to a building should rise in total more than 2000mm. If the difference in height is more than 2000mm an alternative means of access, such as a lift, should be provided.	To be compliant			
6.1.7	The maximum surface cross-fall gradient of a ramp should be 1 in 50 (2%).	To be compliant			
6.1.8	Landings should be provided at the foot and head of a ramp and at intervals of no more than 10 metres.	To be compliant			
6.1.9	Landings should be at least the width of the ramp and a minimum of 1800mm x 1800mm, clear of any door swing or other obstruction.		To be compliant		

Design for Access 2

Laystall Street
1283/Da
26.03.20

OMI

Item	DFA2 Standard	Compliant with DFA2 N/A	Not Compliant with DFA2 but exceeds Part M Requirements	Not Compliant with DFA2	Notes
6.1.10	Handrails should be provided on both sides of all ramps. See section 9: Handrails.	To be compliant			
6.1.11	Surface materials should be smooth, easy to maintain and slip resistant*.	To be compliant			
6.1.12	The colour and luminance* of the ramp surface should contrast with that of the landings.	To be compliant			
6.1.13	Highlight the top and bottom of the ramp by use of colour and luminance* contrast.	To be compliant			
6.1.14	Where a ramp runs along the side of a building a kerbed upstand, at least 100mm high and differentiated by colour and luminance* contrast, should be provided on the open side.	To be compliant			
6.1.15	Good lighting should be provided, particularly at the top and bottom of the ramp. Avoid glare and cross-shadows, which can cause problems in detecting the top and bottom of a ramp and changes in gradient. See section 25: Lighting.	To be compliant			
6.1.16	See diagram 6 for details of ramps.				
7	Footbridges				
7.1.1	Access to footbridges should be by both ramps and steps whenever possible. See sections 6: Ramps and 8: External Steps.	N/A	N/A	N/A	

Design for Access 2

Laystall Street
1283/Da
26.03.20



Item	DFA2 Standard	Compliant with DFA2 N/A	Not Compliant with DFA2 but exceeds Part M Requirements	Not Compliant with DFA2	Notes
7.1.2	The ramps should not be less than 1800mm wide.	N/A	N/A	N/A	
7.1.3	Handrails should be provided to both sides of the steps and ramps. See section 9: Handrails.	N/A	N/A	N/A	
7.1.4	A central handrail should be provided when the width of steps or ramps exceeds 1800mm.	N/A	N/A	N/A	
8	External Steps				
8.1.1	External steps should be protected from bad weather.	To be compliant			
8.1.2	Ramped steps should not be used.	To be compliant			
8.1.3	Steps which 'feather' into ramps should not be used, as changes of level are not easily detected.	To be compliant			
8.1.4	Isolated single steps should not be used.	To be compliant			
8.1.5	The unobstructed width of a stepped access route should be 1800mm minimum.		To be compliant		
8.1.6	No flight of steps should rise more than 1200mm.	To be compliant			
8.1.7	The rise of each step should be as close as possible to, but not less than, 150mm, and each rise within a flight, or series of flights, should be uniform.	To be compliant			
8.1.8	The tread depth for steps should be 280mm. Each tread within a flight should be uniform and slip resistant.		To be compliant		

Design for Access 2

Laystall Street
1283/Da
26.03.20



Item	DFA2 Standard	Compliant with DFA2 N/A	Not Compliant with DFA2 but exceeds Part M Requirements	Not Compliant with DFA2	Notes
8.1.9	A step should not overlap the one below. If an overlap is unavoidable, the nosing should not project over the tread below by more than 25mm.	To be compliant			
8.1.10	All nosings should be distinguished by contrasting colour and luminance*.	To be compliant			
8.1.11	There should be a level unobstructed landing of minimum 1800mm x 1800mm, clear of any door swing, at the top and bottom of each flight of steps.		To be compliant		
8.1.12	A colour and luminance* contrasted corduroy tactile warning surface should be incorporated into the landings at the top and bottom of the steps.	To be compliant			
8.1.13	Do not use open risers or tapered treads, including spiral and helical stairs.	To be compliant			
8.1.14	Do not use open recesses under steps.	To be compliant			
8.1.15	A flight of steps that contains two or more risers should have a continuous handrail on both sides.	To be compliant			
8.1.16	If any stairway consists of two or more flights, separated by a landing or landings, each handrail should be continuous throughout the series of flights.		To be compliant		

Design for Access 2

Laystall Street
1283/Da
26.03.20



Item	DFA2 Standard	Compliant with DFA2 N/A	Not Compliant with DFA2 but exceeds Part M Requirements	Not Compliant with DFA2	Notes
8.1.17	Where the overall unobstructed width of steps is greater than 1800mm, an additional handrail or handrails should be provided to divide the flight into separate channels. No channel should have an unobstructed width of less than 1000mm or more than 1800mm. For further details about handrails, see section 9: Handrails.	To be compliant			
8.1.18	Steps should have strong, even lighting throughout. Avoid glare and cross-shadows, which can cause problems detecting changes in gradient.	To be compliant			
8.1.19	See diagram 8 for details of external steps.				
	1. All nosings should be identified by a contrasting colour and luminance 2. Provide corduroy hazard warning at top and bottom 3. Landings should be minimum 1800mm x 1800mm 4. Open risers should not be used		To be compliant		
9	Handrails (Ramps stairs and steps)				
9.1.1	Handrails should be provided to both sides of ramps, stairs and steps.	To be compliant			
9.1.2	A central handrail should be provided when the width of the ramp, stairs or steps exceeds 1800mm.	To be compliant			

Design for Access 2

Laystall Street
1283/Da
26.03.20



Item	DFA2 Standard	Compliant with DFA2 N/A	Not Compliant with DFA2 but exceeds Part M Requirements	Not Compliant with DFA2	Notes
9.1.3	Handrails should be fixed 1000mm above the surface of landings, 900mm above the surface of ramps and stair nosings, and not more than 100mm beyond the surface width of the ramp or stairs.	To be compliant			
9.1.4	Handrails should be continuous along ramps and stairs, and across landings and resting places.		To be compliant		
9.1.5	Handrails should extend 450mm beyond the start and finish of the ramp or stairs.	To be compliant			
9.1.6	Handrails should be turned down and terminated at the floor or ground level, or turned into the wall on the closed side of the ramp or stairs.	To be compliant			
9.1.7	Handrails should be smooth, free of studs and comfortable to grip. Handrails should not significantly retain heat or cold, for example, some metals or plastics would be inappropriate.	To be compliant			
9.1.8	Handrails should be finished to contrast in colour and luminance* with the surroundings.	To be compliant			
9.1.9	Handrails should be of a circular profile, 40mm - 45mm in diameter, or an oval profile of 50mm width.	To be compliant			
9.1.10	Handrails should be fixed 60mm - 75mm from any adjacent wall or surface.	To be compliant			
9.1.11	See diagram 9 for details of handrails.				
10	Doors				

Design for Access 2

Laystall Street
1283/Da
26.03.20



Item	DFA2 Standard	Compliant with DFA2 N/A	Not Compliant with DFA2 but exceeds Part M Requirements	Not Compliant with DFA2	Notes
10.1.1	A single leaf external door should have a minimum clear opening of 1000mm. The effective clear opening should be free of projections such as door furniture.	To be compliant			
10.1.2	Where there are double doors, at least one leaf should have a clear opening of not less than 1000mm. The effective clear opening should be free of projections such as door furniture.	To be compliant			
10.1.3	Power operated sliding doors should be provided when possible.	N/A	N/A	N/A	
10.1.4	Where there are revolving doors, there should also be an accessible side hung or sliding door, which is in regular use.	N/A	N/A	N/A	
10.1.5	All outward opening doors should be recessed.				
10.1.6	Protection from the weather should be provided at all non-powered entrance doors.	To be compliant			
10.1.7	Thresholds should be flush.	To be compliant			
10.1.8	See diagram 10.1 for details of external doors.	To be compliant			
10.2.0	Internal Doors				

Design for Access 2

Laystall Street
1283/Da
26.03.20

Item	DFA2 Standard	Compliant with DFA2 N/A	Not Compliant with DFA2 but exceeds Part M Requirements	Not Compliant with DFA2	Notes
10.2.1	A clear opening of at least 850mm should be provided. Doors to accessible toilets and to baby changing facilities should have a minimum clear opening of 900mm. The effective clear opening should be free of projections such as door furniture.	To be compliant			
10.2.2	At the leading edge of a door to an accessible area, a clear wall space of at least 450mm should be provided.			300mm to be provided	
10.2.3	See diagram 10.2 for details of internal doors.				
11	Design and fitting of doors and Entry System				
11.1.1	All main entrance doors and doors on circulation routes should be automatically activated with sensors.	To be compliant			
11.1.2	Where possible, doors should have a two-way swing.				Further detailed design required
11.1.3	Where possible, doors should be hung to the same side and open in the same direction in communal and circulation areas.				Further detailed design required
11.1.4	Doors should have a closing force not exceeding 20 Newtons*, that is, they should open and close with a light touch.	To be compliant			
11.1.5	Where doors form part of a building's security, fire protection or energy management systems, any 'hold open' devices should be fixed at the top rather than the bottom of the door.	To be compliant			
11.1.6	Door furniture should contrast with the door and the door itself should contrast with its surround.	To be compliant			

Design for Access 2

Laystall Street
1283/Da
26.03.20

OMI

Item	DFA2 Standard	Compliant with DFA2 N/A	Not Compliant with DFA2 but exceeds Part M Requirements	Not Compliant with DFA2	Notes
11.1.7	A kicking plate 250mm in height should be fitted to both sides of the door.	To be compliant			
11.1.8	A vision panel of minimum width 150mm should be fitted to all doors to provide a viewing area, except where privacy is needed (to toilets, changing rooms or counselling rooms for example). The base of the vision panel should be no higher than 500mm above floor level, and should extend to a minimum height of 1500mm. Beading around the vision panel should be flush with the door.	To be compliant			
11.1.9	Fully glazed doors should be highlighted with permanent contrasting strips or continuous features at heights of 1000mm and 1500mm above ground level. The leading edge of the door should be colour and luminance* contrasted.	To be compliant			
11.1.10	Glazing in doors should be safety glass. Where they are capable of being held open, glass doors should be protected by guarding.	To be compliant			
11.1.11	Where it is necessary to ensure that the door is closed, and the door is not self-closing, an additional horizontal handle fixed at 900mm above floor level will be required.	To be compliant			
11.1.12	Entry systems for doors, gates and barriers should be designed to be accessible, located horizontally at 900mm above floor level and, where possible, should incorporate additional vertical systems.	To be compliant			

Design for Access 2

Laystall Street
1283/Da
26.03.20

OMI

Item	DFA2 Standard	Compliant with DFA2 N/A	Not Compliant with DFA2 but exceeds Part M Requirements	Not Compliant with DFA2	Notes
11.1.13	All numbers and letters on entry systems should be identifiable by raised symbols. The depth of embossing should be at least 1.5mm.	To be compliant			
11.1.14	Include clear instructions, in minimum 14 point font size, on the use of the entry system.	To be compliant			
11.1.15	Entry systems must not rely only on audible intercoms and must incorporate inclusive entry procedures. New technologies and improved designs for providing accessible entry systems should be used.				Further detailed design required
11.1.16	Where possible, incorporate CCTV cameras at entry systems for security and information.				Further detailed design required
11.1.17	See diagram 11 for details of the design and fitting of doors.				
12	Door and Window furniture				
12.1.1	Door and window weight should be as low as possible for the purpose and location. Hinges should be of sufficient strength and positioning for leaf width.	To be compliant			
12.1.2	Where possible, use power-assisted activators for windows and doors which are operated by remote control, or design the structure to allow for powered control in the future. In all cases devices should 'fail safe' for manual operation in case of power failure.				Further detailed design required
12.1.3	Use fittings which are capable of being adapted to specific requirements.				Further detailed design required

Design for Access 2

Laystall Street
1283/Da
26.03.20



Item	DFA2 Standard	Compliant with DFA2 N/A	Not Compliant with DFA2 but exceeds Part M Requirements	Not Compliant with DFA2	Notes
12.1.4	All handles, levers, catches, keys and locks should be large enough to hold easily and not be circular in design. Keys and locks should, where possible, be useable within a 90 degree radius. The use of sliding bolts is not recommended.				Further detailed design required
12.1.5	Catches, handles and all projections should contrast in colour and luminance* with their surroundings.				Further detailed design required
12.1.6	Door fastening mechanisms should be of the lever type and fixed at a height not exceeding 900mm. Where a lock is needed for privacy (for example, for toilets, changing rooms or counselling rooms) this should be externally accessible, in case of an emergency, and should incorporate an 'engaged' indicator.				Further detailed design required
12.1.7	Locks should be fixed at 850mm above floor level.	Doors to be compliant			
12.1.8	Where horizontal handles are fitted these should be of minimum width 400mm and fixed 900mm above floor level.				Further detailed design required
12.1.9	Diagonal and vertical 'D' type handles should be fixed at 900mm from the centre of the handle to the floor.				Further detailed design required
12.1.10	Window fastenings should be located at 900mm above floor level.				Further detailed design required
12.1.11	Catches and locks should be smoothly free turning and maintained for low friction operation.	To be compliant			Further detailed design required

Design for Access 2

Laystall Street
1283/Da
26.03.20



Item	DFA2 Standard	Compliant with DFA2 N/A	Not Compliant with DFA2 but exceeds Part M Requirements	Not Compliant with DFA2	Notes
13	Reception and Refreshment Areas				
13.1.1	Signs should clearly identify the reception area from the entrance. See section 24: Signs and Wayfinding.	To be compliant			
13.1.2	If the reception area is not continuously staffed, suitable monitoring equipment should be provided, for example, CCTV systems, to alert the receptionist that assistance is required. Intercoms should not be used.				Subject to operators management strategy
13.1.3	Counters should be at 760mm above floor level, with knee recess spaces minimum 1500mm wide and 730mm high. An open shelf should be provided, above the counter, at 900mm. Counters should be 700mm wide and, where relevant, should provide a minimum depth of 400mm on the service side and 300mm on the customer side.	To be compliant			
13.1.4	Where glazed barriers are installed, there should be no obstructions to the view of the receptionist's face.	N/A	N/A	N/A	
13.1.5	Lighting should allow for lipreading and facial expressions. See also section 25: Lighting.	To be compliant			
13.1.6	Displays, leaflets, booklets and other literature should be available at a height of 900mm.	N/A	N/A	N/A	
13.1.7	Public address systems, where provided, should be supplemented by visual information systems with large print and colour contrasted to the background.	N/A	N/A	N/A	

Design for Access 2

Laystall Street
1283/Da
26.03.20



Item	DFA2 Standard	Compliant with DFA2 N/A	Not Compliant with DFA2 but exceeds Part M Requirements	Not Compliant with DFA2	Notes
13.1.8	Seats should be available at reception desks or counters, or a waiting area with seating should be provided, with sufficient space to manoeuvre. A mixture of seating options should be provided in a waiting area, for example, different heights, fixed or removable, and with or without arms. See section 5: Seating.				Further detailed design required
13.1.9	Information and menus on display should be in 18 point font minimum. Avoid words in capitals and italics and use of underlines. All information should use clear print guidelines, with additional alternative formats wherever possible. See Useful Sources of Information section.				Further detailed design required
13.1.10	An unobstructed space of 1800mm x 1800mm in front of the reception counter.	To be compliant			
13.1.11	Induction loops or other enhanced sound systems at the reception desk, with a sign clearly indicating their presence. See section 23: Communication Systems. Signs and/or badges should also be used to indicate whether interpreters are available.				Further detailed design required
13.1.12	Public telephones centred at 900mm above floor level, with the availability of text phones and hearing enhancement systems. They should be located where they can be used with privacy and their use will not cause an obstruction.	N/A	N/A	N/A	
13.1.13	Aisles at counters which are minimum 1800mm wide.	N/A	N/A	N/A	

Design for Access 2

Laystall Street
1283/Da
26.03.20

Item	DFA2 Standard	Compliant with DFA2 N/A	Not Compliant with DFA2 but exceeds Part M Requirements	Not Compliant with DFA2	Notes
13.1.14	Tables and chairs, which are not fixed to the floor, to enable people to choose where they sit. Appropriate seating should be provided. See Section 5: Seating.				Further detailed design required
13.1.15	An unobstructed route of at least 800mm between sets of chairs and tables.	To be compliant			
14.1.0	Lobbies				
14.1.1	Lobby doors should be positioned for easy, unobstructed approach and passage, and should ideally be two-way swing.				Further detailed design required
14.1.2	When a door into a lobby is open, there should be a minimum turning circle of 2000mm diameter remaining within the lobby.	To be compliant			
14.1.3	Mats should be flush with the floor surface. Avoid natural materials, which may cause traction.				Further detailed design required
14.1.4	Transitional lighting should be provided to reduce the contrast between the outside and the building interior. See section 25: Lighting.				Further detailed design required
14.1.5	Transitional schemes which contrast in colour and luminance* should be used to separate lobbies from other parts of the building.				Further detailed design required
14.1.6	See diagram 14.1 for alternative lobby arrangements.				
14.2.0	Corridors and Internal Spaces				

Design for Access 2

Laystall Street
1283/Da
26.03.20



Item	DFA2 Standard	Compliant with DFA2 N/A	Not Compliant with DFA2 but exceeds Part M Requirements	Not Compliant with DFA2	Notes
14.2.1	Corridors and internal spaces should be a minimum of 1800mm wide.			To be compliant with part M	
14.2.2	Keep corridors and communal spaces clear of obstructions. Notice boards and appliances such as fire extinguishers should be recessed.				Further detailed design required
14.2.3	Use slip resistant* floor covering for corridors and communal spaces. See section 22: Surfaces and Finishes.				Further detailed design required
14.2.4	Provide unobstructed turning space of minimum 2000mm diameter at corners.			To be compliant with part M	
14.2.5	Provide unobstructed space for approaching and opening doors.	To be compliant			
14.2.6	Provide recessed seating in all corridors longer than 50 metres.	N/A	N/A	N/A	
14.2.7	There should be a contrast, in colour and luminance,* between walls and ceilings, and between walls and floors.	To be compliant			
14.2.8	See diagram 14.2 for details of corridors and internal spaces.				
15	Internal Stairs				
15.1.1	Flights of stairs should have a maximum of 12 risers per flight and a maximum rise of 1800mm.	To be compliant in new build.			Further detailed design required
15.1.2	The clear width of stairs should be 1000mm minimum and 1800mm maximum.	To be compliant			

Design for Access 2

Laystall Street
1283/Da
26.03.20

OMI

Item	DFA2 Standard	Compliant with DFA2 N/A	Not Compliant with DFA2 but exceeds Part M Requirements	Not Compliant with DFA2	Notes
15.1.3	The depth of tread should be 280mm.			Tread depth to be 250mm	
15.1.4	Risers should be as close as possible to, but no less than, 150mm.	To be compliant		Riser heights in listed building to vary	
15.1.5	Do not use open risers, tapered treads or helical or spiral* stairs.	To be compliant			
15.1.6	Avoid open recesses under stairs.	To be compliant			
15.1.7	There should be a level unobstructed landing, 1800mm x 1800mm minimum, at the top and bottom of each flight, clear of any door swing.			Stairs are designed to part K	
15.1.8	A colour and luminance* contrast should be incorporated into the landings at the top and bottom of the stairs.	To be compliant			
15.1.9	A step should not overlap the one below.	To be compliant			
15.1.10	The leading edge of all steps should be distinguished by colour and luminance* contrast.	To be compliant			
15.1.11	Treads should be constructed of opaque non-reflective materials.	To be compliant			
15.1.12	Stairs should have strong, even lighting throughout.	To be compliant			Further detailed design required
15.1.13	For guidance on handrails see section 9.	To be compliant			
	See diagram 15 for details of internal stairs.				
15.1.14	1. Maximum of 12 risers per flight 2. Risers should be as close as possible to 150mm 3. Open risers should not be used				

Design for Access 2

Laystall Street
1283/Da
26.03.20

OMI

Item	DFA2 Standard	Compliant with DFA2 N/A	Not Compliant with DFA2 but exceeds Part M Requirements	Not Compliant with DFA2	Notes
16.1.0	Passenger Lifts				
16.1.1	Internal dimensions should be minimum 2000mm wide x 1400mm deep x 2000mm high with maximum 15mm finishes.		Minimum car lift on Part M is 1100x 1400. proposed lifts are 13 person 1400x1600		
16.1.2	For specific constrained circumstances, for example, in refurbishment schemes, minimum internal dimensions of 1100mm wide x 1400mm deep x 2000mm high would be sufficient.		Minimum car lift on Part M is 1100x 1400. proposed lifts are 13 person 1400x1600		
16.1.3	There should be an unobstructed area in front of the lift entrance of 1800mm x 1800mm.		1500x1500 as a minimum to comply with Part M		
16.1.4	The area in front of and to the side of the lift should be kept clear of obstructions to allow access to the controls.	To be compliant			
16.1.5	Seating should be provided outside and near to the lift.			No Seating due to fire regulations	
16.1.6	Illuminated and audible systems to identify floor levels should be positioned inside and outside the lift.	To be compliant			
16.1.7	Internal handrails should be provided 900mm above floor level.	To be compliant			
16.1.8	Where a lift has a single door, a mirror, with minimum dimensions of 1000mm wide x 1000mm high, should be positioned inside the lift on the wall opposite the door at no higher than 900mm above floor level.	To be compliant			
16.1.9	Doors should include a presence sensor and, where possible, have a minimum door opening time of 20 seconds.				Further detailed design required

Design for Access 2

Laystall Street
1283/Da
26.03.20



Item	DFA2 Standard	Compliant with DFA2 N/A	Not Compliant with DFA2 but exceeds Part M Requirements	Not Compliant with DFA2	Notes
16.1.10	The door to the lift should provide a clear opening width of minimum 900mm. Except where space is constrained in refurbishment schemes lifts should use single or opposite doors only.	To be compliant			Further detailed design required
16.1.11	Call buttons outside the lift should preferably be on the right side of the door, should be colour and luminance* contrasted with the surround, should have embossed symbols, and should be positioned no higher than 900mm.	To be compliant			Further detailed design required
16.1.12	Control buttons within the lift should be horizontal, centred at a height of 900mm above floor level, centrally placed on the lift walls, and preferably on both sides of the compartment. There should also be a standard vertical control panel near to the door.	To be compliant			Further detailed design required
16.1.13	All controls should be identifiable with raised and Braille symbols. The depth of embossing should be at least 1.5mm. The controls should be in a contrasting colour and luminance* on non-reflective panels.	To be compliant			Further detailed design required
16.1.14	Lifts should have emergency communication systems, located no higher than 900mm above floor level, which provide audible and visual signals, explain how to make emergency calls and indicate, audibly and visually, when an emergency call has been received.	To be compliant			Further detailed design required
16.1.15	Flooring, wall and ceiling finishes should be opaque, non-reflective and slip resistant*.	To be compliant			Further detailed design required

Design for Access 2

Laystall Street
1283/Da
26.03.20

OMI

Item	DFA2 Standard	Compliant with DFA2 N/A	Not Compliant with DFA2 but exceeds Part M Requirements	Not Compliant with DFA2	Notes
16.1.16	Lighting within lifts should avoid glare, reflection, shadows or pools of light.	To be compliant			Further detailed design required
16.1.17	At least one lift in each area of the building should be designed as an evacuation lift, with an independent power supply, and should be clearly indicated for this use.				Further detailed design required
16.1.18	Signage indicating the floor level should be provided on the wall opposite the lift doors on each landing.	To be compliant			Further detailed design required
16.1.19	See diagram 16 for details of passenger lifts.				
16.2.0	Platform Lifts				
16.2.1	Internal dimensions should be minimum 1100mm wide x 1400mm deep.	N/A	N/A	N/A	
16.2.2	There should be an unobstructed area in front of the lift entrance of 1800mm x 1800mm.	N/A	N/A	N/A	
16.2.3	The area in front of and to the side of the lift should be kept clear of obstructions to allow access to the controls.	N/A	N/A	N/A	
16.2.4	The door to the lift should provide a clear opening width of minimum 900mm.	N/A	N/A	N/A	
16.2.5	The floor to the lift car should be level with the unobstructed area in front of the lift.	N/A	N/A	N/A	
16.2.6	The lift car should be enclosed.	N/A	N/A	N/A	
16.2.7	Flooring, wall and ceiling finishes should be opaque, non-reflective and slip-resistant.	N/A	N/A	N/A	

Design for Access 2

Laystall Street
1283/Da
26.03.20



Item	DFA2 Standard	Compliant with DFA2 N/A	Not Compliant with DFA2 but exceeds Part M Requirements	Not Compliant with DFA2	Notes
16.2.8	The controls should be capable of use independently by the user and set no higher than 900mm above floor level.	N/A	N/A	N/A	
16.2.9	The doors should not require the simultaneous operation of two mechanisms to open them.	N/A	N/A	N/A	
16.2.10	The door opening and closing system should be automatic.	N/A	N/A	N/A	
16.2.11	The lift should incorporate audible and visual alarm and emergency systems.	N/A	N/A	N/A	
16.2.12	Where vision panels are fitted the base of the vision panel should be no higher than 500mm above floor level, and should extend to a minimum height of 1500mm.	N/A	N/A	N/A	
16.2.13	Where vision panels are fitted the base of the vision panel should be no higher than 500mm above floor level, and should extend to a minimum height of 1500mm.	N/A	N/A	N/A	
17	Toilets				
17.1.1	At least one separate unisex, accessible toilet facility should be provided for each suite of male/female toilets on each floor, with a maximum travel distance of 40 metres. Where more than one accessible toilet is provided, these should allow for transfer from alternative sides.	To be compliant			
17.1.2	Suites of male/female toilets should include at least one larger sized cubicle, minimum 1200mm wide, with grab rails.	N/A	N/A	N/A	

Design for Access 2

Laystall Street
1283/Da
26.03.20



Item	DFA2 Standard	Compliant with DFA2 N/A	Not Compliant with DFA2 but exceeds Part M Requirements	Not Compliant with DFA2	Notes
17.1.3	A separate unisex accessible baby changing area should also be provided. See section 18: Baby Changing Facilities.				Further detailed design required
17.1.4	Where a WC compartment is approached through a lobby the dimensions of the lobby should be as described in section 14.1 Lobbies.				Further detailed design required
17.1.5	The WC compartment door should open outwards and provide a clear opening of at least 900mm and should include a horizontal handle. See section 12: Door and Window Furniture.	To be compliant			Further detailed design required
17.1.6	For privacy, avoid the WC door opening directly on to a public and/or circulation area.	To be compliant			Further detailed design required
17.1.7	The flooring should be of slip resistant* material.	To be compliant			Further detailed design required
17.1.8	The door fastening mechanism should be of the lever type with an integral lock, which is externally accessible in case of an emergency. It should incorporate an 'engaged' indicator.	To be compliant			Further detailed design required
17.1.9	The WC compartment should be minimum 2000mm x 2000mm. This will provide options for positioning the WC pan.				Further detailed design required
17.1.10	Where there is only one toilet in a building the compartment should be increased to 2000mm x 2200mm.	To be compliant			

Design for Access 2

Laystall Street
1283/Da
26.03.20



Item	DFA2 Standard	Compliant with DFA2 N/A	Not Compliant with DFA2 but exceeds Part M Requirements	Not Compliant with DFA2	Notes
17.1.11	A clear unobstructed approach should be provided to the WC. The mid-point of the pan should be located at 600mm from the adjoining wall or boxed-in pipes.				Further detailed design required
17.1.12	Generally the height of the WC pan should be 480mm and the front of the pan should be 750mm from the rear wall. In suites of toilets, different levels of pans, including at a lower height, should be considered.				Further detailed design required
17.1.13	Sensor controlled flushing systems are preferred, particularly where there is transfer space on both sides. Alternatively, a close coupled cistern should be installed with a large, dimple-type flushing handle on the transfer side, at a height of 800mm.				Further detailed design required
17.1.14	A counterbalanced single bar hinged support rail with an integral toilet roll holder should be provided. All support fixings should be designed to withstand an ultimate load of 15kN (kiloNewtons)*.			To be compliant with Doc M	Further detailed design required
17.1.15	A small wash-hand basin should be installed at a height of 740mm. This should be positioned so that it can be reached by a person seated on the WC and should allow for a knee clearance of 450mm minimum. In no case should the wash-hand basin overlap the WC pan.			To be compliant with Doc M	Further detailed design required
17.1.16	Where there is only one toilet in a building, an additional wash-hand basin should be installed at a height of 800mm.	N/A	N/A	N/A	

Design for Access 2

Laystall Street
1283/Da
26.03.20

Item	DFA2 Standard	Compliant with DFA2 N/A	Not Compliant with DFA2 but exceeds Part M Requirements	Not Compliant with DFA2	Notes
17.1.17	A thermostatically controlled mixer tap with a lever handle should be provided, with the tap fixed on the side of the basin nearest to the WC. Sensor taps can cause difficulty.				Further detailed design required
17.1.18	A soap dispenser should be sited over the wash-hand basin and should be operable with minimum pressure.				Further detailed design required
17.1.19	A hot air hand drier and towel dispenser should be installed adjacent to the wash-hand basin at a height of 800mm above floor level.				Further detailed design required
17.1.20	Small toilet roll dispensers are preferred and should be fitted at 450mm above floor level. If provided, larger dispensers should be 150mm above the grab rail.				Further detailed design required
17.1.21	Coat hooks should be fitted at 1200mm and 1800mm above floor level.				Further detailed design required
17.1.22	A full length safety mirror should be fitted, set at maximum 300mm above floor level.				Further detailed design required
17.1.23	A small shelf should be fitted, set at 740mm above floor level.				Further detailed design required
17.1.24	An emergency pull cord should be installed extending to 100mm above floor level on the transfer side of the WC. The cord should be fitted with several pull rings at different heights. Both the cord and the rings should be red coloured. The reset switch should be operable from the toilet seat.				Further detailed design required
17.1.25	A fire alarm should be installed which has visual and audible signals.	To be compliant			

Design for Access 2

Laystall Street
1283/Da
26.03.20

OMI

Item	DFA2 Standard	Compliant with DFA2 N/A	Not Compliant with DFA2 but exceeds Part M Requirements	Not Compliant with DFA2	Notes
17.1.26	An emergency assistance system should be installed which indicates, audibly and visually, when an emergency call has been received, with visual and audible signals which are different from the fire alarm.	To be compliant			
17.1.27	Lighting operated by sensors is preferred. Light switches should be installed no higher than 900mm above floor level. Where the light is operated by a pull cord it should be white coloured, and its end should be 450mm above the floor. Pull rings should be installed at the end and at 900mm above floor level.				Further detailed design required
17.1.28	All fittings and the door should contrast in colour and luminance* with the walls and floor.				Further detailed design required
17.1.29	See diagram 17 for layout of toilets.				
18	Baby Changing Facilities				
18.1.1	Baby changing areas should not be placed in a unisex accessible toilet but should be in a separate space, to ensure that an accessible unisex toilet remains available to disabled people.				Accessible toilets allowed for on all floors. 1 will be allocated for baby changing.
18.1.2	The area for a baby changing facility should be a minimum size of 2000mm x 2000mm.	To be compliant			
18.1.3	The door should have a 900mm clear opening and should open outwards. It should include a horizontal or diagonal handle. See section 12: Door and Window Furniture.	To be compliant			

Design for Access 2

Laystall Street
1283/Da
26.03.20

OMI

Item	DFA2 Standard	Compliant with DFA2 N/A	Not Compliant with DFA2 but exceeds Part M Requirements	Not Compliant with DFA2	Notes
18.1.4	The door fastening mechanism should be of the lever type with an integral lock which is externally accessible in case of an emergency. It should incorporate an 'engaged' indicator.	To be compliant			
18.1.5	All fittings and the door should contrast in colour and luminance* with the walls and floor.	To be compliant			
18.1.6	The changing table should be a maximum of 500mm deep and be permanently fixed at 750mm above floor level.				Further detailed design required
18.1.7	The table should be set against a wall, and should either be purpose-designed or have a raised edge and comply with all relevant safety standards.				Further detailed design required
18.1.8	A wash hand basin and hand dryer or towel holder should be installed at a height of 740mm, and a full length mirror set at maximum 300mm above floor level.				Further detailed design required
18.1.9	A chair should be provided for use if required.				Further detailed design required
18.1.10	Where vending machines are installed the controls should be no more than 900mm above floor level.				Further detailed design required
18.1.11	Nappy bins and other facilities should be recessed if possible, and should not obstruct circulation space.				Further detailed design required
18.1.12	Lighting should be even throughout with no spotlights used.				Further detailed design required
18.1.13	See diagram 18 for layout of baby changing facilities.				
19	Showers and bathrooms				

Design for Access 2

Laystall Street
1283/Da
26.03.20



Item	DFA2 Standard	Compliant with DFA2 N/A	Not Compliant with DFA2 but exceeds Part M Requirements	Not Compliant with DFA2	Notes
19.1.1	A shower room should have a minimum floor dimension of 2500mm x 2500mm and should include a WC and a wash hand basin. See diagram 19a for layout of a shower room.				No public shower or bathrooms
19.1.2	A bathroom should have a minimum floor dimension of 2500mm x 2700mm and should include a WC and a wash hand basin. See diagram 19b for layout of a bathroom.	N/A	N/A	N/A	
19.1.3	Showers and bathrooms should be located on obstruction-free accessible routes.	N/A	N/A	N/A	
19.1.4	Heating should be provided but should be designed and located so as not to cause an obstruction or hazard.	N/A	N/A	N/A	
19.1.5	The door should open outwards and be self-closing.	N/A	N/A	N/A	
19.1.6	The door fastening mechanism should be of the lever type, with an integral lock which is externally accessible in case of an emergency. It should incorporate an 'engaged' indicator.	N/A	N/A	N/A	
19.1.7	The floor should be slip resistant* with level access.	N/A	N/A	N/A	
19.1.8	An emergency pull cord extending to 100mm above floor level should be provided on the transfer side, near to the shower or bath. The cord should be fitted with several pull rings at different heights. Both the cord and the ring should be red coloured. A continuous electronic emergency touch strip around the base of the walls could be considered.	N/A	N/A	N/A	

Design for Access 2

Laystall Street
1283/Da
26.03.20



Item	DFA2 Standard	Compliant with DFA2 N/A	Not Compliant with DFA2 but exceeds Part M Requirements	Not Compliant with DFA2	Notes
19.1.10	A full length safety mirror should be provided. This should be set a maximum of 300mm from floor level.	N/A	N/A	N/A	
19.1.11	Coat hooks should be provided at heights of 900mm, 1200mm and 1800mm above floor level.	N/A	N/A	N/A	
19.1.12	A towel rail should be positioned at a height of 900mm above floor level.	N/A	N/A	N/A	
19.1.13	All fittings and the door should contrast in colour and luminance* with the walls and floor.	N/A	N/A	N/A	
19.1.14	A wet area with a level permeable surface.	N/A	N/A	N/A	
19.1.15	An easily adjustable shower seat in the wet area at a height of 480mm above floor level. It should be minimum 400mm in depth and self draining.	N/A	N/A	N/A	
19.1.16	A fold-up seat in the dry area at a height of 480mm above floor level, with a minimum depth of 400mm.	N/A	N/A	N/A	
19.1.17	An easily adjustable portable shower spray attached to a flexible hose with a rise and fall fitting to ensure that the shower spray can be easily adjusted to different positions.	N/A	N/A	N/A	
19.1.18	A thermostatically controlled shower stream.	N/A	N/A	N/A	
19.1.19	Lever controls set at 900mm above floor level.	N/A	N/A	N/A	
19.1.20	Two counterbalanced drop down rails fitted at 600mm above floor level on both sides of the shower seat, and 320mm from the centre line of the seat.	N/A	N/A	N/A	

Design for Access 2

Laystall Street
1283/Da
26.03.20

OMI

Item	DFA2 Standard	Compliant with DFA2 N/A	Not Compliant with DFA2 but exceeds Part M Requirements	Not Compliant with DFA2	Notes
19.1.21	Two vertical grab rails positioned just outside the drop down rails at 750mm above floor level.	N/A	N/A	N/A	
19.1.22	Recessed soap holders fitted at 650mm and 900mm above floor level.	N/A	N/A	N/A	
19.1.23	A shelf for toiletries fitted at 650mm which can be reached from the shower seat.	N/A	N/A	N/A	
19.1.24	A shower curtain which surrounds the seat and rails, which is operable from the shower seat.	N/A	N/A	N/A	
19.1.25	See diagram 19a for layout of a shower room.	N/A	N/A	N/A	
19.1.26	A bath board available for use.	N/A	N/A	N/A	
19.1.27	A thermostatically controlled mixer tap with a lever handle.	N/A	N/A	N/A	
19.1.28	See diagram 19b for layout of a bathroom.				
20	Kitchens				
20.1.1	Provide a clear unobstructed circulation space of minimum 2000mm x 2000mm.				Further detailed design required
20.1.2	All ventilation controls should be at 900mm above floor level.				Further detailed design required
20.1.3	Provide a separate oven and hob at a height of 760mm.				Further detailed design required
20.1.4	Position controls at the front of appliances.				Further detailed design required
20.1.5	Provide dual height worktops, at 760mm and 900mm, with knee recess spaces 900mm wide and 730mm high.				Further detailed design required

Design for Access 2

Laystall Street
1283/Da
26.03.20



Item	DFA2 Standard	Compliant with DFA2 N/A	Not Compliant with DFA2 but exceeds Part M Requirements	Not Compliant with DFA2	Notes
20.1.6	Provide knee recess spaces below sink, hob and preparation areas. Knee recess spaces should also be considered beside floor mounted storage units, fridges, ovens, etc.				Further detailed design required
20.1.7	Worktops should be a maximum of 600mm deep.				Further detailed design required
20.1.8	Inset sink bowls should be 120mm to 140mm in depth and be designed to maximise the knee recess area.				Further detailed design required
20.1.9	Sinks and hobs should be insulated underneath.				Further detailed design required
20.1.10	Maximise storage space at ground level. Consider mobile storage units. Avoid wall mounted cupboards where possible.				Further detailed design required
20.1.11	All worktops should have rounded edges.				Further detailed design required
20.1.12	All drawers and cupboards should have full-length 'D' type handles.				Further detailed design required
20.1.13	All fittings and the door should contrast in colour and luminance* with the walls and floor.				Further detailed design required
21.1.0	Dwellings				
21.1.1	The design of the external areas should meet the relevant guidance in sections 1 to 9 of this manual.				See relevant sections
21.1.2	At least one accessible parking space should be provided for each dwelling. The design of parking spaces should meet the relevant guidance in section 1: Car Parking.	N/A	N/A	N/A	

Design for Access 2

Laystall Street
1283/Da
26.03.20

OMI

Item	DFA2 Standard	Compliant with DFA2 N/A	Not Compliant with DFA2 but exceeds Part M Requirements	Not Compliant with DFA2	Notes
21.1.3	A level access route of minimum 1800mm wide should be provided to the principal entrance of each dwelling. Level access routes should also be provided to bin stores, garages and other facilities. The design of access routes should meet the guidance in section 3: Footways, Pathways and Access Routes.				
21.1.4	For flats and sheltered accommodation and for communal dwellings, the design of doors, lobbies, corridors and internal spaces should meet the guidance in sections 10.1: External Doors and 14: Lobbies, Corridors and Internal Spaces.				See section 10 & 14
21.1.5	In flats and sheltered accommodation, facilities for parking and charging power wheelchairs and scooters should be provided close to function and meeting rooms and communal areas.			None provided	
21.1.6	Lift access should be provided to each dwelling above ground level. The design of lifts should meet the guidance in section 16: Lifts.	To be compliant			
21.1.7	For single family dwellings, external doors should have a minimum clear opening of 850mm. The effective clear opening should be free of projections, such as door furniture.	To be compliant			
21.1.8	All dwellings that have access to an outside area, for example a garden or balcony, should provide level or ramped access to this area. See section 6: Ramps.	To be compliant			
21.1.9	Where the accommodation is split level, provision should be made for visitors to access the main living areas.	N/A	N/A	N/A	

Design for Access 2

Laystall Street
1283/Da
26.03.20

OMI

Item	DFA2 Standard	Compliant with DFA2 N/A	Not Compliant with DFA2 but exceeds Part M Requirements	Not Compliant with DFA2	Notes
21.1.10	For single family dwellings, the minimum clear width of halls and lobbies should be 1200mm and all rooms downstairs should preferably be accessed from the hall or lobby. If there are passageways, the minimum clear width should be 900mm. The design must accommodate circulation space.	To be compliant			
21.1.11	An accessible WC should be provided at entrance level within each dwelling. An accessible WC should have minimum dimensions of 1500mm x 2000mm and should include a wash-hand basin installed at maximum height of 740mm, and a close coupled cistern fitted with a large dimple-type flushing handle at a height of 800mm on the transfer side.	To be compliant			
21.1.12	Handles and locks, including those for garages and bin stores, and other controls and door and window furniture should be easy to operate by disabled people, and positioned so as to be accessible. Their design should meet the guidance in section 12: Door and Window Furniture.				Further detailed design required
21.1.13	Switches, sockets and service controls for heating, lighting, radio, television, telephones and computers, etc., should be centred at 900mm above floor level.				Further detailed design required
21.02.0	Provision For Adaption				
21.02.1	A suitable, safe location should be identified within each dwelling for parking and charging a power wheelchair or scooter.	N/A	N/A	N/A	

Design for Access 2

Laystall Street
1283/Da
26.03.20

OMI

Item	DFA2 Standard	Compliant with DFA2 N/A	Not Compliant with DFA2 but exceeds Part M Requirements	Not Compliant with DFA2	Notes
21.02.2	The design of all new dwellings that are on more than one level should incorporate provision for a future stair lift, and also a suitably identified space of minimum 1400mm x 1100mm for the future installation of a house lift (through-the-floor lift) from the ground to the first floor. The proposed provision must satisfy all normal Building Regulations requirements.	N/A	N/A	N/A	
21.02.3	At least one accessible bedroom should be provided in each dwelling, of minimum dimensions 4000mm x 4000mm.		All bathrooms will meet Part M 4(1) as a minimum		
21.02.4	Where a development incorporates dwellings with three or more bedrooms, a proportion of these should have a second bedroom of minimum dimensions 3000mm x 3000mm.	N/A	N/A	N/A	
21.02.5	Where possible, ensuite facilities should be provided, of minimum dimensions 2000mm x 2000mm, and should include a WC, a wash hand basin and a shower.		All bathrooms will meet Part M 4(1) as a minimum		
21.02.6	Where only one bathroom is provided it should have minimum dimensions of 2700mm x 2500mm to allow for the provision of a WC, a wash hand basin a bath and a shower. See diagram 19b for suggested layout of a bathroom.		All bathrooms will meet Part M 4(1) as a minimum		
21.02.7	Walls in bathrooms, showers and toilets should be constructed to take adaptations such as grab rails.				Further detailed design required
21.02.8	Ceilings, walls and floors in bedrooms, toilets, showers and bathrooms should be constructed to take adaptations such as track hoists.				Further detailed design required

Design for Access 2

Laystall Street
1283/Da
26.03.20

OMI

Item	DFA2 Standard	Compliant with DFA2 N/A	Not Compliant with DFA2 but exceeds Part M Requirements	Not Compliant with DFA2	Notes
21.02.9	Circulation space of minimum 1800mm x 1800mm should be available in kitchens after fitting-out.				Further detailed design required
21.02.10	On each floor there should be no stepped changes of level.	To be compliant			
21.02.11	Internal doors should have a minimum clear opening of 800mm. The effective clear opening should be clear of projections. Double doors may be fitted, if preferred.	To be compliant			
21.02.12	Window sills should be no more than 900mm above floor level. Any glazing less than 900mm above floor level should be safety glass.	To be compliant			
21.02.13	The width of internal stairs should be minimum 900mm.	N/A	N/A	N/A	
21.02.14	Do not use open risers or open recesses under stairs.	N/A	N/A	N/A	
21.02.15	A step should not overlap the one below.	N/A	N/A	N/A	
21.02.16	There should be a continuous handrail on both sides of the stairs and on landings. See section 9: Handrails.	N/A	N/A	N/A	
21.02.17	For new-build or complete refurbishment, the use of residential sprinklers should be considered.	To be compliant			
22	Surfaces and Finishes				
22.1.1	Surfaces and finishes should be durable, even and slip resistant*.				Further detailed design required
22.1.2	Surfaces that are highly polished and reflective should be avoided.				Further detailed design required

Design for Access 2

Laystall Street
1283/Da
26.03.20



Item	DFA2 Standard	Compliant with DFA2 N/A	Not Compliant with DFA2 but exceeds Part M Requirements	Not Compliant with DFA2	Notes
22.1.3	Finishes should be combined to ensure that the overall acoustic performance avoids unnecessary reflection, reverberation, echo or excessive acoustic absorbency. See section 26: Sound.				Further detailed design required
22.1.4	All floor coverings should be firmly fixed.				Further detailed design required
22.1.5	Floor coverings should avoid the use of deep pile carpets and natural materials, which create traction.				Further detailed design required
22.1.6	Door mats should have a feathered or graded edge or a shallow well. Where a well is used there should be a non-compressible mat and the finished surface should be level with the floor.				Further detailed design required
22.1.7	Designs for carpets, walls and other fittings should not use distinctive patterns, simulated steps or stripes, which can be disorientating.				Further detailed design required
22.1.8	Colour and or texture coded circulation schemes should be used to identify specific areas and routes, but should be limited to 5 overall themes.				Further detailed design required
22.1.9	There should be a contrast, in colour and luminance,* between walls and ceilings and between walls and floors.				Further detailed design required
22.1.10	Glazed areas should be identified with permanent contrasting strips or continuous features at heights of 1000mm and 1500mm above ground level. These should not obscure communication.				Further detailed design required
22.1.11	All fixtures, fittings and controls should be identified by texture and colour and luminance* contrast.				Further detailed design required

Design for Access 2

Laystall Street
1283/Da
26.03.20



Item	DFA2 Standard	Compliant with DFA2 N/A	Not Compliant with DFA2 but exceeds Part M Requirements	Not Compliant with DFA2	Notes
23	Communication Systems				
23.1.1	Where permanent or temporary induction loops* and other enhancement systems are likely to be required, the design of the structure should avoid interference from other electrical systems and electro-magnetic fields, and the use of structural metalwork and other potential structural interference, such as suspended ceiling grids.				Further detailed design required
23.1.2	All public meeting and interview rooms should have an induction loop or other hearing enhancement system permanently fitted and regularly maintained.				Further detailed design required
23.1.3	In auditoriums and conference rooms, and where extra information is provided through audio description, infrared systems* and induction loops should both be available.	N/A	N/A	N/A	
23.1.4	Where confidentiality is an issue, specialist advice should be taken about the appropriate induction loop or other hearing enhancement system, to avoid leakage of information into other rooms and corridors.				Further detailed design required
23.1.5	All communication systems and their controls should be visually identified and clearly indicated to public users.				Further detailed design required

Design for Access 2

Laystall Street
1283/Da
26.03.20



Item	DFA2 Standard	Compliant with DFA2 N/A	Not Compliant with DFA2 but exceeds Part M Requirements	Not Compliant with DFA2	Notes
23.1.6	Visual alarm systems should be installed in all public areas to supplement audible alarm systems. An alarm button with a visual display should also be installed in lifts, toilets and other places requiring emergency communication.				Further detailed design required
23.1.7	Security, emergency and alarm systems should be linked into hearing enhancement systems. Pagers should also be used where possible.				Further detailed design required
23.1.8	All communication equipment should be installed by trained staff.				Further detailed design required
23.1.9	Regular testing of communication equipment, by trained staff, should be included in maintenance procedures.				Further detailed design required
23.1.10	Space should be made available to allow for clear vision of interpreters.				Further detailed design required
24	Signs and Wayfinding				
24.1.1	Facilities for disabled people should be clearly and consistently signposted at ramps, car-parking spaces, entrances, toilets, baby changing facilities, lifts, reception areas, counters, and accessible routes externally and internally.	To be compliant			
24.1.2	Floor plans, where provided, should be located at the main entrance to a building, or in a designated place on the floor of entry, at a maximum height of 900mm from floor level. Floor plans should ideally be slightly inclined from the horizontal, in line with the building's orientation, and with 'You are here' indicated.				Further detailed design required
24.1.3	Signage should be well lit.				Further detailed design required

Design for Access 2

Laystall Street
1283/Da
26.03.20



Item	DFA2 Standard	Compliant with DFA2 N/A	Not Compliant with DFA2 but exceeds Part M Requirements	Not Compliant with DFA2	Notes
24.1.4	Materials for signs should have a non-reflective surface.	To be compliant			Further detailed design required
24.1.5	Signage, and symbols within signs, should be colour and luminance contrasted* with their background.	To be compliant			Further detailed design required
24.1.6	Text on signs should be clear and simple using sans-serif fonts. Words should not be made up of capital letters only.	To be compliant			Further detailed design required
24.1.7	Avoid long lists of items on signs. Shorter columns are easier to read and remember.				Further detailed design required
24.1.8	Floor plans, where provided, should be located at the main entrance to a building, or in a designated place on the floor of entry, at a maximum height of 900mm from floor level. Floor plans should ideally be slightly inclined from the horizontal, in line with the building's orientation, and with 'You are here' indicated.				Further detailed design required
24.1.9	Signage indicating rooms should be placed on the wall next to the door on the door handle side. A small embossed arrow should be used to indicate direction. Where Braille is used, it should be located directly below the text, and arrow if used, and justified to the left.				Further detailed design required
24.1.10	Where raised numbers, letters, Braille and symbols are used, these should be located at 900mm from floor level. The depth of embossing should be at least 1.5mm.				Further detailed design required

Design for Access 2

Laystall Street
1283/Da
26.03.20

Item	DFA2 Standard	Compliant with DFA2 N/A	Not Compliant with DFA2 but exceeds Part M Requirements	Not Compliant with DFA2	Notes
24.1.11	The design of distinct functional areas and routes in a building should be clearly identified through colour, signage and in other ways, to assist orientation within a building.				Further detailed design required
24.1.12	All doors should be colour and luminance contrasted* with the surrounding walls.	To be compliant			Further detailed design required
25	Lighting				
25.1.1	Entrance areas, foyers and lobbies should be used as transition areas to enable people to adjust to changes in lighting levels from inside to outside, and outside to inside, and to lighting levels within different parts of a building. In public buildings, electronic monitoring of lighting levels inside and outside should be considered.	To be compliant			Further detailed design required
25.1.2	Use light colours for walls and ceilings as these help to reflect and diffuse the light. Gloss finishes should not be used on walls or ceilings.	To be compliant			Further detailed design required
25.1.3	Lights should be positioned where they do not cause glare, reflection, shadows or pools of light and dark.	To be compliant			Further detailed design required
25.1.4	Uplighters should not be used at street or floor level but should be positioned above 2000mm from ground or floor level.				Further detailed design required
25.1.5	Light fittings in circulation and work areas should be selected to have a non-directional even light spread.				Further detailed design required

Design for Access 2

Laystall Street
1283/Da
26.03.20

Item	DFA2 Standard	Compliant with DFA2 N/A	Not Compliant with DFA2 but exceeds Part M Requirements	Not Compliant with DFA2	Notes
25.1.6	Fluorescent light fittings should be screened, maintained to avoid flicker, and located to avoid interference with hearing enhancement systems.				Further detailed design required
25.1.7	All lighting systems should be compatible with hearing enhancement and radio frequency systems.				Further detailed design required
25.1.8	Where possible the lamps should have good colour rendering properties, for example, use 'daylight' lamps.	To be compliant			Further detailed design required
26	Sound				
26.1.1	Buildings should be designed to reduce background noise, reverberation and echoes.	To be compliant			Further detailed design required
26.1.2	Where public address systems are used wall, floor and ceiling surfaces should be sufficiently acoustically absorbent to limit extended reverberation, or purpose-made absorbers should be installed.				Further detailed design required
26.1.3	All cables and other electrical equipment should be designed, screened and located to avoid interference with personal hearing aids and hearing enhancement systems.	To be compliant			Further detailed design required
26.1.4	Background noise should be kept to a minimum, for example, avoiding the use of music in public information areas.				Further detailed design required
26.1.5	Equipment and fittings should be selected and maintained to minimise background noise.	To be compliant			Further detailed design required

Design for Access 2

Laystall Street
1283/Da
26.03.20



Item	DFA2 Standard	Compliant with DFA2 N/A	Not Compliant with DFA2 but exceeds Part M Requirements	Not Compliant with DFA2	Notes
26.1.6	Where provision is made for signing or lipreading, this should be suitably located to afford maximum visibility and should be well lit avoiding a distracting background.	N/A	N/A	N/A	
27	Management and Maintenance				
27.1.1	Ensure that paths, ramps and steps are kept clean, unobstructed and free of surface water, leaves, snow and ice.				Subject to operators management strategy
27.1.2	Regularly review the number of accessible car parking spaces.				Subject to operators management strategy
27.1.3	Ensure that parking spaces which are marked out for use by Badge holders are kept clear and unobstructed.				Subject to operators management strategy
27.1.4	Ensure that surfaces and floor coverings are regularly inspected and that any trip hazards are repaired immediately.				Subject to operators management strategy
27.1.5	Ensure that passenger lifts, stair lifts and platform lifts are checked regularly for proper working order. Have procedures in place so that services can be offered when such facilities break down.				Subject to operators management strategy
27.1.6	Ensure that spaces required for wheelchair manoeuvring are kept unobstructed, for example, by temporary displays, deliveries and cleaning equipment.				Subject to operators management strategy
27.1.7	Ensure that accessible WC areas are not used as storage spaces.				Subject to operators management strategy
27.1.8	Ensure that shower heads are returned to the bottom of the shower rail after use.				Subject to operators management strategy

Design for Access 2

Laystall Street
1283/Da
26.03.20



Item	DFA2 Standard	Compliant with DFA2 N/A	Not Compliant with DFA2 but exceeds Part M Requirements	Not Compliant with DFA2	Notes
27.1.9	Ensure that emergency pull cords are not left tied up after cleaning.				Subject to operators management strategy
27.1.10	Ensure that wheelchair spaces are provided and maintained in all seating areas.				Subject to operators management strategy
27.1.11	Ensure that access routes, of minimum width 900mm, to key facilities are provided and maintained between moveable tables and chairs.				Subject to operators management strategy
27.1.12	Ensure that windows, lamps and blinds are kept clean to maximise available light.				Subject to operators management strategy
27.1.13	Ensure that hearing enhancement systems are clearly indicated, tested regularly and maintained.				Subject to operators management strategy
27.1.14	When carrying out refurbishment or redecoration, ensure that textures and colour schemes comply with the guidance in section 22: Surfaces and Finishes.				Subject to operators management strategy
27.1.15	Ensure that signs are replaced and updated when necessary.				Subject to operators management strategy
27.1.16	Ensure that there are emergency evacuation plans, which are regularly reviewed, for all visitors and staff.				Subject to operators management strategy
27.1.17	Ensure that there are emergency assistance procedures to respond to requests for assistance by the use of alarm systems in lifts, toilets, showers, bathrooms, etc.				Subject to operators management strategy
27.1.18	Provide ongoing disability equality training for all staff.				Subject to operators management strategy

Design for Access 2

Laystall Street
1283/Da
26.03.20



Item	DFA2 Standard	Compliant with DFA2 N/A	Not Compliant with DFA2 but exceeds Part M Requirements	Not Compliant with DFA2	Notes
28	Listed Buildings				
28.1.1	Designers should aim to meet the guidance given in the relevant sections in this manual and should consult access officers, planners, conservation officers, building control officers and disabled people's access groups, as appropriate, to ensure that an acceptable balance is reached between the provision of good access and the protection of the character of the listed building.				See OMI D&A Statement
28.1.2	Designers should submit an Access Statement when proposing works that will affect access to a listed building. The Access Statement should identify the physical and communication barriers to access, assess the impact of access requirements on features of historic, architectural or archaeological interest or their setting, and devise a solution that reconciles access and conservation requirements.				See OMI D&A Statement
29	Playgrounds				
29.1.1	Play areas should be fenced, with gates of minimum width 1000mm, and should have attractive, welcoming entrances, with appropriate signs and information. Any closing mechanisms should be fixed at 900mm above ground level and should be smoothly free turning and maintained for low friction operation.	N/A	N/A	N/A	
29.1.2	Landmarks are important features, whether a tree, a mound, a pond or a play structure, and of particular value is a tall feature from which views can be had.	N/A	N/A	N/A	

Design for Access 2

Laystall Street
1283/Da
26.03.20

OMI

Item	DFA2 Standard	Compliant with DFA2 N/A	Not Compliant with DFA2 but exceeds Part M Requirements	Not Compliant with DFA2	Notes
29.1.3	A network of unobstructed paths should connect directly with all entrances and exits and main activity centres, going around and through pieces of equipment.	N/A	N/A	N/A	
29.1.4	Paths should be stable (not sand, bark or loose gravel), smooth, firm, slip resistant*, without grids and anti-skid, and joints should be tight and flush. Paths should be no steeper than 1 in 20 (5%) and should be at least 1800mm wide.	N/A	N/A	N/A	
29.1.5	Rubberised safety surfaces should be used.	N/A	N/A	N/A	
29.1.6	Bitmac and paving can be used in different colours, as can rubberised safety surfaces, to indicate different functions, different areas and changes in level. Different textures can provide clues as to different areas of the playground.	N/A	N/A	N/A	
29.1.7	Different items of play equipment should be provided in order to offer opportunities for all abilities, encourage independence and offer a wide range of experiences and challenges.	N/A	N/A	N/A	
29.1.8	Seats and/or shelters should be provided every 50 metres to give opportunities for opting out of activities or choosing others. See section 5: Seating. Retreats and breakaway points should be provided so that a child has the opportunity to check out an activity before deciding to take part. Seats and tables, dens and retreat areas should be accessible to disabled children and adults.	N/A	N/A	N/A	

Design for Access 2

Laystall Street
1283/Da
26.03.20



Item	DFA2 Standard	Compliant with DFA2 N/A	Not Compliant with DFA2 but exceeds Part M Requirements	Not Compliant with DFA2	Notes
29.1.9	Features in playgrounds can be designed to stimulate the use and development of all the senses. Communication can be through more than visual cues, for example, sounds can be used. The repetition of cues can be particularly useful, for example, striking a stick on railings. However, if a system of tracking by use of colour, texture, graphics or sound is used, it is important to use it consistently.	N/A	N/A	N/A	
29.1.10	Where tunnels and bridges are provided they should be sturdy enough and wide enough to accommodate wheelchair users. Tunnels with sequences of solid walls, window openings and exit/entry places reflect sound differently and can give clues to location, so long as materials that echo are used.	N/A	N/A	N/A	
29.1.11	Seesaws, and other equipment, should be designed to allow a disabled child to transfer from a wheelchair on to the equipment.	N/A	N/A	N/A	
29.1.12	Steps as well as ramps should be provided to high places.	N/A	N/A	N/A	
29.1.13	Slides should either allow use by a wheelchair user or provide the opportunity to transfer by ensuring access to the top and bottom of the slide.	N/A	N/A	N/A	

Design for Access 2

Laystall Street
1283/Da
26.03.20



Item	DFA2 Standard	Compliant with DFA2 N/A	Not Compliant with DFA2 but exceeds Part M Requirements	Not Compliant with DFA2	Notes
29.1.14	Modular play equipment should have ramps at gradients generally no steeper than 1 in 20 (5%), with handrails, leading to towers, the tops of slides and across bridges. Ramps should give access to the highest platform and should be designed as an integral part of the equipment. Platforms, resting places and places to turn around should be provided. Different colours could be used on floors and railings at different levels to cue children about how far they are from the ground.	N/A	N/A	N/A	
29.1.15	Water features, such as paddling pools, should have textured slip resistant* surfaces and gently chamfered edges, to allow disabled children to completely enter the pool. Waterfalls, streams and channels should allow disabled children to get up close.	N/A	N/A	N/A	
29.1.16	Where opportunities for gardening, nature study and messy play are provided, these should include sand trays, flower beds and nature study areas that are raised to different heights, and shaped so that users can play easily. Height and reach should be carefully calculated.	N/A	N/A	N/A	