

Schedule						
Symbol	Label	Quantity	Catalog Number	Description	Lumen Output	Wattage
	AW	11	Holophane DSX1.2.LA224.FW	Wall Mounted @ 8m	0° Bracket Tilt	21875
	BW	2	Holophane DEW.LA014.AY.CGL	Wall Mounted @ 3.5m		1237
	C1	10	Holophane BCL1.1.LA404.FW	Column Mounted @ 10m		37051
	D1	8	Holophane BCL1.1.LA404.SY	Column Mounted @ 10m		43355
	E1	5	Holophane VMX.2.LA044.V1.L2L3.W027	Column Mounted @ 8m	0° Bracket Tilt	4142
	FW	0	Holophane DSX1.2.LA084.FW	Column Mounted @ 6m	0° Bracket Tilt	8223
	F1	1	Holophane DSX1.2.LA084.FW	Column Mounted @ 6m	0° Bracket Tilt	8223

Statistics					
Description	Symbol	Avg	Min	Min/Avg	
Access Road		14 lux	5 lux	0.36	
Car Park		17 lux	10 lux	0.59	
Phase 2 Car Park		15 lux	5 lux	0.33	
Vehicle Parking		20 lux	6 lux	0.30	
Vertical East		1 lux	0 lux	0.00	
Vertical North West		1 lux	0 lux	0.00	
VMU Access Doors		30 lux	22 lux	0.44	
VMU office		38 lux	17 lux	0.45	
Wash Area		26 lux	10 lux	0.38	



Plan View
Scale = 1 : 1000

Note
Holophane Europe Ltd offer a Lighting Design Service in good faith and without charge, every effort is made to ensure we interpret the design specification accurately. All Illuminance values shown are the result of theoretical computer calculations; summated by luminaires positioned in a fixed relationship to each other and the statistical zone. In practice the values may vary due to tolerances in column installation, luminaire orientation, surface reflectance and fluctuations in power supply (voltage).Results provided within this design are derived from product specific photometry, the substitution of alternative luminaires will not produce comparable results.