

1665 8-16 Newton Street NBS

08 May 2018

Table of Contents

Title		Page
C	Demolition/ Alteration/ Renovation	4
C40	Cleaning masonry/ concrete	6
C41	Repairing/ Renovating/ Conserving masonry	11
C51	Repairing/ Renovating/ Conserving timber	18
F	Masonry	20
F10	Brick/ block walling	22
G	Structural/Carcassing metal/timber	26
G20	Carpentry/ timber framing/ first fixing	28
H	Cladding/Covering	32
H10	Patent glazing	34
H62	Natural slating	37
H71	Lead sheet coverings/ flashings	41
H72	Aluminium strip/ sheet coverings/ flashings	45
K	Linings/Sheathing/Dry partitioning	48
K10	Gypsum board dry linings/ partitions/ ceilings	50
L	Windows/Doors/Stairs	53
L10	Windows/ Rooflights/ Screens/ Louvres	55
L20	Doors/ shutters/ hatches	59
L30	Stairs/ ladders/ walkways/ handrails/ balustrades	63
L40	General glazing	65
N	Furniture/Equipment	67
N16	Bird and vermin control systems	69
P	Building fabric sundries	70
P10	Sundry insulation/ proofing work	72
P20	Unframed isolated trims/ skirtings/ sundry items	74
P21	Door/ window ironmongery	77
R	Disposal systems	78

R10	Rainwater drainage systems	80
Z	Building fabric reference specification	83
Z10	Purpose made joinery	85
Z11	Purpose made metalwork	88
Z12	Preservative/ fire retardant treatment	92
Z20	Fixings and adhesives	94
Z21	Mortars	98
Z22	Sealants	102
Z31	Powder coatings	104

C

Demolition/ Alteration/ Renovation

C40

Cleaning masonry/ concrete

C40 Cleaning masonry/ concrete

To be read with Preliminaries/ General conditions.

GENERAL/ PREPARATION

110A SCOPE OF WORK ALL ELEVATIONS TO BUILDING

- 120 RELATED REPAIR AND REMEDIAL WORKS
 - " Work to be carried out before cleaning work: Pointing to cracks and joints in masonry, as section C41.
- 142 REMOVAL OF FITTINGS
 - " Timing: Before commencement of cleaning work.
 - " Disturbance to surfaces: Minimize.
 - " Items for disposal:
 - Brackets;
 - Fasteners; and
 - Metal clips.
 - " Items to be kept for reuse: none.
- 160 PROTECTION
 - " Surfaces not designated for cleaning: Prevent damage, including marking and staining.
 - " Openings: Prevent ingress of water, cleaning agents and detritus.
 - Vents and grilles: Seek instructions before sealing up.
 - " Temporary mechanical fastenings:
 - In masonry: Locate in joints.
 - In other surfaces: Seek instructions.
 - " Additional protection: Submit proposals .
- 175 CONTROL AND DISPOSAL OF WASH WATER AND DETRITUS
 - " Disposal: Safely. Obtain approvals from relevant Authority.
 - " Control of wash water: Collect and divert to prevent ingress and damage to building fabric and adjacent areas.
 - " Above and below ground drainage systems: Keep free from detritus and maintain normal operation.
- 190 CLEANING GENERALLY
 - " Operatives: Appropriately trained and experienced for each type of cleaning work.
 - Evidence of training: Submit on request.
 - " Control of cleaning: Confine cleaning processes and materials to designated areas.
 - " Prevent wind drift.
 - " Detritus: Remove regularly. Dispose of safely.
 - " Monitoring: Frequently check results of cleaning compared to approved trial samples. If results established by trials are not achieved, seek instructions.
 - " Modifications to cleaning methods and materials: Seek instructions.
- 215 RECORD OF CLEANING WORKS
 - " Written report: Record cleaning methods and procedures used for each type of surface and deposit.
 - Content: Relevant attributes of cleaning methods used including:
 - Equipment and settings.
 - Dwell times.
 - Number of applications.
 - Ambient temperatures.
 - " Additional documentation: None.
 - " Submission: At completion of cleaning works.

- 230 TRIAL SAMPLES
 " Trial sample reference: TS001.
 - Surface: Clay brick.
 - Location/ Size: 2m2.
 - Type of soiling: Paint.
 - Cleaning methods: Chemicals.
 " Records: Maintain written records for each trial area, including cleaning methods and conditions, to enable replication of results elsewhere.
- PRODUCTS/ EQUIPMENT
- 300 COMPATIBILITY OF CHEMICAL PRODUCTS
 " Products: Compatible and produced by the same manufacturer.
- 312 SURFACE BIOCIDES
 " Types: Registered by the Health and Safety Executive (HSE) and listed on the HSE website under non-agricultural pesticides.
 " Compatibility with surface: Free from staining or other harmful effects.
- 362 CHEMICAL AGENTS FOR PAINT REMOVAL
 " Manufacturer: Submit proposals.
 - Product reference: Submit proposals.
- APPLICATION
- 412 REMOVAL OF LOOSELY ADHERED DEPOSITS
 " Timing: Before commencement of other cleaning methods.
 " Surfaces: Prevent damage, including abrasion.
- 500 CHEMICAL CLEANING
 " Surfaces: Prevent damage, including discolouration, bleaching and efflorescence.
 " Product variables (including concentrations, dwell times and number of applications):
 " Adjust for each surface to achieve optimum cleaning performance.
 " Application: To wetted surfaces.
 - Drying out: Prevent unless recommended otherwise by cleaning product manufacturer.
 " Removal of chemicals and neutralization: As recommended by product manufacturer, including rinsing with clean water.
 - Additional treatment: Where water rinsing is insufficient to neutralize surface, apply compatible neutralizing agent.
 - Surfaces and joints: Minimize absorption of chemicals. Prevent damage, including abrasion. .
- 120 RELATED REPAIR AND REMEDIAL WORKS
- Work to be carried out before cleaning work: Pointing to cracks and joints in masonry, as section C41.
- 160 PROTECTION
- Surfaces not designated for cleaning: Prevent damage, including marking and staining.
 - Openings: Prevent ingress of water, cleaning agents and detritus.
 - Vents and grilles: Seek instructions before sealing up.
 - Temporary mechanical fastenings:
 - In masonry: Locate in joints.
 - In other surfaces: Seek instructions.
 - Additional protection: Submit proposals .

- 180 COLD WEATHER
- Cleaning procedures using water: Do not use when air temperature is at or below 5°C. Protect damp surfaces from frost.
 - Chemical cleaning agents: Do not use when surface temperatures are below those recommended by manufacturer.
- 190 CLEANING GENERALLY
- Operatives: Appropriately trained and experienced for each type of cleaning work.
 - Evidence of training: Submit on request.
 - Control of cleaning: Confine cleaning processes and materials to designated areas. Prevent wind drift.
 - Detritus: Remove regularly. Dispose of safely.
 - Monitoring: Frequently check results of cleaning compared to approved trial samples. If results established by trials are not achieved, seek instructions.
 - Modifications to cleaning methods and materials: Seek instructions.
- 215 RECORD OF CLEANING WORKS
- Written report: Record cleaning methods and procedures used for each type of surface and deposit.
 - Content: Relevant attributes of cleaning methods used including:
 - Equipment and settings.
 - Dwell times.
 - Number of applications.
 - Ambient temperatures.
 - Additional documentation: None.
 - Submission: At completion of cleaning works.
- 230 TRIAL SAMPLES
- Trial sample reference: Brock and Stone.
 - Surface: Clay brick and Sandstone.
 - Location/ Size: sample.
 - Type of soiling: Atmospheric soiling.
 - Cleaning methods: Steam.
 - Records: Maintain written records for each trial area, including cleaning methods and conditions, to enable replication of results elsewhere.

PRODUCTS/ EQUIPMENT

- 352 STEAM CLEANING EQUIPMENT
- Manufacturer: Contractor's choice .
 - Product reference: Submit proposals .
- 412 REMOVAL OF LOOSELY ADHERED DEPOSITS
- Timing: Before commencement of other cleaning methods.
 - Surfaces: Prevent damage, including abrasion.
- 482 STEAM CLEANING
- Surfaces: Prevent damage, including abrasion.
 - Equipment settings (including nozzle type and distance from surface): Adjust regularly to achieve optimum cleaning performance for each surface.

C41

Repairing/ Renovating/ Conserving masonry

C41 Repairing/ Renovating/ Conserving masonry

To be read with Preliminaries/ General conditions

GENERALLY/ PREPARATION

120 SITE INSPECTION

- Purpose: To confirm type and extent of repair/ renovation/ conservation work shown on drawings and described in survey reports and schedules of work.
- Parties involved: Client/Architect/Contractor.
- Timing: Prior to start on site.
- Instructions issued during inspection: To be noted and issued on AI.

125 REMOVAL OF FITTINGS/ FIXTURES

- Items to be removed, and reinstated on completion of repair work: All none original signage/fire alarm and vents and cables. Unless otherwise stated for disposal or storage on site.
 - Identification: Attach labels or otherwise mark items using durable, non-permanent means, to identify location and describe refixing instructions, where applicable.
 - Treatment following removal: As schedule good all holes with coloured mortar to match brick or stone.
 - Storage: Protect against damage, and store until required.
Storage location: To be determined by client.
 - Reinstatement: Refit in original locations using original installation methods.
- Items unsuitable or not required for reuse: any signage/fire alarm and vents and cables.
 - Disposal: To approved site.
- Masonry fabric and surfaces: Do not damage during removal and replacement of fittings/ fixtures.

130 REMOVAL OF PLANT GROWTHS FROM MASONRY

- Plants, root systems and associated soil/ debris: Carefully remove from joints, voids and facework.
- Removal of roots: Where growths cannot be removed completely without disturbing masonry seek instructions.
- Unwanted plants close to masonry: Where removal of root system is not possible or desirable, cut through stem as close to the ground as possible. Remove bark from stump and apply herbicide paste. Leave stump to wither.

140 RECORD OF WORK

- General: Record work carried out to masonry clearly and accurately using written descriptions, sketches, drawings and photographs, as necessary.
- Specific records: To be kept on site.
- Documentation: Submit on completion of the work.
 - Number of sets: 1 Electronic 1 paper .

WORKMANSHIP GENERALLY

150 POWER TOOLS

- Usage for removal of mortar: Not permitted .

- 160 PROTECTION OF MASONRY UNITS AND MASONRY
- Masonry units: Prevent overstressing during transit, storage, handling and fixing. Store on level bearers clear of the ground, separated with resilient spacers. Protect from adverse weather and keep dry. Prevent soiling, chipping and contamination. Lift units at designed lifting points, where provided.
 - Masonry: Prevent damage, particularly to arrises, projecting features and delicate, friable surfaces. Prevent mortar/ grout splashes and other staining and marking on facework. Protect using suitable nonstaining slats, boards, tarpaulins, etc. Remove protection on completion of the work.
- 165 STRUCTURAL STABILITY
- General: Maintain stability of masonry. Report defects, including signs of movement that are exposed or become apparent during the removal of masonry units.
- 170 DISTURBANCE TO RETAINED MASONRY
- Retained masonry in the vicinity of repair works: Disturb as little as possible.
 - Existing retained masonry: Do not cut or adjust to accommodate new or reused units.
 - Retained loose masonry units and those vulnerable to movement during repair works: Prop or wedge so as to be firmly and correctly positioned.
- 180 WORKMANSHIP
- Skill and experience of site operatives: Appropriate for types of work on which they are employed.
 - Documentary evidence: Submit on request.
- 185 ADVERSE WEATHER
- General: Do not use frozen materials or lay masonry units on frozen surfaces.
 - Air temperature: Do not bed masonry units or repoint:
 - In cement gauged mortars when ambient air temperature is at or below 3°C and falling or unless it is at least 1°C and rising, unless mortar has a minimum temperature of 4°C when laid and the masonry is adequately protected.
 - In hydraulic lime:sand mortars when ambient air temperature is at or below 5°C and falling or unless it is at least 3°C and rising.
 - In nonhydraulic lime:sand mortars in cold weather, unless approval is given.
 - Temperature of the work: Maintain above freezing until mortar has fully set.
 - Rain, snow and dew: Protect masonry by covering during precipitation, and at all times when work is not proceeding.
 - Hot conditions and drying winds: Prevent masonry from drying out rapidly.
 - New mortar damaged by frost: Rake out and replace.

MATERIALS/ PRODUCTION/ ACCESSORIES

- 210 ADVANCE REGISTRATION
- Material registered in advance by the Employer: Obtain from the supplier named in Preliminaries section A56.
 - Ordering: Supersede the Employer's registration and take over responsibility by an order to the supplier covering price, supply and delivery to suit the progress of the work.
- 215 MATERIAL SAMPLES
- Representative samples of designated materials: Submit before placing orders.
 - Designated materials: Brickwork/Stone.
 - Retention of samples: Unless instructed otherwise, retain samples on site for reference. Protect from damage and contamination.

220 RECORDING PROFILES

- Profiles: Take measurements from existing masonry units, as instructed, to allow accurate matching of replacements.
- Recording in situ: If there are no suitable joints to allow use of inserts, seek instructions.
- Drawings and templates: Prepare as necessary. Templates must be clearly and indelibly marked to identify use and location.

240 STONE

- Supplier: Submit Proposals.
- Type: Portland stone to match existing.
- Quality: Free from vents, cracks, fissures, discolouration, or other defects that may adversely affect strength, durability or appearance. Thoroughly seasoned, dressed and worked in accordance with shop drawings prepared by the supplier.
- Finish: To match existing.

245 REPLACEMENT STONE UNITS

- Sizes and profiles: To match existing masonry. Maintain existing joint widths.
- Sinkings for fixings, joggles and lifting devices: Accurately aligned and positioned in relation to existing masonry.
- Marking: Mark each block/ dressing clearly and indelibly on a concealed face to indicate the natural bed and position in the finished work.

250 STONE ORIENTATION

- Orientation of natural bed:
 - In plain walling: Horizontal.
 - In projecting stones and copings: Vertical and perpendicular to wall face.
 - In arches: Perpendicular to line of thrust.

260A BRICKS REPLACEMENT

- Manufacturer: Bricks to match existing.
 - Product reference: TBC.
- Size: To match existing.
- Special shapes: To match existing.
- Recycled content: TBC.

265 SALVAGED AND SECOND HAND BRICKS

- Source: Contractor to submit proposals.
- Condition:
 - Free from matter such as mortar, plaster, paint, bituminous materials and organic growths.
 - Sound, clean and reasonably free from cracks and chipped arrises.

DISMANTLING/ REBUILDING

310 DISMANTLING MASONRY FOR REUSE

- Masonry units to be reused: Remove carefully and in one piece.
 - Treatment: Clean off old mortar, organic growths and dirt, and leave units in a suitable condition for rebuilding.
 - Identification: Mark each unit clearly and indelibly on a concealed face, indicating its original position in the construction. Transcribe markings to drawings/ photographs.

REPLACEMENTS AND INSERTIONS

330 PREPARATION FOR REPLACEMENT MASONRY

- Defective material: Carefully remove to the extent agreed. Do not disturb, damage or mark adjacent retained masonry.
- Existing metal fixings, frame members, etc: Report when exposed.
- Redundant metal fixings: Remove.
- Recesses: Remove projections and loose material; leave joint surfaces in a suitable condition to receive replacement units. Protect from adverse weather if units are not to be placed immediately.

340 REPLACEMENT OF STONE TO ELEVATION

- Stone: Portland stone as clause 240 .
- Bedding depths: Flush to match existing .
- Mortar: As section Z21.
 - Mix: Hydraulic Lime to match existing .
 - Sand source/ type: To match existing .
- Fixings: None .
- Joints: To match existing .
- Other requirements: None .

365 REPLACEMENT OF BRICKS Where noted once scaffolding is erected and inspection and survey has occurred

- Bricks: Reclaimed brick as clause 265.
- Mortar: As section Z21.
 - Mix: As section Z21.
 - Sand source/ type: Well graded crushed stone to approval.
- Fixings: Not required.
- Joints: To match existing.
- Other requirements: None.

385 LAYING REPLACEMENT MASONRY UNITS

- Exposed faces of new material: Keep to agreed face lines.
- Faces, angles and features: Align accurately. Set out carefully to ensure satisfactory junctions with existing masonry and maintain existing joint widths.
- Joint surfaces: Dampen to control suction as necessary.
- Laying units: On a full bed of mortar, all joints filled.
- Exposed faces: Keep clear of mortar and grout.

390 GROUTING JOINTS

- Grout mix: To match existing.
- Joints that cannot be fully filled with bedding mortar: Grout thoroughly around replacement masonry units.
- Grouting: Keep grout back from exposed face to allow for the depth of pointing, using an approved temporary sealing material. Prevent grout staining exposed face.

395 INSTALLING STONE INSERTS

- Pockets to receive inserts:
 - Cut out accurately. Undercut sides of pocket where necessary to provide space for bonding material.
 - Adjust depth so that insert stands proud of existing stone for finishing in situ.
 - Clean out thoroughly.
- Inserts: Cut to the smallest rectangular shape necessary to replace the defective area and provide a firm seating. Install accurately and securely.
 - Exposed faces: Keep clear of bonding material.
- Existing joint widths: Maintain. Do not bridge joints.

TOOLING/ DRESSING STONE IN SITU

450 WEATHERING LEDGES AT JOINTS

- Locations: Where stones project or are recessed.
- Requirement: Carefully weather the ledge, to approval.
- Method: Suitably graded carborundum blocks or tooling as appropriate.

MORTAR REPAIRS

510 PREPARATION FOR MORTAR REPAIRS

- Repair area: Scribe area of masonry to be removed using straight horizontal and vertical lines parallel to joints. Where repair area abuts joints, maintain existing joint widths and do not bridge joints.
- Decayed masonry: Cut back carefully to a minimum depth of 20 mm to a sound background. Where the depth of removal exceeds 50 mm, seek instructions.
- Precautions: Do not weaken masonry by removing excessive material. Do not damage adjacent masonry.
- Top and vertical reveals of repair area: Undercut.

520 MORTAR REPAIRS TO EXISTING JOINTS

- Undercoats: As section Z21.
 - Mix: To match existing 1:1:6.
 - Sand source/ type: Fine sand to approval.
 - Building up: In layers where necessary, each layer not exceeding 12 mm.
- Finishing coat: To match approved samples.
 - Mix: 1:3 nonhydraulic lime putty:sand and stone dust.
 - Sand source/ type: Fine sand to approval.
 - Finished thickness: To match existing.
 - Finish: To match existing.
- Reinforcement: Not required.

540 APPLYING MORTAR

- Surfaces to receive mortar: Clean, and free from dust and debris. Dampen to control suction.
- Applying coats: Build up in layers to specified thickness. Apply mortar firmly, ensuring good adhesion with no voids. Form a mechanical key to undercoats by combing or scratching to produce evenly spaced lines.
Allow each layer to achieve an initial set before applying subsequent coats. Prevent each layer from drying out rapidly by covering immediately with plastics sheeting and/ or dampening intermittently with clean water.
- Finishing mortar coat: Form accurately to required planes/ profiles, and finish flush with adjacent masonry.
- Protection: Protect completed repairs from adverse weather until mortar has set.

CRACK REPAIRS/ TIES/ REINFORCEMENT

630 TIES GENERALLY

- Tie system manufacturer: To SE details and spec.
 - Product reference: To SE details and spec.
- Type/ Diameter: To SE details and spec.
- Grout: To SE details and spec.
- Holes: Drill carefully and accurately, in locations shown on drawings, to suit types and lengths of tie. Remove drilling dust and debris.
- Adjacent masonry: Do not damage during drilling. Keep cavities behind facings free from debris.
- Tie installation:
 - Expansion type anchor fixings: Set to the correct torque.
 - Bonded ties: Grouted.
 - Ends of ties: Keep back from face of masonry to allow for making good.
- Exposed masonry faces: Clean and free from grout/ mortar stains.
- Making good: To match existing.

POINTING/ REPOINTING

810 PREPARATION FOR REPOINTING

- Existing mortar: Working from top of wall downwards, remove mortar carefully, without damaging adjacent masonry or widening joints, to a minimum depth of 30 mm.
 - Loose or friable mortar: Seek instructions when mortar beyond specified recess depth is loose or friable and/ or if cavities are found.
- Raked joints: Remove dust and debris.

820 POINTING GENERALLY

- Preparation of joints: Clean existing mortar out to twice depth of joint and wet thoroughly.
- Mortar: As section Z21.
 - Mix: 1:3 ready-mixed nonhydraulic lime putty:sand.
 - Sand source/ type: Crushed stone fine pointing sand to approval.
- Joints profile/ finish: To match existing.
- Other requirements: None.

840 POINTING WITH TOOLS/ IRONS

- General: Press mortar well into joints using pointing tools/ irons that fit into the joints, so that they are fully filled.
- Face of masonry: Keep clear of mortar. Use suitable temporary adhesive tape on each side of joints where necessary. Finish joints neatly.

860 BRUSHED FINISH TO JOINTS

- Timing: After initial mortar set has taken place remove laitance and excess fines by brushing, to give a coarse texture. Do not compact mortar.

C51

Repairing/ Renovating/ Conserving timber

C51 Repairing/ Renovating/ Conserving timber

To be read with Preliminaries/ General conditions

GENERAL

110 INSPECTION

- Purpose: To confirm nature and extent of repair/ renovation/ conservation work shown on drawings and described in survey reports and schedules of work.
- Parties involved: Contractor's representative.
- Timing: At least 14 days before starting each section of work.
- Instructions issued during inspection: Confirm in writing, with drawings and schedules as required, before commencing work.

130 OPENING UP

- Purpose: To reveal previously concealed areas of structure or fabric not recorded during initial surveys.
- Extent: To be agreed.
- Timing: Give notice before starting opening up.
 - Period of notice: At least 24 hours.
- Retained building structure/ fabric: Do not damage or destabilize.

150 TIMBER PROCUREMENT

- Timber (including timber for wood-based products): Obtained from well-managed forests and/ or plantations in accordance with:
 - The laws governing forest management in the producer country or countries.
 - International agreements such as the Convention on International Trade in Endangered Species of wild fauna and flora (CITES).
- Documentation: Provide either:
 - Documentary evidence (that has been or can be independently verified) regarding the provenance of all timber supplied.
 - Evidence that suppliers have adopted and are implementing a formal environmental purchasing policy for timber and wood-based products.
- Certification scheme: UK Timber Procurement Policy Category A evidence certification scheme..
 - Other evidence: None.

160 TIMBER SUPPLIER

- Supplier: Contractor's choice.

PRODUCTS

360 SOFTWOOD FOR JOINERY REPAIRS To Existing Windows

- Species: to match existing, European.
- Quality: Generally to BS EN 942; free from decay and insect attack (except pinhole borers).
 - Appearance class: Class J2.
- Treatment: to NBS section Z12 and Wood Protection Association Commodity Specification
- Moisture content on delivery: 13-19%.

EXECUTION

600 WORKMANSHIP

- Skill and experience of site operatives: Appropriate for types of work on which they are employed.
 - Documentary evidence: Submit on request.

620 PROTECTION OF TIMBER AND WOOD COMPONENTS BEFORE AND DURING INSTALLATION

- Storage: Keep dry, under cover, clear of the ground and with good ventilation. Support sections/ components on regularly spaced, level bearers on a dry, firm base.
- Handling: Do not overstress, distort or disfigure sections or components during transit, storage, lifting, erection or fixing.

630 MATERIAL SAMPLES

- Representative samples of designated materials: Submit before placing orders.
 - Designated materials: softwood.

640 PROTOTYPES

- General: Prepare one of each of the following items and arrange for inspection before starting repetitive fabrication: typical repair.

650 DIMENSIONS GENERALLY

- Site dimensions: Take as necessary before starting fabrication.
 - Discrepancies with drawings: Report without delay and obtain instructions before proceeding.

665 CROSS SECTION DIMENSIONS OF NON-STRUCTURAL SOFTWOOD

- Dimensions: Dimensions in this specification and shown on drawings are finished sizes.
- Maximum permitted deviations from finished sizes: As stated in BS EN 1313-1, clause 6 for sawn sections.

700 WOOD COMPONENTS - AS DELIVERED FINISH

- Components to be painted: Primed.
- Components to be clear finished: First coat of specified finish applied.

760 REPAIR OF MEMBERS - CUTTING OUT MEMBERS

- Extent of timber removal: Cut out full cross section of member where wood is defective or decayed, plus 100 mm of sound wood.
- Distance from face of support to cut end of existing timber: Obtain instructions if dimension exceeds 100 mm.
- Joint profile: Square cut.

860 MOISTURE CONTENT CHECKING

- Procedure: When instructed, check moisture content of timber sections with an approved electrical moisture meter.
- Test results: Keep records of all tests. If moisture content falls outside specified range, obtain instructions.

F

Masonry

F10

Brick/ block walling

F10 Brick/ block walling

To be read with Preliminaries/ General conditions.

TYPES OF WALLING

110 CLAY FACING BRICKWORK TO MATCH EXISTING

- Bricks: To BS EN 771-1.
 - Manufacturer: Contractor's choice Brickwork to match existing.
 - Product reference: Contractor's choice.
 - Recycled content: None permitted.
 - Special shapes: None.
- Mortar: As section Z21.
 - Standard: To BS EN 998-2.
 - Mix: 1:1:6 cement:lime:sand.
 - Additional requirements: Coloured mortar to match bricks .
- Bond: To match existing.
- Joints: Bucket handle.
- Features: None.

TESTING

415 FRESH MORTAR CEMENT CONTENT

- Test method: BREMORTEST in accordance with Building Research Establishment Information Paper 8/89 .
- Test specimens: Test mortar for the following wall types: F10/ 110 .
- Results: Submit.

WORKMANSHIP GENERALLY

430 CONDITIONING OF CLAY AND CALCIUM SILICATE BRICKS AND CLAY BLOCKS

- Bricks and blocks delivered warm from manufacturing process: Do not use until cold.
- Absorbent bricks in warm weather: Wet to reduce suction. Do not soak.

460 MORTAR GROUPS

- Mix proportions: For a specified group select a mix design from the following:
 - Group 1:
 - 1:0–0.25:3 (Portland cement:lime:sand with or without air entraining additive).
 - 1:3 (Portland cement:sand and air entraining additive).
 - Group 2:
 - 1:0.5:4–5 (Portland cement:lime:sand with or without air entraining additive).
 - 1:3 (masonry cement:sand containing Portland cement and lime in approximate ratio 1:1, and an air entraining additive).
 - 1:2.5–3.5 (masonry cement:sand containing Portland cement and inorganic materials other than lime and air entraining additive).
 - 1:3–4 (Portland cement:sand and air entraining additive.)
 - Group 3:
 - 1:1:5–6 (Portland cement:lime:sand with or without air entraining additive).
 - 1:3.5–4 (masonry cement:sand containing Portland cement and lime in approximate ratio 1:1, and an air entraining additive).
 - 1:4–5 (masonry cement:sand containing Portland cement and inorganic materials other than lime and air entraining additive).
 - 1:5–6 (Portland cement:sand and air entraining additive).
 - Group 4:
 - 1:2:8–9 (Portland cement:lime:sand with or without air entraining additive).
 - 1:4.5 (masonry cement:sand containing Portland cement and lime in approximate ratio 1:1, and an air entraining additive).
 - 1:5.5–6.5 (masonry cement:sand containing Portland cement and inorganic materials other than lime and air entraining additive).
 - 1:7–8 (Portland cement:sand and air entraining additive).
- Batching: Mix proportions by volume.
- Mortar type: Continuous throughout any one type of masonry work.

500 LAYING GENERALLY

- Mortar joints: Fill vertical joints. Lay bricks, solid and cellular blocks on a full bed.
- AAC block thin mortar adhesive and gypsum block adhesive joints: Fill vertical joints. Lay blocks on a full bed.
- Clay block joints:
 - Thin layer mortar: Lay blocks on a full bed.
 - Interlocking perpends: Butted.
- Bond where not specified: Half lap stretcher.
- Vertical joints in brick and concrete block facework: Even widths. Plumb at every fifth cross joint.

520 ACCURACY

- Courses: Level and true to line.
- Faces, angles and features: Plumb.
- Permissible deviations:
 - Position in plan of any point in relation to the specified building reference line and/ or point at the same level ± 10 mm.
 - Straightness in any 5 m length ± 5 mm.
 - Verticality up to 3 m height ± 10 mm.
 - Verticality up to 7 m height ± 14 mm.
 - Overall thickness of walls ± 10 mm.
 - Level of bed joints up to 5 m (brick masonry) ± 11 mm.
 - Level of bed joints up to 5 m (block masonry) ± 13 mm.

610 SUPPORT OF EXISTING WORK

- Joint above inserted lintel or masonry: Fully consolidated with semidry mortar to support existing structure.

635 JOINTING

- Profile: Consistent in appearance.

665 POINTING TO ALL WALLING

- Joint preparation: Remove debris. Dampen surface.
- Mortar: As section Z21.
 - Standard: To BS EN 998-2.
 - Mix: 1:1:6 cement:lime:sand.
 - Additional requirements: Coloured mortar to match bricks.
- Profile: Bucket handle.

690 ADVERSE WEATHER

- General: Do not use frozen materials or lay on frozen surfaces.
- Air temperature requirements: Do not lay bricks/ blocks:
 - In cement gauged mortars when at or below 3°C and falling or unless it is at least 1°C and rising.
 - In hydraulic lime:sand mortars when at or below 5°C and falling or below 3°C and rising.
 - In thin joint mortar glue when outside the limits set by the mortar manufacturer.
- Temperature of walling during curing: Above freezing until hardened.
- Newly erected walling: Protect at all times from:
 - Rain and snow.
 - Drying out too rapidly in hot conditions and in drying winds.

ADDITIONAL REQUIREMENTS FOR FACEWORK

710 THE TERM FACEWORK

- Definition: Applicable in this specification to brick/ block walling finished fair.
 - Painted facework: The only requirement to be waived is that relating to colour.

730 BRICK/ CONCRETE BLOCK SAMPLES

- General: Before placing orders with suppliers submit for approval of appearance labelled samples of the following: Bricks as in clause F10/110 .
- Selection of samples: Representative of the range in variation of appearance.

740 FINISHED MASONRY WORK REFERENCE PANELS

- General: Before proceeding to construct the following walling types, construct panels as specified. Give notice when panels are dry.
- Selection of masonry units: Reasonably representative of the average quality of the whole order to be delivered .
- Panel types:
 - Walling type: F10/110 .
 - Location: Typical Parapet .
 - Size: 1.5 x 1.5 m .
 - Other requirements: None .

750 COLOUR CONSISTENCY OF MASONRY UNITS

- Colour range: Submit proposals of methods taken to ensure that units are of consistent and even appearance within deliveries.
- Conformity: Check each delivery for consistency of appearance with previous deliveries and with approved reference panels; do not use if variation is excessive.
- Finished work: Free from patches, horizontal stripes and racking back marks.

760 APPEARANCE

- Brick/ block selection: Do not use units with damaged faces or arrises.
- Cut masonry units: Where cut faces or edges are exposed cut with table masonry saw.
- Quality control: Lay masonry units to match relevant reference panels.
 - Setting out: To produce satisfactory junctions and joints with built-in elements and components.
 - Coursing: Evenly spaced using gauge rods.
- Lifts: Complete in one operation.
- Methods of protecting facework: Submit proposals.

790 PUTLOG SCAFFOLDING

- Use: Not permitted in facework.

800 TOOTHED BOND

- New and existing facework in same plane: Bond together at every course to achieve continuity.

830 CLEANLINESS

- Facework: Keep clean.
- Mortar on facework: Allow to dry before removing with stiff bristled brush.
- Removal of marks and stains: Rubbing not permitted.

G

Structural/Carcassing metal/timber

G20

Carpentry/ timber framing/ first fixing

G20 Carpentry/ timber framing/ first fixing

To be read with Preliminaries/ General conditions.

GENERAL

105 TIMBER PROCUREMENT

- Timber (including timber for wood based products): Obtained from well managed forests/ plantations in accordance with:
 - The laws governing forest management in the producer country or countries.
 - International agreements such as the Convention on International Trade in Endangered Species of wild fauna and flora (CITES).
- Documentation: Provide either:
 - Documentary evidence (which has been or can be independently verified) regarding the provenance of all timber supplied, or
 - Evidence that suppliers have adopted and are implementing a formal environmental purchasing policy for timber and wood based products.

150 STRENGTH GRADING OF TIMBER

- Grader: A company currently registered under a third party quality assurance scheme operated by a certification body approved by the UK Timber Grading Committee.

160 GRADING AND MARKING OF SOFTWOOD

- Timber of a target/ finished thickness less than 100 mm and not specified for wet exposure: Graded at an average moisture content not exceeding 20% with no reading being in excess of 24% and clearly marked as 'DRY' or 'KD' (kiln dried).
- Timber graded undried (green) and specified for installation at higher moisture contents: Clearly marked as 'WET' or 'GRN'.
- Structural timber members cut from large graded sections: Regraded to approval and marked accordingly.

PRODUCTS

210 STRUCTURAL SOFTWOOD (GRADED DIRECT TO STRENGTH CLASS) FOR STRUCTURAL USE GENERALLY

- Grading standard: To BS 4978, BS EN 14081-1, or other national equivalent and so marked.
- Strength class to BS EN 338: C16.
- Treatment:
 - Preservative treatment: Organic solvent impregnation to NBS section Z12 and Wood Protection Association Commodity Specification C8.
Design service life: 20 years.
 - Fire retardant treatment: Fire retardant impregnation to NBS section Z12 and Wood Protection Association Commodity Specification FR2, Type DI.

360A STUDDING FRAME TO BASE OF LOUVRE SUPPORT

- Manufacturer: None.
 - Product reference: Graded timber studding .
- Dimensions: Overall 4200mm x 6650mm.
 - Depth: 100mm x 50mm frame at 400mm centres.
 - Width: -.
- Masonry depth: Not applicable.

WORKMANSHIP GENERALLY

- 401 CROSS SECTION DIMENSIONS OF STRUCTURAL SOFTWOOD AND HARDWOOD
- Dimensions: Dimensions in this specification and shown on drawings are target sizes as defined in BS EN 336.

- Tolerances: The tolerance indicators (T1) and (T2) specify the maximum permitted deviations from target sizes as stated in BS EN 336, clause 4.3:
 - Tolerance class 1 (T1) for sawn surfaces.
 - Tolerance class 2 (T2) for further processed surfaces.

- 420 WARPING OF TIMBER

- Bow, spring, twist and cup: Not greater than the limits set down in BS 4978 or BS EN 14081-1 for softwood, or BS 5756 for hardwood.

- 430 SELECTION AND USE OF TIMBER

- Timber members damaged, crushed or split beyond the limits permitted by their grading: Do not use.

- 435 NOTCHES, HOLES AND JOINTS IN TIMBER

- Notches and holes:
 - General: Avoid if possible.
 - Sizes: Minimum needed to accommodate services.
 - Position: Do not locate near knots or other defects.
 - In same joist: Minimum 100 mm apart horizontally.
 - Notches in joists:
 - Position: Locate at top. Form by sawing down to a drilled hole.
 - Depth (maximum): 0.15 x joist depth.
 - Distance from supports: Between 0.1 and 0.2 x span.
 - Holes in joists:
 - Position: Locate on neutral axis.
 - Diameter (maximum): 0.25 x joist depth.
 - Centres (minimum): 3 x diameter of largest hole.
 - Distance from supports: Between 0.25 and 0.4 of span.
 - Notches in roof rafters, struts and truss members: Not permitted.
 - Holes in struts and columns: Locate on neutral axis.
 - Diameter (maximum): 0.25 x minimum width of member.
 - Centres (minimum): 3 x diameter of largest hole.
 - Distance from ends: Between 0.25 and 0.4 of span.
- Scarf joints, finger joints and splice plates: Do not use without approval.

- 440 PROCESSING TREATED TIMBER

- Cutting and machining: Carry out as much as possible before treatment.
- Extensively processed timber: Retreat timber sawn lengthways, thickened, planed, ploughed, etc.
- Surfaces exposed by minor cutting/ drilling: Treat with two flood coats of a solution recommended by main treatment solution manufacturer.

- 450 MOISTURE CONTENT

- Moisture content of wood and wood based products at time of installation: Not more than:
 - Covered in generally unheated spaces: 24%.
 - Covered in generally heated spaces: 20%.
 - Internal in continuously heated spaces: 20%.

451 MOISTURE CONTENT TESTING

- Procedure: When instructed, test timber sections with an approved electrical moisture meter.
- Test sample: Test 5% but not less than 10 lengths of each cross-section in the centre of the length.
- Test results: 90% of values obtained to be within the specified range. Provide records of all tests.

510 PROTECTION

- Generally: Keep timber dry and do not overstress, distort or disfigure sections or components during transit, storage, lifting, erection or fixing.
- Timber and components: Store under cover, clear of the ground and with good ventilation. Support on regularly spaced, level bearers on a dry, firm base. Open pile to ensure free movement of air through the stack.
- Trussed rafters: Keep vertical during handling and storage.

JOINTING TIMBER

570 JOINTING/ FIXING GENERALLY

- Generally: Where not specified precisely, select methods of jointing and fixing and types, sizes and spacings of fasteners in compliance with section Z20.

ERECTION AND INSTALLATION

710 PROPOSALS FOR ERECTING STRUCTURAL TIMBER

- Proposals: Submit details of:
 - Method and sequence of erection.
 - Type of craneage.
 - Temporary guys and bracing proposed for use during erection.
- Latest date for submission: 3 working days.

740 PRE-ERECTION CHECKING

- Timing: Not less than 10 days before proposed erection start date.
- Checklist:
 - Foundations and other structures to which timber structure will be attached: Check for accuracy of setting out.
 - Holding down bolts: Check for position, protruding length, condition and slackness.
- Inaccuracies and defects: Report without delay.
- Erection: Obtain permission to commence.

750 MODIFICATIONS/REPAIRS

- Defects due to detailing or fabrication errors: Report without delay.
- Methods of rectification: Obtain approval of proposals before starting modification or remedial work.
- Defective/damaged components: Timber members/ components may be rejected if the nature and/or number of defects would result in an excessive amount of site repair.

760 TEMPORARY BRACING

- Provision: As necessary to maintain structural timber components in position and to ensure complete stability during construction.

770 ADDITIONAL SUPPORTS

- Provision: Position and fix additional studs, noggings and/ or battens to support edges of sheets materials, and wall/ floor/ ceiling mounted appliances, fixtures, etc. shown on drawings
- Material properties: Additional studs, noggings and battens to be of adequate size and have the same treatment, if any, as adjacent timber supports.

775 BEARINGS

- Timber surfaces which are to transmit loads: Finished to ensure close contact over the whole of the designed bearing area.
- Packings: Where provided, to cover the whole of the designed bearing area.
 - Crushing strength: Not less than timber being supported.
 - In external or inaccessible locations: Rot and corrosion proof.

780 WALL PLATES

- Position and alignment: To give the correct span and level for trusses, joists, etc.
- Bedding: Fully in fresh mortar.
- Joints: At corners and elsewhere where joints are unavoidable use nailed half lap joints. Do not use short lengths of timber.

784 JOISTS GENERALLY

- Centres: Equal, and not exceeding designed spacing.
- Bowed joists: Installed with positive camber.
- End joists: Positioned approximately 50 mm from masonry walls.

795 TRIMMING OPENINGS

- Trimmers and trimming joists: When not specified otherwise, not less than 25 mm wider than general joists.

830 LATERAL RESTRAINT STRAPS TO LOUVBRE HOUSING

- Manufacturer: Catnic or similar approved.
 - Product reference: Submit proposals.
- Material/ finish: Galvanized steel.
- Size: Not less than 30 x 5 mm cross section, 150 mm cranked end and 2500mm long.
- Fixing: To top of joists/ rafters/ ties at not more than 1.2 m centres and as shown on drawings.
 - Ensure that cranked end is in tight contact with cavity face of wall inner leaf and is not pointing upwards.
- Straps spanning joists/ rafter/ ties running parallel to wall: Fix noggings and packs tightly beneath straps.
 - Size of noggings and packs: Not less than three quarters of joist/ rafter/ tie depth and not less than 38 mm thick.
 - Notching: Notch joists so that straps fit flush with surface. Do not notch rafters/ ties.
- Fasteners: Fixing and positioning to engineers details and spec.

850 INSPECTION GENERALLY

- Structural timber-work: Give reasonable notice before covering up.

H
Cladding/Covering

H10
Patent glazing

H10 Patent glazing

To be read with Preliminaries/ General conditions.

TYPES OF PATENT GLAZING

115A PATENT GLAZING SYSTEM

- Manufacturer: Lonsdale Metal Co Ltd.
 - Web: www.roofglazing.co.uk.
 - Email: info@lonsdalemetal.co.uk.
 - Product reference: ThermGard
- Type: ALM100/4.
- Glazing bar:
 - Finish and colour: Polyester powder coating, colour RAL White.
 - Film thickness (minimum): 40 microns.
 - Spacing: 600 mm.
 - Slope: 30° .
 - Bottom overhang lap: 75 mm.
- Infill: 28 mm low-e.
- Incorporated components: GlazaTherm Top hung opening rooflights with electric motors.

221 PRODUCT SAMPLES

- General: Before commencing detailed design, submit labelled samples of: patent glazing section .

231 FASTENER SAMPLES

- General: During detailed design, submit labelled samples of each type of fastener, with details of methods of adjustment and tolerances.

DESIGN/ PERFORMANCE REQUIREMENTS

311 REQUIREMENTS GENERALLY

- Extent of compliance: Entire patent glazing assembly, including flashings and junctions with adjacent parts of the building.
- Deflections and other movements: Make full allowance.

351 SURFACE SPREAD OF FLAME

- Standard: To BS 476-7.
 - Internal: Class Class 1 .
 - External: Class Class 1 .

352 REACTION TO FIRE

- Standard: To BS EN 13501-1.
 - Class B-s3, d2 or better.

361 WATER PENETRATION

- Requirement: Under site exposure conditions, water must not penetrate onto internal surfaces or into cavities not designed to be wetted.

371 HEAT CONSERVATION

- Average thermal transmittance (U-value) of patent glazing: 2.0 W/m²K .

381 CONDENSATION

- Requirement: Condensation must not form on internal surfaces of framing members or glazing/ infilling in the following conditions:
 - External air temperature: -5°C .
 - Internal air temperature: 20°C .
 - Internal relative humidity (maximum): 30% .

401 THERMAL SAFETY

- Glazing panes/ units: Must have adequate resistance to thermal stress generated by orientation, shading, solar control and construction.

411 ACOUSTIC PROPERTIES

- Sound transmittance: Minimum weighted sound reduction index (Rw) within 100 to 3150 Hz frequency range to BS 5821-3: 30 dB .
 - Location: As drawing P(301) .

421 SECURITY

- Fixings to patent glazing bars caps/ wings: Secured to prevent unauthorized removal.

FABRICATION AND INSTALLATION

510 WORKMANSHIP GENERALLY

- Standard: To BS 5516-1 and 2.
- Fixings: Concealed unless otherwise indicated on detailed drawings.
 - General requirements: As section Z20.
 - Material: Compatible with building component and substrate.
 - Metals: Isolate dissimilar metals to avoid electrolytic corrosion.
- Allowance for thermal and building movement: Where appropriate.
 - Movement joints: Do not bridge.
- Fabrication: Machine cut and drill components in the workshop wherever possible.
- Installation: Submit proposals before cutting and drilling into structure in positions other than shown on detailed design drawings.

520 GLASS

- Standards and product labels: To BS 952 and the relevant parts of:
 - BS EN 572 for basic soda lime silicate glass.
 - BS EN 1096 for coated glass.
 - BS EN 1863 for heat strengthened soda lime silicate glass.
 - BS EN 12150 for thermally toughened soda lime silicate glass.
 - BS EN 13024 for thermally toughened borosilicate glass.
 - BS EN ISO 12543 for laminated glass.
- Pane dimensions: Within ± 2 mm of nominal size.
- Glass quality: Clean and free from obvious scratches, bubbles, cracks, rippling, dimples and other defects.
- Glass edges: Generally undamaged. Shells and chips not more than 2 mm deep and extending not more than 5 mm across surface are acceptable if ground out.

580 PROTECTION AND FINAL CLEANING

- Cement and plaster based spillage: Remove whilst wet.
- Staining, scratching and other disfigurement of patent glazing: Prevent during installation and by following trades.
- Completion: At agreed time, remove protective coverings and thoroughly clean external and internal surfaces with mild detergent solutions approved by patent glazing manufacturer.

H62

Natural slating

H62 Natural slating

To be read with Preliminaries/ General conditions.

TYPES OF SLATING

105 ROOF SLATING EXISTING SLATE TO BE RE-USED IN ALL AREAS

- Substrate: Rafters at 600 mm centres.
- Pitch: As existing.
- Underlay: Vapour permeable underlay as clause 235.
 - Recycled content: None permitted.
 - Direction: Parallel to eaves.
 - Head-lap (minimum): 75 mm.
- Battens:
 - Size: 50 x 25 mm.
 - Fixing: 63 x 5 mm sherardized steel screws with plastic plugs.
- Slates:
 - Supplier: Submit proposals.
Product reference: Contractor's choice.
 - Type: Spanish blue-black.
 - Size: 405 x 205 mm.
 - Head-lap (minimum): 76 mm.
- Fixing: Two nails each slate.
- Accessories: None.

SLATING GENERALLY

210 BASIC WORKMANSHIP

- General: Fix slating and accessories to make the whole sound and weathertight at earliest opportunity.
- Setting out: To true lines and regular appearance, with neat fit at edges, junctions and features.
- Fixings for slating accessories: As recommended by manufacturer.
- Gutters and pipes: Keep free of debris. Clean out at completion.

220 REMOVING EXISTING SLATING

- General: Carefully remove slates, battens, underlay, etc. with minimum disturbance of adjacent retained slating.
- Undamaged slates: Set aside for reuse.

235A BREATHER MEMBRANE

- Manufacturer: Easy-Trim Roofing and Construction Products Ltd.
 - Web: www.easy-trim.co.uk.
 - Email: enquiries@easy-trim.co.uk.
 - Product reference: Master INTEGRATE

240 UNDERLAY

- Handling: Do not tear or puncture.
- Laying: Maintain consistent tautness.
- Vertical laps (minimum): 100 mm wide, coinciding with supports and securely fixed.
- Fixing: Galvanized steel, copper or aluminium 20 x 3 mm extra large clout head nails.
- Eaves: Where exposed, use an external grade (UV resistant) underlay or a proprietary eaves support product.
- Penetrations: Use proprietary underlay seals or cut underlay to give a watertight fit around pipes and components.
- Ventilation paths: Do not obstruct.

245 BATTENS/ COUNTERBATTENS - TREATED

- Timber: Sawn softwood.
 - Species: In accordance with BS 5534, clause 4.11.1.
 - Permissible characteristics and defects: Not to exceed limits in BS 5534, Annex D.
 - Grading: Fully factory pre-graded in accordance with BS 5534.
 - Moisture content at time of fixing and covering (maximum): 22%.
- Preservative treatment: As section Z12 and Wood Protection Association Commodity Specification C8.
 - Type: Micro-emulsion.

259 COUNTERBATTENS ON RAFTERS

- Fixing: Into rafters at not more than 300 mm centres.

265 BATTEN FIXING

- Setting out: Align parallel to ridge in straight horizontal lines to gauge of slates. Align on adjacent areas.
- Batten length (minimum): Sufficient to span over three supports.
- Joints in length: Square cut. Butt centrally on supports. Joints must not occur more than once in any group of four battens on one support.
- Additional battens: Provide where unsupported laps in underlay occur between battens.
- Fixing: Each batten to each support. Splay fix at joints in length.

275 SLATE FIXING

- Setting out: Lay slates with an even overall appearance with slightly open (maximum 5 mm) butt joints. Align tails.
- Slate thickness: Consistent in any one course. Lay with thicker end as tail.
- Ends of courses: Use extra wide slates to maintain bond and to ensure that cut slates are as large as possible. Do not use slates less than 150 mm wide.
- Top course: Head-nail short course to maintain gauge.
- Fixing: Centre nail each slate twice through countersunk holes 20-25 mm from side edges.
 - Nails: Copper clout to BS 1202-2 or aluminium clout to BS 1202-3.
 - Nail dimensions: Determine in accordance with BS 5534 to suit site exposure, withdrawal resistance and slate supplier's recommendations.

ROOF SLATING EDGES/ JUNCTIONS/ FEATURES

305 GENERALLY

- Fittings and accessories: As recommended by slate supplier, do not improvise.
 - Exposed fittings and accessories: To match slate colour and finish.
- Cut slates: Cut only where necessary, to give straight, clean edges.
- Flashings: Fix with or immediately after slating. Form neatly.

920 TOP EDGES

- Top slate courses: Fix under abutment and make weathertight with flashings dressed down not less than 150 mm.

930 SIDE ABUTMENTS

- Slating substrate work: Chase abutment wall and insert stepped flashing.
 - Flashing: Return not less than 75 mm behind slating, overlapping underlay and battens. Turn back to form a vertical welt.
- Abutment slates: Cut and fix neatly.

950 ANGLES WITH SOAKERS

- Angle slates: Cut extra wide slates and fix to form a straight, close mitred junction.
- Soakers: Interleave with angle slates. Fix by nailing to battens at top edge.

960 JUNCTION WITH ROOF VERGES

- Slating substrate work: Fix additional slating batten parallel to and below verges.
- Course end slates: Splay cut slate and a half width slates to angle of verge rake. Fix to additional slating batten with cut edge parallel to and below verge.

H71

Lead sheet coverings/ flashings

H71 Lead sheet coverings/ flashings

To be read with Preliminaries/ General conditions.

TYPES OF LEADWORK

200 GUTTER LINING

- Substrate: Plywood on rafters at 450 mm centres.
 - Preparation: Not required.
- Underlay: Needle punched nonwoven polyester geotextile.
- Type of lead: Rolled to BS EN 12588.
 - Thickness: 1.75 or 1.80 mm (Code 4).
- Pretreatment: Apply thin coating of patination oil to underside of lead and allow to dry before laying .
- Joints in direction of fall: -.
 - Spacing: On centre line of gutter.
- Cross joints: Wood cored roll at gutter watershed.
 - Spacing: 1500 mm.
- Outlets: Catchpit with overflow pipe.

420 COVER FLASHINGS TO GUTTER TO ROOFLIGHT

- Lead:
 - Thickness: 1.75 or 1.80 mm (Code 4).
- Dimensions:
 - Lengths: Not more than 1500 mm.
 - End to end joints: Laps of not less than 100 mm.
 - Cover: Overlap to upstand of not less than 75 mm.
- Fixing: Lead wedges into bed joint, clips to lead upstand at laps and 500 mm centres.

GENERAL REQUIREMENTS/ PREPARATORY WORK

510 WORKMANSHIP GENERALLY

- Standard: To BS 6915 and latest edition of 'Rolled lead sheet. The complete manual' published by the Lead Sheet Association.
- Fabrication and fixing: To provide a secure, free draining and completely weathertight installation.
- Operatives: Trained in the application of lead coverings/ flashings. Submit records of experience on request.
- Preforming: Measure, mark, cut and form lead prior to assembly wherever possible.
- Marking out: With pencil, chalk or crayon. Do not use scribes or other sharp instruments without approval.
- Bossing and forming: Straight and regular bends, leaving sheets free from ripples, kinks, buckling and cracks.
- Solder: Use only where specified.
- Sharp metal edges: Fold under or remove as work proceeds.
- Finished work: Fully supported, adequately fixed to resist wind uplift but also able to accommodate thermal movement without distortion or stress.
 - Protection: Prevent staining, discolouration and damage by subsequent works.

515 LEADWELDING

- In situ leadwelding: Not permitted.

- 520 LEAD SHEET
- Production method:
 - Rolled, to BS EN 12588, or
 - Machine cast and BBA certified, or
 - Sand cast, from lead free from bitumen, solder, other impurities, inclusions, laminations, cracks, air, pinholes and blowholes; to code thicknesses but with a tolerance (by weight) of $\pm 10\%$.
 - Identification: Labelled to show thickness/ code, weight and type.
- 555 LAYOUT
- Setting out of longitudinal and cross joints: Submit proposals.
- 610 SUITABILITY OF SUBSTRATES
- Condition: Dry and free of dust, debris, grease and other deleterious matter.
- 630A PLYWOOD UNDERLAY TO GUTTERS
- Standard: Manufactured to an approved national standard and to BS EN 636, section 8 (plywood for use in humid conditions).
 - Sheet size: 2400 or 1200 x 1200 mm and 6 mm thick.
 - Moisture content: Not more than 22% at time of covering. Give notice if greater than 16%.
 - Laying: Cross joints staggered and a 0.5 to 1 mm gap between boards.
 - Fixing: With 25 mm annular ringed shank copper or stainless steel nails, at 300 mm grid centres over the area of each sheet and at 150 mm centres along edges, set in 10 mm from perimeter edges.
 - Nail heads: Set flush or just below the surface.
- 640 TIMBER FOR USE WITH LEADWORK
- Quality: Planed, free from wane, pitch pockets, decay and insect attack (ambrosia beetle excepted).
 - Moisture content: Not more than 22% at time of fixing and covering. Give notice if greater than 16%.
 - Preservative treatment: Organic solvent as section Z12 and Wood Protection Association Commodity Specification C8.
- 645A GEOTEXTILES
- Manufacturer: Associated Lead Mills.
 - Web: www.associatedlead.co.uk.
 - Product reference: Geotec.
- 650 LAYING UNDERLAY
- Handling: Prevent tears and punctures.
 - Laying: Butt or overlap jointed onto a dry substrate.
 - Fixing edges: With copper or stainless steel staples or clout nails.
 - Do not lay over roof edges but do turn up at abutments.
 - Wood core rolls: Fixed over underlay.
 - Protection: Keep dry and cover with lead at the earliest opportunity.

FIXING LEAD

- 705 HEAD FIXING LEAD SHEET
- Top edge: Secured with two rows of fixings, 25 mm and 50 mm from top edge of sheet, at 75 mm centres in each row, evenly spaced and staggered.
 - Sheets less than 500 mm deep: May be secured with one row of fixings, 25 mm from top edge of sheet and evenly spaced at 50 mm centres.

710 FIXINGS

- Nails to timber substrates: Copper clout nails to BS 1202-2, or stainless steel (austenitic) clout nails to BS 1202-1.
 - Shank type: Annular ringed, helical threaded or serrated.
 - Shank diameter: Not less than 2.65 mm for light duty or 3.35 mm for heavy duty.
 - Length: Not less than 20 mm or equal to substrate thickness.
- Screws to concrete or masonry substrates: Brass or stainless steel to BS 1210, tables 3 or 4.
 - Diameter: Not less than 3.35 mm.
 - Length: Not less than 19 mm.
 - Washers and plastic plugs: Compatible with screws and lead.
- Screws to composite metal decks: Self tapping as recommended by the deck and lead manufacturer/ supplier for clips.

770 WEDGE FIXING INTO JOINTS/ CHASES

- Joint/ chase: Rake out to a depth of not less than 25 mm.
- Lead: Dress into joint/chase.
 - Fixing: Lead wedges at not more than 450 mm centres, at every change of direction and with at least two for each piece of lead.
- Sealant: Submit proposals.
 - Application: As section Z22.

JOINTING LEAD

810 FORMING DETAILS

- Method: Bossing or leadwelding except where bossing is specifically required.
- Leadwelded seams: Neatly and consistently formed.
 - Seams: Do not undercut or reduce sheet thickness.
 - Filler strips: Of the same composition as the sheets being joined.
 - Butt joints: Formed to a thickness one third more than the sheets being joined.
 - Lap joints: Formed with 25 mm laps and two loadings to the edge of the overlap.
- Bossing: Carried out without thinning, cutting or otherwise splitting the lead sheet.
 - Details where bossing must be used: Ends of hollow rolls at parapet walkway .

830 STANDING SEAM JOINTS

- Joint allowance: 100 mm overlap, 75 mm underlap and copper or stainless steel clips at not more than 750 mm centres.
- Forming joint: Welt overlap and clips around underlap, loosely turn over to form a standing seam of consistent cross section.

860 DRIPS WITH SPLASH LAPS

- Underlap: Dress into rebate along top edge of drip.
 - Fixing: One row of nails at 50 mm centres on centre line of rebate.
- Overlap: Dress over drip and form a 40 mm splash lap.

880 WELTED JOINTS

- Joint allowance: 50 mm overlap and 25 mm underlap.
- Copper or stainless steel clips: Fix to substrate at not more than 450 mm centres.
- Overlap: Welt around underlap and clips and lightly dress down.

970A PATINATION OIL

- Manufacturer: Associated Lead Mills.
 - Web: www.associatedlead.co.uk.
 - Product reference: Patination Oil

H72

Aluminium strip/ sheet coverings/ flashings

H72 Aluminium strip/ sheet coverings/ flashings

To be read with Preliminaries/ General conditions.

TYPES OF ALUMINIUM WORK

250 WEATHERING TO ALUMINIUM LOUVRES

- Substrate: Timber .
- Underlay: Needle punched nonwoven polyester geotextile.
- Aluminium: Coated sheet/ strip.
 - Alloy designation: Not applicable.
 - Temper: Not applicable.
 - Finish: Polyvinylidene fluoride (PVDF) coating.
 - Thickness: 1.0 mm.
- Joints: Single lock welt.
- Spacing: 2 m maximum.
- Edge details: Beaded drip at front, upstand at rear with tuck in.
- Fixing: Fixed clips at 450 mm centres.
- Accessories: Sleeves for balustrades.

GENERAL REQUIREMENTS/ PREPARATORY WORK

510 WORKMANSHIP GENERALLY

- Standard: Generally to CP 143-15.
- Fabrication and fixing: To provide a secure, free draining and completely weathertight installation.
- Operatives: Trained in the application of aluminium coverings/ flashings. Submit records of experience on request.
- Measuring, marking, cutting and forming: Prior to assembly wherever possible.
- Marking out: With pencil, chalk or crayon. Do not use scribes or other sharp instruments without approval.
- Folding: With mechanical or manual presses to give straight, regular and tight bends, leaving panels free from ripples, kinks, buckling and cracks. Use hand tools only for folding details that cannot be pressed.
- Surface protection: Fully coat surfaces to be embedded in concrete or mortar with high build bitumen based paint, after folding.
- Sharp metal edges: Fold under or remove as work proceeds.
- Joints: Do not use sealants to attain waterproofing.
- Finished aluminium work: Fully supported, adequately fixed to resist wind uplift and able to accommodate thermal movement without distortion or stress.
 - Protection: Prevent staining, discolouration and damage by subsequent works.

515 WELDING

- In situ welding: Not permitted.

560 CONTROL SAMPLES

- General: Complete areas of finished work and obtain approval of appearance before proceeding:
- Size: 300mm long.
- Location: Cover for base of louvres.

610 SUITABILITY OF SUBSTRATES

- Condition: Dry and free of dust, debris, grease and other deleterious matter.

- 620 PREPARATION OF EXISTING TIMBER SUBSTRATES
- Remedial work: Adjust boards to level and securely fix. Punch in any protruding fasteners and plane or sand to achieve an even surface.
 - Defective boards: Give notice.
 - Moisture content: Not more than 22% at time of covering.
- 630 PLYWOOD UNDERLAY
- Standard: Manufactured to an approved national standard and to BS EN 636, section 8 (plywood for use in humid conditions).
 - Sheet size: 2400 or 1200 x 1200 mm and 6 mm thick.
 - Laying: Parallel to perimeter edges with cross joints staggered and a 0.5 to 1 mm gap between sheets.
 - Fixing: With 25 mm annular ringed shank aluminium or galvanized steel nails, at 300 mm grid centres over the area of each sheet and at 150 mm centres along edges, set in 10 mm from perimeter edges and in pairs across joints.
 - Nail heads: Set flush with or just below surface.
- 640 TIMBER FOR USE WITH ALUMINIUM WORK
- Quality: Planed, free from wane, splits, pitch pockets, decay and insect attack (ambrosia beetle excepted).
 - Moisture content: Not more than 22% at time of fixing and covering.
 - Preservative treatment: Organic solvent as section Z12, and Wood Protection Association Commodity Specification C8.
- 645A NEEDLE PUNCHED NONWOVEN POLYESTER GEOTEXTILE UNDERLAY
- Manufacturer: Delta Membrane Systems Ltd.
 - Web: www.deltamembranes.com.
 - Email: info@deltamembranes.com.
 - Product reference: Delta-Trela.
- 650 LAYING UNDERLAY
- Handling: Prevent tears and punctures.
 - Laying: Butt jointed onto a dry substrate.
 - Fixing edges: With aluminium or galvanized steel staples or 20 x 3 mm extra large head clout nails.
 - Do not lay over eaves and drip/ step aluminium underlaps.
 - Ventilation paths: Do not obstruct.
 - Protection: Keep dry and cover with aluminium at the earliest opportunity.

FIXING

- 710 FIXINGS FOR CLIPS
- Nails to timber substrates: Aluminium to BS 1202-3 for aluminium clips. Stainless steel (austenitic) for stainless steel clips.
 - Shank type: Annular ringed or helical threaded.
 - Shank diameter: Not less than 2.65 mm.
 - Head: Flat.
 - Length: Not less than 25 mm or equal to substrate thickness.
 - Screws to concrete/ masonry substrates: Sherardized or zinc plated steel or aluminium, for aluminium clips, to BS EN 14592. Stainless steel (austenitic) to BS EN 14592 for stainless steel clips.
 - Diameter: Not less than 3.35 mm.
 - Length: Not less than 25 mm.
 - Washers and plastic plugs: Compatible with screws.
 - Screws to composite metal decks: Self tapping, as recommended by the deck and aluminium manufacturer/ supplier for aluminium or stainless steel clips.

760 CONTINUOUS CLIPS

- Material: Cut from same alloy and thickness as that being secured.
- Dimensions:
 - Width: Sufficient to suit detail.
 - Length: Not more than 1.8 m.
- Fixing: To substrate at 150 mm centres. Welt edge of strip/ sheet being fixed to continuous clip and dress down.

JOINTING

810 FORMING DETAILS

- Folds and welts: Form without thinning or splitting the strip/ sheet.
- Thermal movement: Form details with appropriate allowance for movement, without impairment of security at full expansion or contraction.

860 DRIP/ STEP JOINTS

- Strip/ Sheet from below step: Fold up full height of upstand and fix to top edge.
- Form aluminium underlap/ continuous clip:
 - Cover to roof slope: Not less than 100 mm with anticapillary welt at top edge.
 - Projection: 25 mm for forming into drip welt.
 - Downstand: Not less than 40 mm with welt at bottom edge.
 - Fixing: To roof slope at 100 mm centres, avoiding through fixings at longitudinal joint positions.
- Strip/ Sheet from above step: Fold around underlap projection and single welt to form a drip.

K

Linings/Sheathing/Dry partitioning

K10

Gypsum board dry linings/ partitions/ ceilings

K10 Gypsum board dry linings/ partitions/ ceilings

To be read with Preliminaries/ General conditions.

TYPES OF DRY LINING

- 205 LINING ON TIMBER STUDDING TO BASE OF LOUVRE HOUSING
- Background: 100mm x 50mm studs at 400mm centres.
 - Metal resilient (acoustic) bars: Not required.
 - Linings: 12.5 mm plasterboard.
 - Fixing: Screws.
 - Finishing: Skim coat plaster.
 - Primer/ Sealer: As recommended by board manufacturer for vapour control.
 - Accessories: Metal beads/ stops recommended by board manufacturer .
 - Other requirements: None.

COMPONENTS

- 400 GYPSUM BOARDS GENERALLY
- Standard:
 - Gypsum plasterboard to BS EN 520.
 - Gypsum fibre board to BS EN 15283-2.
 - Evidence of compliance: All sheets to be CE marked. Submit Declaration of Performance (DoP).
- 402 GYPSUM PLASTERBOARD (VAPOUR CONTROL)
- Type: To BS EN 520, type A.
 - Core density (minimum): 650 kg/m³.
 - Reaction to fire: Manufacturer's standard.
 - Water vapour resistance factor: Manufacturer's standard.
 - Thermal conductivity: Manufacturer's standard.
 - Other BS EN 520 characteristics: None.
 - Recycled content: Contractor's choice.
 - Moisture vapour resistance of backing layer (minimum): 60 MNs/g.
 - Exposed surface and edge profiles: Clean and undamaged.

INSTALLATION

- 435 DRY LININGS GENERALLY
- General: Use fixing, jointing, sealing and finishing materials, components and installation methods recommended by board manufacturer.
 - Cutting gypsum boards: Neatly and accurately without damaging core or tearing paper facing.
 - Cut edges: Minimize and position at internal angles wherever possible. Mask with bound edges of adjacent boards at external corners.
 - Fixings boards: Securely and firmly to suitably prepared and accurately levelled backgrounds.
 - Finishing: Neatly to give flush, smooth, flat surfaces free from bowing and abrupt changes of level.

505 INSTALLING MINERAL WOOL INSULATION

- Fitting insulation: Closely butted joints and no gaps. Use fasteners to prevent slumping or displacement.
- Services:
 - Electrical cables overlaid by insulation: Sized accordingly.
 - Ceilings: Cut insulation around electrical fittings, etc.

560 JOINTS BETWEEN BOARDS

- Tapered edged gypsum boards:
 - Bound edges: Lightly butted.
 - Cut/ unbound edges: 3 mm gap.
- Square edged plasterboards: 3 mm gap.
- Square edged gypsum fibre boards: 5 mm gap.

565 VERTICAL JOINTS

- Joints: Centre on studs.
 - Partitions: Stagger joints on opposite sides of studs.
 - Two layer boarding: Stagger joints between layers.

570 HORIZONTAL JOINTS

- Surfaces exposed to view: Horizontal joints not permitted. Seek instructions where height of partition/ lining exceeds maximum available length of board.
- Two layer boarding: Stagger joints between layers by at least 600 mm.
- Edges of boards: Support using additional framing.
 - Two layer boarding: Support edges of outer layer.

590 FIXING GYPSUM BOARD TO METAL FRAMING/ FURRINGS

- Partitions/ Wall linings: Fix securely and firmly at the following centres (maximum):
 - Single layer boarding: To all framing at 300 mm centres. Reduce to 200 mm centres at external angles.
 - Multi-layer boarding: Face layer at 300 mm centres, and previous layers around perimeters at 300 mm centres.
- Ceilings: 230 mm. Reduce to 150 mm at board ends and at lining perimeters.
- Position of screws from edges of boards (minimum): 10 mm.
 - Screw heads: Set in a depression. Do not break paper or gypsum core.

610 FIXING GYPSUM BOARD TO TIMBER

- Fixing to timber: Securely at the following centres (maximum):
 - Nails: 150 mm.
 - Screws to partitions/ wall linings: 300 mm. Reduce to 200 mm at external angles.
 - Screws to ceilings: 230 mm.
- Position of nails/ screws from edges of boards (minimum):
 - Bound edges: 10 mm.
 - Cut/ unbound edges: 13 mm.
- Position of nails/ screws from edges of timber supports (minimum): 6 mm.

FINISHING

680 SKIM COAT PLASTER FINISH

- Plaster type As recommended by board manufacturer..
 - Thickness: 2-3 mm.
- Joints: Fill and tape except where coincident with metal beads.
- Finish: Tight, matt, smooth surface with no hollows, abrupt changes of level or trowel marks.

692 RIGID BEADS/STOPS

- Internal: To BS EN 13658-1.
- External: To BS EN 13658-2.

695 INSTALLING BEADS/ STOPS

- Cutting: Neatly using mitres at return angles.
- Fixing: Securely using longest possible lengths, plumb, square and true to line and level, ensuring full contact of wings with substrate.
- Finishing: After joint compounds/ plasters have been applied, remove surplus material while still wet from surfaces of beads exposed to view.

L

Windows/Doors/Stairs

L10

Windows/ Rooflights/ Screens/ Louvres

L10 Windows/ Rooflights/ Screens/ Louvres

To be read with Preliminaries/ General conditions.

GENERAL

110 EVIDENCE OF PERFORMANCE

- Certification: Provide independently certified evidence that all incorporated components comply with specified performance requirements.

115 TIMBER PROCUREMENT

- Timber (including timber for wood based products): Obtained from well managed forests and/ or plantations in accordance with:
 - The laws governing forest management in the producer country or countries.
 - International agreements such as the Convention on International Trade in Endangered Species of wild fauna and flora (CITES).
- Documentation: Provide either:
 - Documentary evidence (which has been or can be independently verified) regarding the provenance of all timber supplied.
 - Evidence that suppliers have adopted and are implementing a formal environmental purchasing policy for timber and wood based products.
- Certification scheme: UK Timber Procurement Policy Category A evidence certification scheme.
 - Other evidence: UK Timber procurement policy Category B evidence: Completed supply chain information within attached proforma ???.

120 SITE DIMENSIONS

- Procedure: Before starting work on designated items take site dimensions, record on shop drawings and use to ensure accurate fabrication.
- Designated items: Aluminium Louvre lining.

140 CONTROL SAMPLES

- Procedure:
 - Finalise component details.
 - Fabricate one of each of the following designated items as part of the quantity required for the project.
 - Obtain approval of appearance and quality before proceeding with manufacturer of the remaining quantity.
- Designated items: Aluminium louvre.

PRODUCTS

460A ROOFLIGHTS TO MAIN ROOF

- Manufacturer: Velux Company Ltd
Woodside Way
Glenrothes
Fife Scotland
KY7 4ND
Tel: 01592 778225 or similar approved.
 - Product reference: Conservation roof window MK08 .
- Type: Flat.
- Frame: Aluminium.
 - Finish: Powder coated.
 - Colour: Black.
- Kerb: None - in roof.
- Thermal performance (U-value maximum): 1.2 W/m²K.
- Fire performance (minimum): Not applicable.
- Glazing details: Double skin .
- Other requirements: Electrical opening.
- Fixing: With all manufacturers flashings and soakers into existing slate roof.

560B GLAZED SCREEN SYSTEM TO LIFT LOBBY ON 4th FLOOR

- Manufacturer: Promat UK Ltd.
 - Web: www.promat.co.uk.
 - Email: behindthewall@etexgroup.com.
 - Product reference: SYSTEMGLAS SF1
- Screen height: 3100mm.
- Fire resistance rating of whole system: 90 minutes.
- Sound insulation rating: None.
- Glazing details: Type 1.
 - Finish: Clear.
- Incorporated features: Manifestation as required.
- Accessories/ Other requirements: Fire rated self closing door and frame to match screen details.
- Installation: To specialist detail and spec.

650A LOUVRES

- Manufacturer: Construction Specialties (UK) Ltd.
 - Web: www.c-sgroup.co.uk.
 - Email: info@c-sgroup.co.uk.
 - Product reference: CS Ventilation Louvre A-4080
- Size: As drawings.
- Material / Finish: Zero VOC fluoro-polymer powder coat - consult Construction Specialties for range of available colours.
- Guards: Insect mesh.
- Blanking Plates: Not required.
- Louvred Doors: Not required.

EXECUTION

710 PROTECTION OF COMPONENTS

- General: Do not deliver to site components that cannot be installed immediately or placed in clean, dry floored and covered storage.
- Stored components: Stack vertical or near vertical on level bearers, separated with spacers to prevent damage by and to projecting ironmongery, beads, etc.

730 PRIMING/ SEALING

- Wood surfaces inaccessible after installation: Prime or seal as specified before fixing components.

750 BUILDING IN

- General: Not permitted unless indicated on drawings.
 - Brace and protect components to prevent distortion and damage during construction of adjacent structure.

782 FIXING OF ALUMINIUM FRAMES

- Standard: As section Z20.
- Fasteners: Stainless steel wood screws.
 - Spacing: When not predrilled or specified otherwise, position fasteners not more than 250 mm from ends of each jamb, adjacent to each hanging point of opening lights, and at maximum 600 mm centres.

810A SEALANT

- Manufacturer: Adshead Ratcliffe & Co Ltd.
 - Web: www.arbo.co.uk.
 - Email: arbo@arbo.co.uk.
 - Product reference: Arbokol 1000
- Colour: Black.
- Accessories: Joint backing: Closed cell foam polyethylene rod.

820 IRONMONGERY

- Fixing: In accordance with any third party certification conditions applicable. Assemble and fix carefully and accurately using fasteners with matching finish supplied by ironmongery manufacturer. Do not damage ironmongery and adjacent surfaces.
- Checking/ Adjusting/ Lubricating: Carry out at Completion and ensure correct functioning.

L20

Doors/ shutters/ hatches

L20 Doors/ shutters/ hatches

To be read with Preliminaries/ General conditions.

GENERAL

110 EVIDENCE OF PERFORMANCE

- Certification: Provide independently certified evidence that all incorporated components comply with specified performance requirements.

112 TIMBER PROCUREMENT

- Timber (including timber for wood-based products): Obtained from well-managed forests and/ or plantations in accordance with:
 - The laws governing forest management in the producer country or countries.
 - International agreements such as the Convention on International Trade in Endangered Species of wild fauna and flora (CITES).
- Documentation: Provide either:
 - Documentary evidence (which has been or can be independently verified) regarding the provenance of all timber supplied.
 - Evidence that suppliers have adopted and are implementing a formal environmental purchasing policy for timber and wood-based products.
- Certification scheme: UK Timber procurement policy Category A evidence certification scheme..
 - Other evidence: None.

115 FIRE RESISTING DOORS/ DOOR ASSEMBLIES/ DOORSETS

- Door products: As defined in BS EN 12519.
- Evidence of fire performance: Provide certified evidence, in the form of a product conformity certificate, directly relevant fire test report or engineering assessment, that each door/ door assembly/ doorset supplied will comply with the specified requirements for fire or smoke resistance if tested to BS 476-22, BS EN 1634-1 or BS EN 1634-3. Such certification must cover door and frame materials, glass and glazing materials and their installation, essential and ancillary ironmongery, hinges and seals.
- Components, assemblies or sets will be marked to the relevant product standard and/ or third party certification rating.

150 SITE DIMENSIONS

- Procedure: Before starting work on designated items take site dimensions, record on shop drawings and use to ensure accurate fabrication.
- Designated items: Existing door opening top of stairs 4th floor.

PRODUCTS

280 DOORS FLUSH FIRE DOOR

- Manufacturer: Premdor, Birtwaite Business Park, Huddersfield Road, Darton, Barnsley S75 5SJ
Tel: 0844 209 0008 or similar approved.
 - Product reference: Portfolio Code 71311.
- Finish as delivered: Laminated .
- Glazing/ Infill details: Existing frame.
 - Manifestation: Not required.
 - Beading: Not required.
- Ironmongery: As ironmongery schedule.
- Thermal performance (U-value maximum): Manufacturer's standard.
- Other requirements: FD60.

EXECUTION

710 PROTECTION OF COMPONENTS

- General: Do not deliver to site components that cannot be installed immediately or placed in clean, dry, floored and covered storage.
- Stored components: Stacked on level bearers, separated with spacers to prevent damage by and to projecting ironmongery, beads, etc.

730 PRIMING/ SEALING

- Wood surfaces inaccessible after installation: Primed or sealed as specified before fixing components.

750 FIXING DOORSETS

- Timing: After associated rooms have been made weathertight and the work of wet trades is finished and dried out.

770 DAMP PROOF COURSES ASSOCIATED WITH BUILT IN WOOD FRAMES

- Method of fixing: To backs of frames using galvanized clout nails.

780 DAMP PROOF COURSES IN PREPARED OPENINGS

- Location: Correctly positioned in relation to door frames. Do not displace during fixing operations.

820A SEALANT

- Manufacturer: Adshead Ratcliffe & Co Ltd.
 - Web: www.arbo.co.uk.
 - Email: arbo@arbo.co.uk.
 - Product reference: Arbokol 1000
- Colour: Black.
- Accessories: Joint backing: Closed cell foam polyethylene rod.

830 FIXING IRONMONGERY GENERALLY

- Fasteners: Supplied by ironmongery manufacturer.
 - Finish/ Corrosion resistance: To match ironmongery.
- Holes for components: No larger than required for satisfactory fit/ operation.
- Adjacent surfaces: Undamaged.
- Moving parts: Adjusted, lubricated and functioning correctly at completion.

840 FIXING IRONMONGERY TO FIRE RESISTING DOOR ASSEMBLIES

- General: All items fixed in accordance with door leaf manufacturer's recommendations ensuring that integrity of the assembly, as established by testing, is not compromised.
- Holes for through fixings and components: Accurately cut.
 - Clearances: Not more than 8 mm unless protected by intumescent paste or similar.
 - Lock/ Latch cases for fire doors requiring $\geq$ 60 minutes integrity performance: Coated with intumescent paint or paste before installation.

850 LOCATION OF HINGES

- Primary hinges: Where not specified otherwise, positioned with centre lines 250 mm from top and bottom of door leaf.
- Third hinge: Where specified, positioned on centre line of door leaf .
- Hinges for fire resisting doors: Positioned in accordance with door leaf manufacturer's recommendations.

860 INSTALLATION OF EMERGENCY EXIT DEVICES

- Standard: Unless specified otherwise, install panic bolts/ latches in accordance with BS EN 1125.

L30

Stairs/ ladders/ walkways/ handrails/ balustrades

L30 Stairs/ ladders/ walkways/ handrails/ balustrades

To be read with Preliminaries/ General conditions.

PRELIMINARY INFORMATION/ REQUIREMENTS

130 SITE DIMENSIONS

- Procedure: Before starting work on designated items take site dimensions, record on shop drawings and use to ensure accurate fabrication.
 - Designated items: Uncaged fixed access ladder.

COMPONENTS

310A PROPRIETARY ROOF ACCESS HATCH

- Manufacturer: Bilco UK Ltd
Park Farm Business centre
Foenham St Genevieve,
Bury St Edmunds,
Suffock
IP28 6TS or similar approved
Tel: .
 - Product reference: Type E-50TB Roof Access Hatch.
- Component material, finish as delivered and light reflectance value contrast where applicable:

410A ACCESS LADDERS TO PLANT ON ROOF

- Manufacturer: Eurosafe Solutions Ltd.
 - Web: www.eurosafesolutions.com.
 - Email: infouk@eurosafesolutions.com.
 - Product reference: Ascent Ladders
- Height (to clear): Allow 5500mm.
- Material: Galvanised Mild Steel.
- Fixing background: To base, head and foot.
- Platform: Not required, step-through.
- Step down: Not required.
- Finish: Galvanised.

INSTALLATION

640 INSTALLATION GENERALLY

- Fasteners and methods of fixing: To section Z20.
- Structural members: Do not modify, cut, notch or make holes in structural members, except as indicated on drawings.
- Temporary support: Do not use stairs, walkways or balustrades as temporary support or strutting for other work.
- Applied finishes: Substrates to be even, dry, sound and free from contaminants. Make good substrate surfaces and prepare/ prime as finish manufacturer's recommendation before application.

L40

General glazing

L40 General glazing

To be read with Preliminaries/ General conditions.

GENERAL REQUIREMENTS

- 110 PREGLAZING
- Preglazing of components: Not permitted.
- 111 PREGLAZING
- Preglazing of components: Permitted.
 - Prevention of displacement: Submit details of precautions to be taken to protect glazing and compound/ seals during delivery and installation.
 - Defective/ displaced glazing/ compound/ seals: Reglaze components in situ.
- 150 WORKMANSHIP AND POSITIONING GENERALLY
- Glazing generally: In accordance with BS 6262 series.
 - Integrity: Glazing must be wind and watertight under all conditions with full allowance made for deflections and other movements.
 - Dimensional tolerances: Panes/ sheets to be within ± 2 mm of specified dimensions.
 - Materials:
 - Compatibility: Glass/ plastics, surround materials, sealers, primers and paints/ clear finishes to be used together to be compatible. Avoid contact between glazing panes/ units and alkaline materials such as cement and lime.
 - Protection: Keep materials dry until fixed. Protect insulating glass units and plastics glazing sheets from the sun and other heat sources.
- 152 PREPARATION
- Surrounds, rebates, grooves and beads: Clean and prepare before installing glazing; ensure compliance with any certified installation requirements.
- 155 GLASS GENERALLY
- Standards: To BS 952 and relevant parts of:
 - BS EN 572 for basic soda lime silicate glass.
 - BS EN 1096 for coated glass.
 - BS EN 1748-1 for borosilicate glass.
 - BS EN 1748-2 for ceramic glass.
 - BS EN 1863 for heat strengthened soda lime silicate glass.
 - BS EN 12150 for thermally toughened soda lime silicate safety glass.
 - BS EN 12337 for chemically strengthened soda lime silicate glass.
 - BS EN 13024 for thermally toughened borosilicate safety glass.
 - BS EN ISO 12543 for laminated glass and laminated safety glass.
 - Panes/ sheets: Clean and free from obvious scratches, bubbles, cracks, rippling, dimples and other defects.
 - Edges: Generally undamaged. Shells and chips not more than 2 mm deep and extending not more than 5 mm across the surface are acceptable if ground out.
- 170 PLASTICS GLAZING SHEET
- Condition: Free from scratches, edge splits and other defects.
 - Preparation for use: Protective coverings carefully peeled back from edges and trimmed off to facilitate glazing. Remainder retained in place until completion unless instructed otherwise.

TYPES OF GLAZING

210 PUTTY FRONTED SINGLE GLAZING TO REPLACEMENT GLAZING

- Pane material: 4 mm rough cast glass.
- Surround: Softwood.
 - Sealer: Sealant primer.
- Type of putty: Linseed oil.
- Thermal performance (U-value maximum): Unrated.
- Glass installation:
 - Glass: Located centrally in surround using setting and location blocks, and secured with glazing sprigs/ cleats/ clips at 300 mm centres.
 - Finished thickness of back bedding after inserting glazing (minimum): 1.5 mm.
 - Front putty: Finished to a smooth, neat triangular profile stopping 2 mm short of sight line. Surface lightly brushed to seal putty to glass and left smooth with no brush marks.
- Sealing putty: Seal as soon as sufficiently hard but not within 7 days of glazing. Within 28 days apply either:
 - The full final finish, suitably protected until completion and cleaned down and made good as necessary, or
 - Two coats of primer applied locally to the compound, to be followed nearer completion with the full specified finish.
- Opening lights: Keep in closed position until putty has set sufficiently to prevent displacement of glazing when opened.

N

Furniture/Equipment

N16

Bird and vermin control systems

N16 Bird and vermin control systems

To be read with Preliminaries/ General conditions.

GENERAL

130 INSECT CONTROL FLY NETTING TO REAR OF LOUVRES

- Species: Winged insects.
- System manufacturer: Mesh Direct
Unit B5 Fraylings Business Park
Stoke on Trent
ST6 4LN
tel: 01782 820970 or similar approved
Product: Fly Screen Black Plastic.
Detection: None.
- Prevention: Mesh screens.
- Elimination: None.
- Other requirements: None.

FABRICATION

505 FABRICATION GENERALLY

- Design: Complete detailed design of items specified in this sub-section and obtain approval prior to commencing fabrication.
- Shop drawings: Submit.
- Structural calculations: Submit.
- Frameworks: Assemble and brace, including temporary members required for installation.
- Contact between dissimilar metals: Avoid.
- Temporary support: Do not subject members to non-design loadings.

EXECUTION

610 WORKMANSHIP GENERALLY

- Preparation:
 - Water supplies: Do not contaminate.
 - Existing building services and components: Protect, and leave undamaged.
- Timing: Coordinate with other related trades.
- Damaged building components: Obtain instructions.
- Contaminants: Remove and leave affected area clean.
- Coatings:
 - Suitability of substrates: Sufficiently dry and sound, to suit coatings.
 - Preparation and application: As section M60, and in accordance with BS 6150.
- Fasteners and adhesives: As section Z20.
 - Material: Compatible with building components and substrate.
 - Metals: Isolate dissimilar metals to avoid electrolytic corrosion.
- Thermal and building movement: Allow for, where appropriate.
 - Movement joints: Do not bridge.
- Roost inhibitors, nets and mesh screens: Correctly fitted and tensioned.

P

Building fabric sundries

P10

Sundry insulation/ proofing work

P10 Sundry insulation/ proofing work

SUNDRY INSULATION/ PROOFING WORK

To be read with Preliminaries/ General conditions.

TYPES OF INSULATION

- 190A INSULATION FITTED BETWEEN STUDS TO BASE OF LOUVRES
- Manufacturer: Rookwool Ltd
Pencoed Bridgend
CF35 6NY
Tel: 01656 862621 or similar approved.
 - Product reference: Rockwool RW Slab.
 - Material: Mineral wool to BS EN 13162.
 - Facing: Paper.
 - Recycled content: Contractor's choice.
 - Thickness: 100 mm.
 - Installation requirements:
 - Joints: Butted, no gaps.
 - Fasteners: Use where necessary to retain insulation and/ or prevent slumping.
- 310A VAPOUR CONTROL LAYER
- Manufacturer: Visqueen Building Products.
 - Web: www.visqueenbuilding.co.uk.
 - Email: riba@visqueenbuilding.co.uk.
 - Product reference: Visqueen Vapour Barrier
 - Accessories: Double-sided bonding tape.

P20

Unframed isolated trims/ skirtings/ sundry items

P20 Unframed isolated trims/ skirtings/ sundry items

To be read with Preliminaries/ General conditions

110A SOFTWOOD STUDDING TO BASE OF LOUVRE HOUSING

- Quality of wood and fixing: To BS 1186-3.
 - Species: European redwood.
 - Class: CSH.
- Moisture content at time of fixing: 9-13%.
- Preservative treatment: Water-based microemulsion as section Z12, service life 30 years.
- Fire rating: Not applicable.
- Profile: 100mm x 50mm frame at 600mm centres.
 - Finished size: 100mm x 50mm.
- Finish as delivered: sawn cut.
- Fixing: Screwed at 600mm centres.

110B SOFTWOOD FILLETS AND NOGGINS

- Quality of wood and fixing: To BS 1186-3.
 - Species: European redwood.
 - Class: CSH.
- Moisture content at time of fixing: 9-13%.
- Preservative treatment: Water-based microemulsion as section Z12, service life 30 years.
- Fire rating: Not applicable.
- Profile: 100mm x 50mm / 25mm X 25mm .
 - Finished size: 100mm x 50mm / 25mm x 25mm.
- Finish as delivered: sawn cut.
- Fixing: Screwed at 600mm centres.

110C SOFTWOOD ROOFING BATTENS

- Quality of wood and fixing: To BS 1186-3.
 - Species: European redwood.
 - Class: CSH.
- Moisture content at time of fixing: 9-13%.
- Preservative treatment: Water-based microemulsion as section Z12, service life 30 years.
- Fire rating: Not applicable.
- Profile: 35mm x 50mm.
 - Finished size: 35mm x 50mm.
- Finish as delivered: sawn cut.
- Fixing: Screwed at 600mm centres.

150 METAL CAPPING TO STUD WALL TO SUPPORT LOUVRES

- Material: Aluminium .
 - Thickness: As drawing 2mm.
- Finish: Polyester powder coating.
- Fixing: Plugged and screwed.
- Metalwork: As section Z11.

240A PLYWOOD LINING TO TIMBER BASE TO LOUVRES

- Manufacturer: Hanson Plywood Ltd.
 - Web: www.hanson-plywood.co.uk.
 - Email: panels@hanson-plywood.co.uk.
 - Product reference: Hanson Birch Plywood - Exterior
- Grade: B/BB.
- Board size: 1220 x 2440 mm.
- Thickness: 18 mm.

EXECUTION

510 INSTALLATION GENERALLY

- Joinery workmanship: As section Z10.
- Metal workmanship: As section Z11.
- Methods of fixing and fasteners: As section Z20 where not specified.
- Straight runs: To be in one piece, or in long lengths with as few joints as possible.
- Running joints: Location and method of forming to be agreed where not detailed.
- Joints at angles: Mitre, unless shown otherwise.
- Position and level: To be agreed where not detailed.

P21

Door/ window ironmongery

P21 Door/ window ironmongery

To be read with Preliminaries/ General conditions.

PRE-TENDER

10 QUANTITIES AND LOCATIONS

- Quantities and locations of ironmongery are given in the schedules .
- Fixing: As sections L10 and L20.

GENERAL

121 IRONMONGERY FROM SINGLE PROPRIETARY RANGE

- Manufacturer: rb Architectural Hardware or similar approved .
 - Product reference: Submit proposals .
- Principal material/ finish: Satin stainless steel, grade 1.4401 (316) .
- Items unavailable within selected range: Submit proposals.

141 SAMPLE BOARDS

- General: Before placing orders with suppliers submit a sample board, containing labelled samples of ironmongery and showing methods of fixing.
- Range: Include All items .
 - Conformity: Retain board on site in an approved location for the duration of the contract. Ensure conformity of ironmongery as delivered with labelled samples.

170 IRONMONGERY FOR FIRE DOORS

- Relevant products: Ironmongery fixed to, or morticed into, the component parts of a fire resisting door assembly.
- Compliance: Ironmongery included in successful tests to BS 476-22 or BS EN 1634-1 on door assemblies similar to those proposed.
 - Certification: Submit CERTIFIRE certificates .
- Melting point of components (except decorative non functional parts): 800°C minimum.

R

Disposal systems

R10

Rainwater drainage systems

R10 Rainwater drainage systems

To be read with Preliminaries/ General conditions.

GENERAL

SYSTEM PERFORMANCE

- 221 COLLECTION AND DISTRIBUTION OF RAINWATER
- General: Complete, and without leakage or noise nuisance.

PRODUCTS

- 370A ALUMINIUM PIPEWORK
- Manufacturer: Alumasc Exterior Building Products Ltd.
 - Web: www.alumasc-exteriors.co.uk.
 - Email: info@alumasc-exteriors.co.uk.
 - Product reference: CP25 Flushjoint 63 mm round pipework
 - System colour/ finish: Powder coat, RAL 9017m Black.
 - Pipes: CP25/3MA, length 3000 mm.
 - Fittings:
 - Bends: CP25/B/135A, 135° bend.
 - Branches: Not required.
 - Access pipe: Not required.
 - Offset (two part): Not required.
 - Shoe: Not required.
 - Pipe clips: RW1/236 standard pipe clip.

EXECUTION

- 600 PREPARATION
- Work to be completed before commencing work specified in this section:
 - Below ground drainage. Alternatively, make temporary arrangements for dispersal of rainwater without damage or disfigurement of the building fabric and surroundings.
 - Painting of surfaces which will be concealed or inaccessible.
- 605 INSTALLATION GENERALLY
- Electrolytic corrosion: Avoid contact between dissimilar metals where corrosion may occur.
 - Plastics and galvanized steel pipes: Do not bend.
 - Allowance for thermal and building movement: Provide and maintain clearance as fixing and jointing proceeds.
 - Protection:
 - Fit purpose made temporary caps to prevent ingress of debris.
 - Fit access covers, cleaning eyes and blanking plates as the work proceeds.
- 610 FIXING AND JOINTING GUTTERS
- Joints: Watertight.
 - Brackets: Securely fixed.
 - Fixings: Plugged and screwed into masonry.
 - Fixing centres: 1200 mm.
 - Additional brackets: Where necessary to maintain support and stability, provide at joints in gutters and near angles and outlets.
 - Roofing underlay: Dressed into gutter.

635 FIXING PIPEWORK

- Pipework: Fix securely, plumb and/ or true to line.
- Branches and low gradient sections: Fix with uniform and adequate falls to drain efficiently.
- Externally socketed pipes and fittings: Fix with sockets facing upstream.
- Additional supports: Provide as necessary to support junctions and changes in direction.
- Vertical pipes:
 - Provide a loadbearing support at least at every storey level.
 - Tighten fixings as work proceeds so that every storey is self supporting.
 - Wedge joints in unsealed metal pipes to prevent rattling.
- Wall and floor penetrations: Isolate pipework from structure.
 - Pipe sleeves: As section P31.
 - Masking plates: Fix at penetrations if visible in the finished work.
- Expansion joint pipe sockets: Fix rigidly to buildings. Elsewhere, provide brackets and fixings that allow pipes to slide.

640 FIXING VERTICAL PIPEWORK

- Bracket fixings: Bolted into masonry.
- Distance between bracket fixing centres (maximum): 1200 mm.

650 JOINTING PIPEWORK AND GUTTERS

- General: Joint with materials and fittings that will make effective and durable connections.
- Jointing differing pipework and gutter systems: Use adaptors intended for the purpose.
- Cut ends of pipes and gutters: Clean and square. Remove burrs and swarf. Chamfer pipe ends before inserting into ring seal sockets.
- Jointing or mating surfaces: Clean and, where necessary, lubricate immediately before assembly.
- Junctions: Form with fittings intended for the purpose.
- Jointing material: Strike off flush. Do not allow it to project into bore of pipes and fittings.
- Surplus flux, solvent jointing materials and cement: Remove.

655 JOINTING INTERNAL PIPEWORK

- Jointing: Solvent welded.

660 JOINTING EXTERNAL PIPEWORK

- Jointing: Solvent welded.

680 FIXING INSULATION TO INTERNAL PIPELINES AND GUTTERS

- Fixing: Secure and neat. Provide continuity at supports and leave no gaps. Fix split pipe insulation with the split on 'blind' side of pipeline.
 - Method: Mechanical fasteners.
- Timing: Do not fit insulation until completion of pipe airtightness or leakage testing.

685 IDENTIFICATION OF INTERNAL RAINWATER PIPEWORK

- Standard: In accordance with Water Regulations Advisory Scheme (WRAS) Information and guidance note 9-02-05 and BS 8515.

690 ELECTRICAL CONTINUITY - PIPEWORK

- Joints in metal pipes with flexible couplings: Clips (or suitable standard pipe couplings) supplied for earth bonding by pipework manufacturer to ensure electrical continuity.

700 ACCESS FOR TESTING AND MAINTENANCE

- General: Install pipework and gutters with adequate clearance to permit testing, cleaning and maintenance, including painting where necessary.
- Access fittings and rodding eyes: Position so that they are not obstructed.

COMPLETION

900 TESTING GENERALLY

- Dates for testing: Give notice.
 - Period of notice (minimum): 1 Week.
- Preparation:
 - Pipework: Complete, securely fixed, free from defects, obstruction and debris before testing.
- Testing:
 - Supply clean water, assistance and apparatus.
 - Do not use smoke to trace leaks.
- Records: Submit a record of tests.

905 INTERNAL PIPEWORK TEST - ENGLAND, WALES, IRELAND AND NORTHERN IRELAND

- Preparation: Temporarily seal open ends of pipework with plugs.
- Test apparatus: Connect a 'U' tube water gauge and air pump to pipework via a plug.
- Testing: Pump air into pipework until gauge registers 38 mm.
- Required performance:
 - Allow a period for temperature stabilization, after which the pressure of 38 mm is to be maintained without loss for at least 3 minutes.

915 MAINTENANCE INSTRUCTIONS

- General: At completion, submit printed instructions recommending procedures for maintenance of the rainwater installation, including full details of recommended inspection, cleaning and repair procedures.

920 IMMEDIATELY BEFORE HANDOVER

- Construction rubbish, debris, swarf, temporary caps and fine dust which may enter the rainwater system: Remove. Do not sweep or flush into the rainwater system.
- Access covers, rodding eyes, outlet gratings and the like: Secure complete with fixings.

Z

Building fabric reference specification

Z10

Purpose made joinery

Z10 Purpose made joinery

To be read with Preliminaries/ General conditions.

110 FABRICATION

- Standard: To BS 1186-2.
- Sections: Accurate in profile and length, and free from twist and bowing. Formed out of solid unless shown otherwise.
 - Machined surfaces: Smooth and free from tearing, wooliness, chip bruising and other machining defects.
- Joints: Tight and close fitting.
- Assembled components: Rigid. Free from distortion.
- Screws: Provide pilot holes.
 - Screws of 8 gauge (4 mm diameter) or more and screws into hardwood: Provide clearance holes.
 - Countersink screws: Heads sunk at least 2 mm below surfaces visible in completed work.
- Adhesives: Compatible with wood preservatives applied and end uses of timber.

120 CROSS SECTION DIMENSIONS OF TIMBER

- General: Dimensions on drawings are finished sizes.
- Maximum permitted deviations from finished sizes:
 - Softwood sections: To BS EN 1313-1:-
Clause 6 for sawn sections.
 - Hardwood sections: To BS EN 1313-2:-
Clause 6 for sawn sections.
Clause NA.3 for further processed sections.

130 PRESERVATIVE TREATED WOOD

- Cutting and machining: Completed as far as possible before treatment.
- Extensively processed timber: Retreat timber sawn lengthways, thickened, planed, ploughed, etc.
- Surfaces exposed by minor cutting and/ or drilling: Treat as recommended by main treatment solution manufacturer.

140 MOISTURE CONTENT

- Wood and wood based products: Maintained within range specified for the component during manufacture and storage.

210 LAMINATED PLASTICS VENEERED BOARDS/ PANELS

- Fabrication: To British Laminated Plastics Fabricators Association Ltd (BLF) fabricating standards.
- Balancing veneer: From decorative veneer manufacturer and of similar composition. Applied to reverse side of core material.
- Finished components: Free from defects, including bow, twist, scratches, chipping, cracks, pimpling, indentations, glue marks, staining and variations in colour and pattern.
- Joints visible in completed work: Tight butted, true and flush.

220 WOOD VENEERED BOARDS/ PANELS

- Core material and veneers: Conditioned before bonding.
- Setting out: Veneer features and grain pattern aligned regularly and symmetrically unless instructed otherwise.
- Balancing veneer: Applied to reverse side of core material.
 - Moisture and temperature movement characteristics: As facing veneer.
- Veneer edges: Tight butted and flush, with no gaps.
- Tolerance of veneer thickness (maximum): ± 0.5 mm.
- Finished components: Free from defects, including bow, twist, scratches, chipping, splits, blebs, indentations, glue marks and staining.
- Surface finish: Fine, smooth, free from sanding marks.

250 FINISHING

- Surfaces: Smooth, even and suitable to receive finishes.
 - Arrises: Eased unless shown otherwise on drawings.
- End grain in external components: Sealed with primer or sealer as section M60 and allowed to dry before assembly.

Z11

Purpose made metalwork

Z11 Purpose made metalwork

To be read with Preliminaries/ General conditions.

- 310 MATERIALS GENERALLY
- Grades of metals, section dimensions and properties: To appropriate British Standards. When not specified, select grades and sections appropriate for the purpose.
 - Prefinished metal: May be used if methods of fabrication do not damage or alter appearance of finish, and finish is adequately protected.
 - Fasteners: To appropriate British Standards and, unless specified otherwise, of same metal as component being fastened, with matching coating or finish.
- 320 STEEL LONG AND FLAT PRODUCTS
- Hot rolled structural steels (excluding structural hollow sections and tubes): To BS EN 10025-1.
 - Fine grain steels, including special steels: To BS EN 10025-3 and -4.
 - Steels with improved atmospheric corrosion resistance: To BS EN 10025-5.
- 330 STEEL PLATE, SHEET AND STRIP
- Plates and wide flats, high yield strength steel: To BS EN 10025-6.
- 340 HOT ROLLED STEEL PLATE, SHEET AND STRIP
- Flat products, high yield strength for cold forming: To BS EN 10149-1, -2 and -3.
 - Carbon steel sheet and strip for cold forming: To BS EN 10111.
 - Narrow strip, formable steel and steel for general engineering purposes: To BS 1449-1.8 and BS 1449-1.14.
- 350 COLD ROLLED STEEL PLATE, SHEET AND STRIP
- Steel sections: To BS EN 10162.
 - Flat products, high yield strength micro-alloyed steels for cold forming: To BS EN 10268.
 - Carbon steel flat products for cold forming: To BS EN 10130 and BS EN 10131.
 - Uncoated carbon steel narrow strip for cold forming: To BS EN 10139 and BS EN 10140.
 - Narrow strip steel for general engineering purposes: To BS EN 10132-1, -2, and -3.
 - Carbon steel flat products for vitreous enamelling: To BS EN 10209.
- 360 COATED STEEL FLAT PRODUCTS
- Hot dip zinc coated carbon steel sheet and strip for cold forming: To BS EN 10346 and BS EN 10143.
 - Hot dip zinc coated structural steel sheet and strip: To BS EN 10143 and BS EN 10346.
 - Hot dip zinc-aluminium (za) coated sheet and strip: To BS EN 10346.
 - Hot dip aluminium-zinc (az) coated sheet and strip: To BS EN 10346.
 - Organic coated flat products: To BS EN 10169.
- 370 STEEL STRUCTURAL HOLLOW SECTIONS (SHS)
- Non alloy and fine grain steels, hot finished: To BS EN 10210-1 and -2.
 - Non-alloy and fine grain steels, cold formed welded: To BS EN 10219-2.
 - Weather resistant steels, hot finished: To BS 7668.

380 OTHER STEEL SECTIONS

- Equal flange tees: To BS EN 10055.
- Equal and unequal angles: To BS EN 10056-1 and -2.
- Wire, carbon steel for general engineering purposes: To BS 1052.
- Wire and wire products, general: To BS EN 10218-2.
- Tubes:
 - Seamless circular: To BS EN 10297-1.
 - Seamless cold drawn: To BS EN 10305-1.
 - Welded and cold sized square and rectangular: To BS EN 10305-5.
 - Welded circular: To BS EN 10296-1.
 - Welded cold drawn: To BS EN 10305-2.
 - Welded cold sized: To BS EN 10305-3.

400 STAINLESS STEEL PRODUCTS

- Chemical composition and physical properties: To BS EN 10088-1.
- Sheet, strip and plate: To BS EN 10088-2.
- Semi-finished products bars, rods and sections: To BS EN 10088-3.
- Wire: To BS EN 1088-3.
- Tubes:
 - Welded circular: To BS EN 10296-2.
 - Seamless circular: To BS EN 10297-2.

410 ALUMINIUM ALLOY PRODUCTS

- Designations:
 - Designation system, chemical composition and forms: To BS EN 573-1, -2, -3 and -5.
 - Temper designations: To BS EN 515.
- Sheet, strip and plate: To BS EN 485-1 to -4.
- Cold drawn rods, bars and tubes: To BS EN 754-1 and -2.
- Extruded rods, bars, tubes and profiles: To BS EN 755-1 and -2.
- Drawn wire: To BS EN 1301-1, -2 and -3.
- Rivet, bolt and screw stock: To BS 1473.
- Structural sections: To BS 1161.

FABRICATION

515 FABRICATION GENERALLY

- Contact between dissimilar metals in components: Avoid.
- Finished components: Rigid and free from distortion, cracks, burrs and sharp arrises.
 - Moving parts: Free moving without binding.
- Corner junctions of identical sections: Mitre.

520 COLD FORMED WORK

- Profiles: Accurate, with straight arrises.

525 ADHESIVE BONDING

- Preparation of surfaces of metals to receive adhesives:
 - Degrease.
 - Abrade mechanically or chemically etch.
 - Prime: To suit adhesive.
- Adhesive bond: Form under pressure.

530 STAINLESS STEEL FABRICATION

- Guillotining or punching: Do not use for metal thicknesses greater than 10 mm.
- Thermal cutting:
 - Carbonation in the heat affected zone: Remove, after cutting.
- Bending:
 - Plates or bars: Cold bending radius not less than material thickness.
 - Tubes: Cold bending radius not less than 2 x tube diameter.
- Welding: In addition to general welding requirements:
 - Protect adjacent surfaces from weld spatter.
 - Pickle all welds before post fabrication treatments.
- Protection: Provide protection to fabricated components during transit and on site.

555 BRAZING

- Standard: To BS EN 14324.
- Testing:
 - Destructive testing: To BS EN 12797.
 - Nondestructive testing: To BS EN 12799.

FINISHING

745 PREPARATION FOR APPLICATION OF COATINGS

- General: Complete fabrication, and drill fixing holes before applying coatings.
- Paint, grease, flux, rust, burrs and sharp arrises: Remove.

760 ZINC AND CADMIUM PLATING OF IRON AND STEEL SURFACES

- Zinc plating: To BS EN ISO 2081.
- Cadmium plating: To BS EN ISO 2082.

770 CHROMIUM PLATING

- Standard: To BS EN ISO 1456.

780 GALVANIZING

- Standard: To BS EN ISO 1461.
- Preparation:
 - Vent and drain holes: Provide in accordance with BS EN ISO 14713-1 and -2. Seal after sections have been drained and cooled.
 - Components subjected to cold working stresses: Heat treat to relieve stresses before galvanizing.
 - Welding slag: Remove.
 - Component cleaning: To BS EN ISO 8501-3.
 - Grade: St 2½.

COMPLETION

910 DOCUMENTATION

- Submit:
 - Manufacturer's maintenance instructions.
 - Guarantees, warranties, test certificates, record schedules and log books.

920 COMPLETION

- Protection: Remove.
- Cleaning and maintenance: Carry out in accordance with procedures detailed in fabricators' guarantees.

Z12

Preservative/ fire retardant treatment

Z12 Preservative/ fire retardant treatment

To be read with Preliminaries/ General conditions.

110 TREATMENT APPLICATION

- Timing: After cutting and machining timber, and before assembling components.
- Processor: Licensed by manufacturer of specified treatment solution.
 - Operatives: Must have completed the PCA training scheme.
- Certification: For each batch of timber provide a certificate of assurance that treatment has been carried out as specified.

120 COMMODITY SPECIFICATIONS

- Standard: In accordance with the Wood Protection Association (WPA) publication 'Industrial wood preservation specification and practice'.

130 PRESERVATIVE TREATMENT SOLUTION STRENGTHS/ TREATMENT CYCLES

- General: Select to achieve specified service life and to suit treatability of specified wood species.

140 COPPER-ORGANIC PRESERVATIVE TREATMENT

- Solution:
 - Manufacturer: Submit proposals.
 - Product reference: Submit proposals.
 - Colour: Contractor's choice.
 - Application: High pressure impregnation.
- Moisture content of wood:
 - At time of treatment: Not more than 28%.
 - After treatment: Timber to be surface dry before using.

610 MAKING GOOD TO PRESERVATIVE TREATMENT ON-SITE

- Preservative solution: Compatible with off-site treatment.
- Application: In accordance with preservative manufacturer's recommendations.

620 MAKING GOOD TO FIRE RETARDANT TREATMENT ON-SITE

- Fire retardant: Compatible with off-site treatment.
- Application: In accordance with fire retardant manufacturer's recommendations.

Z20

Fixings and adhesives

Z20 Fixings and adhesives

To be read with Preliminaries/ General conditions.

PRODUCTS

310 FASTENERS GENERALLY

- Materials: To have:
 - Bimetallic corrosion resistance appropriate to items being fixed.
 - Atmospheric corrosion resistance appropriate to fixing location.
- Appearance: Submit samples on request.

320 PACKINGS

- Materials: Noncompressible, corrosion proof.
- Area of packings: Sufficient to transfer loads.

330 NAILED TIMBER FASTENERS

- Nails:
 - Steel: To BS 1202-1 or BS EN 10230-1.
 - Copper: To BS EN 1202-2.
 - Aluminium: To BS 1202-3.

340 MASONRY FIXINGS

- Light duty: Plugs and screws.
- Heavy duty: Expansion anchors or chemical anchors.

350 PLUGS

- Type: Proprietary types to suit substrate, loads to be supported and conditions expected in use.

360 ANCHORS

- Types:
 - Expansion: For use in substrate strong enough to resist forces generated by expansion of anchor.
 - Adhesive or chemical:
 - For use in substrate where expansion of anchor would fracture substrate.
 - For use in irregular substrate where expansion anchors cannot transfer load on anchor.
 - Cavity: For use where the anchor is retained by toggles of the plug locking onto the inside face of the cavity.

370 WOOD SCREWS

- Type:
 - Wood screws (traditional pattern).
 - Standard: To BS 1210.
 - Wood screws.
 - Pattern: Parallel, fully threaded shank or twin thread types.
- Washers and screw cups: Where required are to be of same material as screw.

380 MISCELLANEOUS SCREWS

- Type: To suit the fixing requirement of the components and substrate.
 - Pattern: Self-tapping, metallic drive screws, or power driven screws.
- Washers and screw cups: Where required to be of same material as screw.

390 ADHESIVES GENERALLY

- Standards:
 - Hot-setting phenolic and aminoplastic: To BS 1203.
 - Thermosetting wood adhesives: To BS EN 12765.
 - Thermoplastic adhesives: To BS EN 204.

410 POWDER ACTUATED FIXING SYSTEMS

- Types of fastener, accessories and consumables: As recommended by tool manufacturer.

EXECUTION

610 FIXING GENERALLY

- Integrity of supported components: Select types, sizes, quantities and spacings of fixings, fasteners and packings to retain supported components without distortion or loss of support.
- Components, substrates, fixings and fasteners of dissimilar metals: Isolate with washers/ sleeves to avoid bimetallic corrosion.
- Appearance: Fixings to be in straight lines at regular centres.

620 FIXING THROUGH FINISHES

- Penetration of fasteners and plugs into substrate: To achieve a secure fixing.

630 FIXING PACKINGS

- Function: To take up tolerances and prevent distortion of materials and components.
- Limits: Do not use packings beyond thicknesses recommended by fixings and fasteners manufacturer.
- Locations: Not within zones to be filled with sealant.

640 FIXING CRAMPS

- Cramp positions: Maximum 150 mm from each end of frame sections and at 600 mm maximum centres.
- Fasteners: Fix cramps to frames with screws of same material as cramps.
- Fixings in masonry work: Fully bed in mortar.

650 NAILED TIMBER FIXING

- Penetration: Drive fully in without splitting or crushing timber.
- Surfaces visible in completed work: Punch nail heads below wrot surfaces.
- Nailed timber joints: Two nails per joint (minimum), opposed skew driven.

660 SCREW FIXING

- Finished level of countersunk screw heads:
 - Exposed: Flush with timber surface.
 - Concealed (holes filled or stopped): Sink minimum 2 mm below surface.

670 PELLETED COUNTERSUNK SCREW FIXING

- Finished level of countersunk screw heads: Minimum 6 mm below timber surface.
- Pellets: Cut from matching timber, match grain and glue in to full depth of hole.
- Finished level of pellets: Flush with surface.

680 PLUGGED COUNTERSUNK SCREW FIXING

- Finished level of countersunk screw heads: Minimum 6 mm below timber surface.
- Plugs: Glue in to full depth of hole.
- Finished level of plugs: Projecting above surface.

690 USING POWDER ACTUATED FIXING SYSTEMS

- Powder actuated fixing tools: To BS 4078-2 and Kitemark certified.
- Operatives: Trained and certified as competent by tool manufacturer.

700 APPLYING ADHESIVES

- Surfaces: Clean. Adjust regularity and texture to suit bonding and gap filling characteristics of adhesive.
- Support and clamping during setting: Provide as necessary. Do not mark surfaces of or distort components being fixed.
- Finished adhesive joints: Fully bonded. Free of surplus adhesive.

Z21
Mortars

Z21 Mortars

To be read with Preliminaries/ General conditions.

CEMENT GAUGED MORTARS

- 110 CEMENT GAUGED MORTAR MIXES
- Specification: Proportions and additional requirements for mortar materials are specified elsewhere.
- 120 SAND FOR SITE MADE CEMENT GAUGED MASONRY MORTARS
- Standard: To BS EN 13139.
 - Grading: 0/2 (FP or MP).
 - Fines content where the proportion of sand in a mortar mix is specified as a range (e.g. 1:1: 5-6):
Lower proportion of sand: Use category 3 fines.
Higher proportion of sand: Use category 2 fines.
 - Sand for facework mortar: Maintain consistent colour and texture. Obtain from one source.
- 131 READY-MIXED LIME:SAND FOR CEMENT GAUGED MASONRY MORTARS
- Standard: To BS EN 998-2.
 - Lime: Nonhydraulic to BS EN 459-1.
 - Type: CL 90S.
 - Pigments for coloured mortars: To BS EN 12878.
- 135 SITE MADE LIME:SAND FOR CEMENT GAUGED MASONRY MORTARS
- Permitted use: Where a special colour is not required and in lieu of factory made ready-mixed material.
 - Lime: Nonhydraulic to BS EN 459-1.
 - Type: CL 90S.
 - Mixing: Thoroughly mix lime with sand, in the dry state. Add water and mix again. Allow to stand, without drying out, for at least 16 hours before using.
- 160 CEMENTS FOR MORTARS
- Cement: To BS EN 197-1 and CE marked.
 - Types: Portland cement, CEM I.
Portland limestone cement, CEM II/A-L or CEM II/A-LL.
Portland slag cement, CEM II/B-S.
Portland fly ash cement, CEM II/B-V.
 - Strength class: 32.5, 42.5 or 52.5.
 - White cement: To BS EN 197-1 and CE marked.
 - Type: Portland cement, CEM I.
 - Strength class: 52.5.
 - Sulfate resisting Portland cement:
 - Type: To BS EN 197-1 Sulfate resisting Portland cement, CEM I/SR and CE marked.
To BS EN 197-1 fly ash cement, CEM II/B-V and CE marked.
 - Strength class: 32.5, 42.5 or 52.5.
 - Masonry cement: To BS EN 413-1 and CE marked.
 - Class: MC 12.5.

- 180 ADMIXTURES FOR SITE MADE CEMENT GAUGED MORTARS
- Air entraining (plasticizing) admixtures: To BS EN 934-3 and compatible with other mortar constituents.
 - Other admixtures: Submit proposals.
 - Prohibited admixtures: Calcium chloride, ethylene glycol and any admixture containing calcium chloride.
- 190 RETARDED READY TO USE CEMENT GAUGED MORTAR
- Standard: To BS EN 998-2.
 - Lime for cement:lime:sand mortars: Nonhydraulic to BS EN 459-1.
 - Type: CL 90S.
 - Pigments for coloured mortars: To BS EN 12878.
 - Time and temperature limitations: Use within limits prescribed by mortar manufacturer.
 - Retempering: Restore workability with water only within prescribed time limits.
- 200 STORAGE OF CEMENT GAUGED MORTAR MATERIALS
- Sands and aggregates: Keep different types/ grades in separate stockpiles on hard, clean, free-draining bases.
 - Factory made ready-mixed lime:sand/ ready to use retarded mortars: Keep in covered containers to prevent drying out or wetting.
 - Bagged cement/ hydrated lime: Store off the ground in dry conditions.
- 210 MAKING CEMENT GAUGED MORTARS
- Batching: By volume. Use clean and accurate gauge boxes or buckets.
 - Mix proportions: Based on dry sand. Allow for bulking of damp sand.
 - Mixing: Mix materials thoroughly to uniform consistency, free from lumps.
 - Mortars containing air entraining admixtures: Mix mechanically. Do not overmix.
 - Working time (maximum): Two hours at normal temperatures.
 - Contamination: Prevent intermixing with other materials.

LIME:SAND MORTARS

- 310 LIME:SAND MORTAR MIXES
- Specification: Proportions and additional requirements for mortar materials are specified elsewhere.
- 320 SAND FOR LIME:SAND MASONRY MORTARS
- Type: Sharp, well graded.
 - Quality, sampling and testing: To BS EN 13139.
 - Grading/ Source: As specified elsewhere in relevant mortar mix items.
- 330 READY PREPARED LIME PUTTY
- Type: Slaked directly from CL 90 quicklime to BS 890, using an excess of water.
 - Maturation: In pits/ containers that allow excess water to drain away.
 - Density of matured lime putty: 1.3 - 1.4 kg/litre.
 - Maturation period before use (minimum): 30 days.
- 345 ADMIXTURES FOR HYDRAULIC LIME:SAND MORTARS
- Air entraining (plasticizing) admixtures: To BS EN 934-3 and compatible with other mortar constituents.
 - Prohibited admixtures: Calcium chloride, ethylene glycol and any admixture containing calcium chloride.

350 STORAGE OF LIME:SAND MORTAR MATERIALS

- Sands and aggregates: Keep different types/ grades in separate stockpiles on hard, clean, free-draining bases.
- Ready prepared nonhydraulic lime putty: Prevent drying out and protect from frost.
- Nonhydraulic lime:sand mortar: Store on clean bases or in clean containers that allow free drainage. Prevent drying out or wetting and protect from frost.
- Bagged hydrated hydraulic lime: Store off the ground in dry conditions.

380 READY TO USE NONHYDRAULIC LIME:SAND MORTARS

- Manufacturer: Submit proposals.
 - Product reference: Contractor's choice.
- Materials: Select from:
 - Lime putty slaked directly from quicklime to BS EN 459-1 and mixed thoroughly with sand.
 - Quicklime to BS EN 459-1 slaked directly with sand.
- Maturation period before use (maximum): Seek instructions.

Z22 Sealants

To be read with Preliminaries/General conditions.

PRODUCTS

310 JOINTS TO WINDOW PERIMETERS

- Primer, backing strip, bond breaker: Types recommended by sealant manufacturer.

EXECUTION

610 SUITABILITY OF JOINTS

- Presealing checks:
 - Joint dimensions: Within limits specified for the sealant.
 - Substrate quality: Surfaces regular, undamaged and stable.
- Joints not fit to receive sealant: Submit proposals for rectification.

620 PREPARING JOINTS

- Surfaces to which sealant must adhere:
 - Remove temporary coatings, tapes, loosely adhering material, dust, oil, grease, surface water and contaminants that may affect bond.
 - Clean using materials and methods recommended by sealant manufacturer.
- Vulnerable surfaces adjacent to joints: Mask to prevent staining or smearing with primer or sealant.
- Backing strip and/ or bond breaker installation: Insert into joint to correct depth, without stretching or twisting, leaving no gaps.
- Protection: Keep joints clean and protect from damage until sealant is applied.

630 APPLYING SEALANTS

- Substrate: Dry (unless recommended otherwise) and unaffected by frost, ice or snow.
- Environmental conditions: Do not dry or raise temperature of joints by heating.
- Sealant application: Fill joints completely and neatly, ensuring firm adhesion to substrates.
- Sealant profiles:
 - Butt and lap joints: Slightly concave.
 - Fillet joints: Flat or slightly convex.
- Protection: Protect finished joints from contamination or damage until sealant has cured.

Z31

Powder coatings

Z31 Powder coatings

To be read with Preliminaries/ General conditions.

120A POWDER MANUFACTURER

- Manufacturer: Valspar Powder Coatings Ltd.
 - Web: www.synthapulvin.co.uk.
 - Email: synthapulvin@valspar.com.
 - Product reference: Syntha Pulvin

210 WORKING PROCEDURES

- Comply with the follow following standards.
 - Aluminium components: To BS 6496 or BS EN 12206-1.
 - Steel components: To BS EN 13438.
 - Safety standards: To British Coatings Federation 'Code of safe practice - Application of thermosetting powder coatings by electrostatic spraying'.

220 POWDER COATING APPLICATORS

- Applicator requirements:
 - Approved by powder coating manufacturer.
 - Currently certified to BS EN ISO 9001.
 - Comply with quality procedures, guarantee conditions, standards and tests required by powder coating manufacturer.
 - Applicator to use only one plant.
 - Selected applicator: Submit details before commencement of powder coating including: Name and contact details.
Details of accreditation schemes.

225 GUARANTEES

- Powder coating manufacturer and applicator guarantees:
 - Submit sample copies before commencement of powder coating.
 - Submit signed project specific copies on completion of work.

230 CONTROL SAMPLES

- Sequence: Prior to ordering materials for the works, obtain approval of appearance for:
 - Powder coated samples: Of various grades and forms of background metal to be used, showing any colour, texture and gloss variation.
 - Fabrication samples: Showing joint assembly, how powder coating is affected and how any cut metal edges are finished and protected.
- Samples to include the following information:
 - Product reference.
 - Colour.
 - Reference number.
 - Name.
 - Gloss level.

250 COMPONENT DESIGN

- Condition of components to be powder coated:
 - To comply with relevant recommendations of BS 4479-1, -3, and -4.
 - Of suitable size to fit plant capacity.
 - Of suitable thickness to withstand oven curing.

310 PRETREATMENT OF ALUMINIUM COMPONENTS

- Condition of components to be pretreated:
 - Free from corrosion and damage.
 - All welding and jointing completed and finish off as specified.
 - Free from impurities including soil, grease, oil.
 - Suitable for and compatible with the pretreatment process.
- Conversion coating requirements:
 - Chromate system: To BS 6496 or BS EN 12206-1.
 - Chromate-free system: To BS EN 12206-1. Submit details before using.
- Rinsing requirements: Use demineralized water. Drain and dry.

320 PRETREATMENT OF STEEL COMPONENTS

- Condition of components to be pretreated:
 - Free from corrosion and damage.
 - All welding and jointing completed and finish off as specified.
 - Free from impurities including soil, grease, oil.
 - Suitable for and compatible with the pretreatment process.
- Conversion coating requirements: To BS EN 13438.
- Rinsing requirements: Use demineralized water. Drain and dry.

430 EXTENT OF POWDER COATINGS

- Application: To visible component surfaces, and concealed surfaces requiring protection. Coated surfaces will be deemed 'significant surfaces' for relevant BS 6496 or BS EN 13438 performance requirements.

435 APPLICATION OF POWDER COATINGS

- Surfaces to receive powder coatings: Free from dust or powder deposits.
- Powder colours: Obtain from one batch of one manufacturer.
- Commencement of powder coating: To be continuous from pretreatment.
- Jig points: Not visible on coated components.
- Curing: Controlled to attain metal temperatures and hold periods recommended by powder coating manufacturer.
- Stripping and recoating of components: Only acceptable by prior agreement of powder coating manufacturer. Stripping, pretreatment and powder coating are to be in accordance with manufacturer's requirements.
- Overcoating of components: Not acceptable.

440 PERFORMANCE AND APPEARANCE OF POWDER COATINGS

- For aluminium components:
 - Standard: To BS 6496 or BS EN 12206-1.
- For steel components:
 - Standard: To BS EN 13438.
- Visual inspection after powder coating: Significant surface viewing distances to be as specified in the relevant Standard, unless specified otherwise.
- Colour and gloss levels: To conform with approved samples.

450 ALUMINIUM ALLOY FABRICATIONS

- Units may be assembled:
 - Before powder coating.
 - From components powder coated after cutting to size.
 - Where approved, from components powder coated before cutting to size.
- Exposure of uncoated background metal: Not acceptable.
- Assembly sealants: Compatible with powder coatings. Obtain approval of colour if sealants are visible after fabrication.

460 STEEL FABRICATIONS

- Unit assembly: Wherever practical, before powder coating.
- Exposure of uncoated background metal: Not acceptable.
- Assembly sealants: Compatible with powder coatings. Obtain approval of colour if sealants are visible after fabrication.

470 FIXINGS

- Exposed metal fixings: Powder coat together with components, or coat with matching repair paint system applied in accordance with the powder coating manufacturer's recommendations.

480 DAMAGED COMPONENTS - REPAIR/ REPLACEMENT

- Before delivery to site: Check all components for damage to powder coatings. Replace damaged components.
- Site damage: Submit proposals for repair or replacement.

510 PROTECTION

- Powder coated surfaces of components: Protect from damage during handling and installation, or by subsequent site operations.
- Protective coverings: Must be:
 - Resistant to weather conditions.
 - Partially removable to suit building in and access to fixing points.
- Protective tapes in contact with powder coatings: Must be:
 - Low tack, self adhesive and light in colour.
 - Applied and removed in accordance with tape and powder coating manufacturers' recommendations. Do not use solvents to remove residues as these are detrimental to the coating.
- Inspection of protection: Carry out monthly. Promptly repair any deterioration or deficiency.

535 DOCUMENTATION

- Submit the following information for each batch of powder coated components:
 - Supplier.
 - Trade name.
 - Colour.
 - Type of powder.
 - Method of application.
 - Batch and reference number.
 - Statutory requirements.
 - Test certificates.
 - Maintenance instructions.

540 COMPLETION

- Protection: Remove.
- Cleaning and maintenance of powder coatings: Carry out in accordance with procedures detailed in powder coating manufacturer and applicator guarantees.