



OUR TOWN HALL
P20 NBS SPECIFICATION
UNFRAMED ISOLATED
TRIMS/SKIRTINGS/SUNDRY ITEMS

Document reference: **OTH-PUR-TH-ZZ-SPE-A-5921**

Date: 24/07/2019

Issue: 02

CLAUSE SUFFIX LETTERS

This Purcell Specification is based upon the National Building Specification (NBS). The Contractor's attention is drawn to the suffix letters **A**, **B** and ***** that occur after some of the clause numbers in the work sections.

These suffix letters are used as follows:

- ☐ ***** is used for a new clause, not found in the NBS
- ☐ **A** is used for an NBS clause which has been altered in the Purcell Standard Specification.
- ☐ **B** is used for a new clause in this particular Job Specification or against an existing clause from the Purcell Standard Specification amended for this project.

No liability is accepted for the incorrect application of this convention in this Specification.

Rev	By	Description	Date	Authorised
-	NM	FOR TENDER	15/11/19	DH
01	VT	FOR TENDER: a. P20 240a clause added: PLYWOOD b. P20 245 clause added: BLOCKBOARD c. P20 260a clause added: WOOD VENEERED	29/11/19	DH
02	DW	FOR TENDER 100 moved to 100A 110 moved to 110B 120 moved 120B 240B Added 510A changed to installation of skirtings Former 510 Installation Generally - moved to 510B 514 moved to revision B.	24/07/20	NM

Table of Contents

Title		Page
P20	Unframed isolated trims/skirtings/sundry items	4

P20

Unframed isolated trims/skirtings/sundry items

P20 Unframed isolated trims/skirtings/sundry items**To be read with Preliminaries/ General conditions****TRIMS/CASINGS****100A TRIMS GENERALLY**

- This section will describe the following components where relevant;
 - Skirtings
 - Architraves
 - Picture Rails
 - Cover fillets, beads, lippings
 - Pinboard
 - Window boards
 - Duct casings
 - Battens for curtains
 - Shelves
- Quality of timber and fixing: To BS 1186:Part 3.
- Species: European White Wood
- Class: 2 or 3 (1 or CSH for clear finish trims)
- Moisture content at time of fixing 10 to 14% (continuous heating 12-19 degrees C)
- Preservative treatment: not required
- Profile: To match existing or as stated on drawings installation to clauses 510 & 514
- Finished size: To match existing or as stated on drawings
- Profile: n/a
- Finished size: n/a
- Profile: n/a
- Finished size: n/a

110B WALL GUARD Type A

- Manufacturer: Gradus Wall Protection, Park Green, Macclesfield, Cheshire, SK11 7LZ.
 - Tel: 01625 428922 - Website: www.gradus.com - Email: sales@gradus.com
 - Reference: WGS125 Wall Guard – select from continuous retainer option (WGS125C) or fixing clip retainer option (WGS125F)
 - Cover: PVC-u
 - Inner Bumper: PVC-u
 - Retainer: Aluminium – 50mm fixing clips
 - Accessories: PVC-u - WGS1251 End Cap
 - Height: 125mm
 - Depth: 25mm
 - Length: 4.00m
 - Colour : 033 Slate (LRV: 7.03) subject to sample
- Refer to OTH-PUR-TH-ZZ-DWG-A-5102 for location and installation height.

111 WALL GUARD Type B

- Manufacturer: Gradus Wall Protection, Park Green, Macclesfield, Cheshire, SK11 7LZ.
 - Tel: 01625 428922 - Website: www.gradus.com - Email: sales@gradus.com
 - Reference: WGA100 Wall Guard
 - Cover: PVC-u
 - Retainer: Aluminium
 - Accessories: PVC-u - WGA1001 End Cap
 - Height: 100mm
 - Depth: 50mm
 - Length: 4.00m
 - Colour: 033 Slate (LRV: 7.03) subject to sample
 - Fixing: Mechanical (screw) fix – as per manufacturer's instructions
- Refer to OTH-PUR-TH-ZZ-DWG-A-5102 for location and installation height.

120B CORNER GUARD Type C

- Manufacturer: Gradus, Park Green, Macclesfield, Cheshire, SK11 7LZ.
 - Tel: 01625 428922 - Website: www.gradus.com - Email: sales@gradus.com
 - Reference: High Impact PVC-u Corner Guards – CGH7590 – 75mm wing, 90° angle
 - Cover: PVC-u
 - Retainer: Aluminium
 - Accessories: PVC-u Top & Bottom Caps Code: CGH7590CAP
 - Length (select as required): 2.0m
 - Colour: 033 Slate (LRV: 7.03)
 - Fixing: Mechanical (screw) fix – as per manufacturer's instructions
- Refer to OTH-PUR-TH-ZZ-DWG-A-5102 for location and installation height.

BOARD MATERIALS**240A PLYWOOD JOINERY**

- Manufacturer: Hanson Plywood Ltd.
 - Web: www.hanson-plywood.co.uk.
 - Email: panels@hanson-plywood.co.uk.
 - Product reference: H Birch Plywood.
- Face grade: BB/BB.
- Board size: 1220x2440mm.
- Thickness: 18mm.

240B PLYWOOD BOXING

- Manufacturer: Hanson Plywood Ltd.
 - Web: www.hanson-plywood.co.uk.
 - Email: panels@hanson-plywood.co.uk.
 - Product reference: H Performance plywood.
- Board size: 1220x2440mm.
- Thickness: 12mm.

240C PLYWOOD NON-VISIBLE PACKING SHIMS

- Manufacturer: Contractor's choice to PIFA Standard 6/83A or Agreement certified.
 - Product reference: Contractor's choice.
- Face ply species: Contractor's choice.
- Appearance class to BS EN 635: Class II/III.
- Bond quality to BS EN 314-2: Class 3.
- Fire rating: To BS 476-7, Class 1.
- Thickness: Refer to Architects drawings.
- Edges: Refer to Architects drawings.
- Finish: Prepared and primed as section M60.
- Support/ Fixing: Refer to Architects drawings.

245 BLOCKBOARD JOINERY

- Manufacturer: Hanson Plywood Ltd.
 - Web: www.hanson-plywood.co.uk.
 - Email: panels@hanson-plywood.co.uk.
 - Product reference: BB Birch Blockboard.
- Board size: 2440x1220mm.
- Thickness: 18mm.

260A WOOD VENEERED FACE AND LIPPED PLYWOOD AS P20/240A & FACE AND LIPPED BLOCKBOARD AS P20/24

- " Manufacturer: Woodlam (UK) Limited.
- Product reference: White Oak Unfinished.
- " Fire rating: FR Euro Class B.
- " Veneer species: European White Oak Quarter Cut.
- " Finished thickness: 19mm.
- " Edges: Face and Lipped.
- " Support/ Fixing: As drawing OTH-PUR-TH-04-DWG-A-9544 and OTH-PUR-TH-04-DWG-A-9587.
- " Refer to NBS M60/162 for oiled finish.

INSTALLATION**510A INSTALLATION TO NEW SKIRTINGS**

- Prior to fixing new and refixing existing skirtings allow to scribe the base of skirting using a block plane to account for any unevenness in the existing floor to achieve a flush junction between floor and skirting.
Refer to skirtingboard schedule ref: OTH-PUR-TH-ZZ-SCH-A-9595 for skirting size and profile.

510B INSTALLATION GENERALLY

- Joinery workmanship: As section Z10.
- Metal workmanship: As section Z11.
- Methods of fixing and fasteners: As section Z20 where not specified.
- Straight runs: To be in one piece, or in long lengths with as few joints as possible.
- Running joints: Location and method of forming to be agreed where not detailed.
- Joints at angles: Mitre, unless shown otherwise.
- Position and level: To be agreed where not detailed.

514A JOINTS Timber boarding including skirtings

- Joints between new and existing boards to have 45 ° splice and be filled with a 2 part epoxy timber filler and sanded to produce a flush finish - joints not to be visible after painting. External corners to be mitred with 2mm radius to the finished ariss