Paul Daly

From: Debbie Fifer <Debbie.Fifer@canalrivertrust.org.uk>
Sent: 26 June 2020 15:27
To: Paul Daly
Subject: RE: Brownfields Mill

Hi Paul

Apologies fore the delay getting back to you.

Having reviewed the latest information provided and impression of the proposed barrier-skirt and corner treatment I can confirm that we are now generally satisfied with the design of what is being proposed.
I would advise that you check with the LPA that they are ok with this in terms on heritage impact (especially if any fixings to coping stones etc requires) and from a safety perspective. The risk of anti-social behaviour and rough sleeping in the area under the bridge is still a concern and we would advise regular maintenance of this area by the management company associated with this development.

You are also advised to consider any potential impact of additional wind loading as a result of the screening.

Kind Regards

Debbie

Debbie Fifer MRTPI
Planning Manager / Rheolwr Cynllunio

M: 07795 307592
E: Debbie.Fifer@canalrivertrust.org.uk

Canal & River Trust / Glandwr Cymru,
Navigation Road, Northwich, Cheshire, CW8 1BH.

https://canalrivertrust.org.uk/specialist-teams/planning-and-design

Canal & River Trust
Making life better by water

From: Paul Daly <p.daly@stephenson-studio.com>
Sent: 26 June 2020 12:25
To: Debbie Fifer <Debbie.Fifer@canalrivertrust.org.uk>