


Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.36	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 10m2 of plaster missing				
	Floor Finish	Wood block (partially lifted)	High	Retain				
	Fixtures & Fittings	Ceiling vent Radiator brackets Exit sign	High None None	Retain Remove Remove				Remove: - Radiator brackets - Exit sign
	M&E Items	Lighting Heating pipes Misc. cables Plug sockets	None Low None None	Remove all				Remove: - Lighting - Heating pipes - Misc. cables - Plug sockets




Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.37	Wall Finish(es)	Paint	None	Remove flaking paint				
	Ceiling Finish	Paint	None	Remove flaking paint Approx. 3m2 of plaster missing				
	Floor Finish	Wood block Glazed tile	High Low	Retain Retain				
	Fixtures & Fittings							
	M&E Items	Heating pipes Fuse board Fuse box Lighting Switch Conduit	Low None None None None None	Remove all				Remove: • Heating pipes • Fuse board • Fuse box • Lighting • Switch • Conduit


Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.38	Wall Finish(es)	Paint	None	Remove flaking paint				
	Ceiling Finish	Paint	None	Remove flaking paint Approx. 5m2 of plaster missing				
	Floor Finish	Wood block Red clay tile	High Low	Retain Retain				
	Fixtures & Fittings							
	M&E Items	Heating pipes Lighting Switch Conduit	Low None None None	Remove all				Remove: • Heating pipes • Lighting • Switch • Conduit

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.39	Wall Finish(es)	Paint White Tile	Low None	Remove flaking paint Remove				Remove: White tile
	Ceiling Finish	Paint	None	Remove flaking paint Approx. 6m2 of plaster missing				Remove: Areas of loose plaster
	Floor Finish	Wood block Glazed tile	High Low	Retain Retain				
	Fixtures & Fittings							
	M&E Items	Heating pipes Wall light Switch Conduit Plug socket	Low None None None None	Remove all				Remove: - Heating pipes - Wall light - Switch - Conduit - Plug socket


Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.40	Wall Finish(es)	Paint White Tile	Low None	Remove flaking paint Remove				Remove: White tile
	Ceiling Finish	Paint	None	Remove flaking paint Approx. 8m2 of plaster missing				
	Floor Finish	Red clay tile	Low	Retain				
	Fixtures & Fittings	Mirrors	None	Remove all				Remove: Mirrors
	M&E Items	Light Conduit Plug socket Light switches	None None None None	Remove all				Remove: - Light - Conduit - Plug socket - Light switches

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.41	Wall Finish(es)	Paint	Low	Remove flaking paint				
	Ceiling Finish	Paint	None	Remove flaking paint Approx. 5m2 of plaster missing				
	Floor Finish	Wood block Glazed tile	High Low	Retain Retain				
	Fixtures & Fittings	Ventilation grill Timber batten	Low None	Retain Remove				Remove: Timber batten
	M&E Items	Heating pipes Plug socket Switch Conduit Light	Low None None None None	Remove all				Remove: - Heating pipes - Plug socket - Switch - Conduit - Light

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.42	Wall Finish(es)	Paint White Tile	Low None	Remove flaking paint Remove				Remove: White tile
	Ceiling Finish	Paint	None	Remove flaking paint Approx. 6m2 of plaster missing				
	Floor Finish	Red clay tile	Low	Retain				
	Fixtures & Fittings	Urinal Cistern brackets Mirror Timber batten	Low None None None	Remove all				Remove: - Urinal - Cistern brackets - Mirror - Timber batten
	M&E Items	Heating pipes Plug socket Switch Conduit Light Fuse box	Low None None None None None	Remove all				Remove: - Heating pipes - Plug socket - Switch - Conduit - Light - Fuse box

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.43	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Paint	None	Remove flaking apint Approx. 3m2 of plaster missing				
	Floor Finish	Wood block Glazed tile	High Low	Retain Retain				
	Fixtures & Fittings	Timber batten	None	Remove				Remove: Timber batten
	M&E Items	Light switch Conduit Light Plug socket Cable	None None None None None	Remove all				Remove: - Light switch - Conduit - Light - Plug socket - Cable

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.44	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 3m2 of plaster missing				
	Floor Finish	Red clay tile	Low	Retain				
	Fixtures & Fittings	Cistern brackets Timber boards	None None	Remove Remove				Remove: - Cistern brackets - Timber boards
	M&E Items	Waste pipe Conduit Light	None None None	Remove Remove Remove				Remove: - Waste pipe - Conduit - Light

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.45	Wall Finish(es)	Wallpaper Paint	None Low	Remove Remove flaking paint				
	Ceiling Finish	Paint	Low	Remove flaking paint				
	Floor Finish	Red clay tile	Low	Retain				
	Fixtures & Fittings	Shelf brackets Timber battens Timber switch mounting	None None None	Remove Remove Remove				Remove: - Shelf brackets - Timber battens - Timber switch mounting
	M&E Items	Gas pipe Conduit Misc. wires and cables Switches Misc. electrical items Heating pipes	Low None None None None Low	Remove all				Remove: - Gas pipe - Conduit - Misc. wires and cables - Switches - Misc. electrical items - Heating pipes

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.46	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Ceiling paper	None	Remove Approx. 4m2 of plaster missing				
	Floor Finish	Red clay tile White tile	Low Low	Retain Retain				
	Fixtures & Fittings							
	M&E Items	Conduit Light	None Nne	Remove Remove				Remove: • Conduit • Light


Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.47	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Paint	Low	Remove flaking paint				
	Floor Finish	Wood block Glazed tile	High Low	Retain Retain				
	Fixtures & Fittings							
	M&E Items	Switch Conduit Light Plug socket Misc. cable	None None None None None	Remove all				Remove: • Switch • Conduit • Light • Plug socket • Misc. cable


Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.48	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Ceiling paper	None	Remove Approx. 5m2 of plaster missing				
	Floor Finish	Wood block	High	Retain				
	Fixtures & Fittings							
	M&E Items	Switch Conduit Light Plug socket	None None None None	Remove all				Remove: • Switch • Conduit • Light • Plug socket

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.49	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Paint	Low	Remove flaking paint				
	Floor Finish	Wood block	High	Retain				
	Fixtures & Fittings							
	M&E Items	Light switch Conduit Heating pipe	None None Low	Remove all				Remove; • Light switch • Conduit • Heating pipe


Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.50	Wall Finish(es)	Wall paper	None	Remove				
	Ceiling Finish	Ceiling paper	None	Remove Approx. 10m2 of plaster missing				
	Floor Finish	Wood block	High	Retain				
	Fixtures & Fittings							
	M&E Items	Switch Conduit Light Plug socket Misc. wires	None None None None None	Remove all				Remove: • Switch • Conduit • Light • Plug socket • Misc. wires

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.51	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 3m2 of plaster missing				
	Floor Finish	Wood block Glazed tile	High Low	Retain Retain				
	Fixtures & Fittings							
	M&E Items	Early switch Conduit Light Plug socket	Low None None None	Remove all				Remove: • Early switch • Conduit • Light • Plug socket

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.52	Wall Finish(es)	Wallpaper White tile	None None	Remove Remove				Remove: White tile
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 4m2 of plaster missing				
	Floor Finish	Red clay tile	Low	Retain				
	Fixtures & Fittings							
	M&E Items	Conduit Light Timber conduit	None None None	Remove all				Remove: - Conduit - Light - Timber conduit


Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.53	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 1m2 of plaster missing				
	Floor Finish	Red clay tile	Low	Retain				
	Fixtures & Fittings	Timber boards	None	Remove				Remove: Timber boards
	M&E Items	Early light switch misc. electrical items Light Conduit Gas pipe	Low None None None Low	Remove all				Remove: - Early light switch - misc. electrical items - Light - Conduit - Gas pipe

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.54	Wall Finish(es)	Wallpaper White tile	None None	Remove Remove				Remove: White tile
	Ceiling Finish	Paint Ceiling tile	Low None	Remove flaking paint Remove Approx. 10m2 of plaster missing				Remove: Ceiling tile
	Floor Finish	Red clay tile	Low	Retain				
	Fixtures & Fittings	Timber boards	None	Remove				Remove: Timber boards
	M&E Items	Timber conduit Conduit Gas pipe Switches Plug socket Light	None None Low None None None	Remove all				Remove: - Timber conduit - Conduit - Gas pipe - Switches - Plug socket - Light

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.55	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 20m2 of plaster missing	 			
	Floor Finish	Wood block	High	Retain				
	Fixtures & Fittings							
	M&E Items	Early light switch Conduit	Low None	Remove all				Remove: • Early light switch • Conduit


Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.56	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 5m2 of plaster missing				
	Floor Finish	Wood block	High	Retain				
	Fixtures & Fittings							
	M&E Items	Conduit Gas pipe Early switch Plug socket Light	None Low None None None	Remove all				Remove: • Conduit • Gas pipe • Early switch • Plug socket • Light

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.57	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Ceiling paper	None	Remove Approx. 15m2 of plaster missing				
	Floor Finish	Wood block	High	Retain				
	Fixtures & Fittings	Ventilation grill	Low	Retain				
	M&E Items	Early light switch Conduit Light Misc. pipes	Low None None Low	Remove all				Remove: • Early light switch • Conduit • Light • Misc. pipes

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.58	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 1m2 of plaster missing				
	Floor Finish	Red clay tile	Low	Retain				
	Fixtures & Fittings	Timber battens Shelf brackets	None None	Remove Remove				Remove; • Timber battens • Shelf brackets
	M&E Items	Misc. electrical items Switch Conduit Gas pipe Early switch	None None None Low Low	Remove all				Remove: • Misc. electrical items • Switch • Conduit • Gas pipe • Early switch

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.59	Wall Finish(es)	Paint	Low	Remove flaking paint				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 4m2 of plaster missing				
	Floor Finish	Red clay tile	Low	Retain				
	Fixtures & Fittings	Shelves	None	Remove				Remove: Shelves
	M&E Items	Misc. cables Conduit	None None	Remove all				Remove: - Misc. cables - Conduit

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.60	Wall Finish(es)	Wallpaper Paint	None Low	Remove Remove flaking paint				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 10m2 of plaster missing				
	Floor Finish	Red clay tile	Low	Retain				
	Fixtures & Fittings							
	M&E Items	Early switch Conduit Light Plug socket Gas pipe Misc. electrical items	Low None None None Low None	Remove all				Remove: • Early switch • Conduit • Light • Plug socket • Gas pipe • Misc. electrical items

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.61	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 2m2 of plaster missing				
	Floor Finish	Wood block	High	Retain				
	Fixtures & Fittings							
	M&E Items	Plug socket Early light switch Conduit	None Low None	Remove all				Remove: • Plug socket • Early light switch • Conduit

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.62	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 6m2 of plaster missing				
	Floor Finish	Wood block	High	Retain				
	Fixtures & Fittings							
	M&E Items	Early light switch Conduit Light	Low None None	Remove all				Remove: • Early light switch • Conduit • Light

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.63	Wall Finish(es)	Paint	Low	Remove flaking paint				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 1m2 of plaster missing				
	Floor Finish	Red clay tile	Low	Retain				
	Fixtures & Fittings							
	M&E Items	Light switch Conduit Light Misc. cable Misc. pipe	None None None None None	Remove all				Remove: • Light switch • Conduit • Light • Misc. cable • Misc. pipe

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.64	Wall Finish(es)	Wallpaper White tile	None None	Remove Remove				Remove: White tile
	Ceiling Finish	Ceiling paper	None	Remove				
	Floor Finish	Red clay tile	Low	Retain				
	Fixtures & Fittings	Timber batten	None	Remove				Remove: Timber batten
	M&E Items	Switch Conduit Plug sockets Misc. cables	None None None None	Remove all				Remove: - Switch - Conduit - Plug sockets - Misc. cables


Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.65	Wall Finish(es)	Wallpaper White tile	None None	Remove Remove				Remove: White tile
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 5m2 of plaster missing				
	Floor Finish	Red clay tile	Low	Retain				
	Fixtures & Fittings	Cupboard Shelving Timber boards Timber battens	Low Low None None	Remove Remove Remove Remove				Remove; - Cupboard - Shelving - Timber boards - Timber battens
	M&E Items	Misc. cables Conduit Light	None None None	Remove all				Remove: - Misc. cables - Conduit - Light

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.66	Wall Finish(es)	Paint	Low	remove flaking paint				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 3m2 of plaster missing				
	Floor Finish	Red clay tile	Low	Retain				
	Fixtures & Fittings	Timber light mount	None	Remove				Remove: Timber light mount
	M&E Items	Light Heating pipe Redundant pipe	None Low Low	Remove all				Remove: - Light - Heating pipe - Redundant pipe

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.67	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 5m2 of plaster missing				
	Floor Finish	Wood block	High	Retain				
	Fixtures & Fittings							
	M&E Items	Switch Conduit Modern light Heating pipe Gas pipe Misc. wires	None None None Low Low None	Remove all				Remove: • Switch • Conduit • Modern light • Heating pipe • Gas pipe • Misc. wires

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.68	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 20m2 of plaster missing				
	Floor Finish	Wood block (lifted)	High	Retain				
	Fixtures & Fittings							
	M&E Items	Light switch Heating pipe	None Low	Remove Remove				Remove: - Light switch - Heating pipe

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.69	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 6m2 of plaster missing				
	Floor Finish	Wood block Vinyl and plastic nosing to steps	High None	Retain Remove				Remove: Nosing to stairs
	Fixtures & Fittings	Hooks Radiator brackets	None Low	Remove Remove				Remove: - Hooks - Radiator brackets
	M&E Items	Heating pipe Modern light Conduit Switch Plug socket	Low None None None None	Remove all				

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.70	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 15m2 of plaster missing				
	Floor Finish	Wood block	High	Retain				
	Fixtures & Fittings	Radiator brackets	Low	Remove				Remove: Radiator brackets
	M&E Items	Heating pipe Switch Modern light	Low None None	Remove all				Remove: - Heating pipe - Switch - Modern light

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.71	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Ceiling paper	None	Remove Approx. 10m2 of plaster missing	 			
	Floor Finish	Wood block	High	Retain				
	Fixtures & Fittings	Ventilation grill Radiator brackets	Low Low	Retain Remove				Remove: Radiator brackets
	M&E Items	Heating pipes Switch Conduit Modern light	Low None None None	Remove all				Remove: - Heating pipes - Switch - Conduit - Modern light

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.72	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Ceiling paper	None	Remove Approx. 3m2 of plaster missing				Remove: Loose ceiling paper
	Floor Finish	Adhesive over wood block	None / High	Remove adhesive and retain wood block				
	Fixtures & Fittings	Radiator brackets	Low	Remove				Remove: Radiator brackets
	M&E Items	Misc. wires Modern light Heating pipe	None None Low	Remove all				Remove: - Misc. wires - Modern light - Heating pipe

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.73	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Ceiling paper	None	Remove Approx. 15m2 of plaster missing				
	Floor Finish	Wood block (partly lifted) Glazed tile Carpet and adhesive	High Low None / none	Retain Retain Remove				Remove: • Carpet
	Fixtures & Fittings	Radiator brackets	Low	Remove				Remove: • Radiator brackets
	M&E Items	Switch Conduit Modern light Heating pipe 2no. Radiators	None None None Low Low	Remove all				Remove: • Switch • Conduit • Modern light • Heating pipe • 2no. Radiators

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.74	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Paint	Low	Remove flaking paint				
	Floor Finish	Wood block Red clay tile	High Low	Retain Retain				
	Fixtures & Fittings							
	M&E Items	Switch Conduit Heating pipe	None None Low	Remove all				Remove: • Switch • Conduit • Heating pipe

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.75	Wall Finish(es)	Paint	Low	Remove flaking paint				
	Ceiling Finish	Paint	Low	Remove flaking paint				
	Floor Finish	Red clay tile	Low	Retain				
	Fixtures & Fittings	Cistern brackets	None	Remove				Remove: Cistern brackets
	M&E Items	Light switch Conduit Lights Plug socket Heating pipe	None None None None Low	Remove all				Remove: - Light switch - Conduit - Lights - Plug socket - Heating pipe

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.76	Wall Finish(es)	Wallpaper Paint	None Low	Remove Remove flaking paint				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 5m2 of plaster missing				
	Floor Finish	Red clay tile	Low	Retain				
	Fixtures & Fittings	Speaker	Medium	Retain				
	M&E Items	Light switch Conduit Lights Gas pipe	None None None Low	Remove all				Remove: • Light switch • Conduit • Lights • Gas pipe

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.77	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	N/A	N/a	4m2 of plaster missing				
	Floor Finish	Red clay tile	Low	Retain				
	Fixtures & Fittings	Toilet roll holder	None	Remove				Remove: Toilet roll holder
	M&E Items	Light switch Conduit Heating pipe Water pipe	None None Low Low	Remove all				Remove: - Light switch - Conduit - Heating pipe - Water pipe

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.78	Wall Finish(es)	Wallpaper Paint	None Low	Remove Remove flaking paint				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 8m2 of plaster missing				
	Floor Finish	Wood block	High	Retain				
	Fixtures & Fittings	Wall hatch Timber batten Radiator bracket	Low None Low	Retain Remove Remove				Remove: • Timber batten • Radiator bracket
	M&E Items	Light switch Conduit Light Heating pipe Radiator	None None None Low Low	Remove all				Remove: • Light switch • Conduit • Light • Heating pipe • Radiator

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.79	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 6m2 of plaster missing				
	Floor Finish	Adhesive over wood block	None / High	Remove adhesive and retain wood block				
	Fixtures & Fittings	Timber board Radiator brackets	None Low	Remove Remove				Remove: • Timber board • Radiator brackets
	M&E Items	Light switch Conduit Light Heating pipe Radiator	None None None Low Low	Remove all				Remove: • Light switch • Conduit • Light • Heating pipe • Radiator

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.80	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Ceiling paper on plasterboard	None	Remove ceiling paper				
	Floor Finish	Carpet and adhesive over wood block	None / None / High	Remove carpet and adhesive and retain wood block				Remove: • Carpet
	Fixtures & Fittings	Wall hatch	Low	Retain				
	M&E Items	Plug sockets Switches Modern lights	None None None	Remove all				Remove: • Plug sockets • Switches • Modern lights

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.81	Wall Finish(es)	Paint	Low	remove flaking paint				
	Ceiling Finish	Paint	Low	remove flaking paint				
	Floor Finish	Red clay tile	Low	Retain				
	Fixtures & Fittings	Shelves Various hooks on timber board	None Various	Remove Retain earlier hooks				Remove: - Shelves - Various hooks on timber board (REMOVE ONLY MODERN HOOKS)
	M&E Items							

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.82	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 5m2 of plaster missing				
	Floor Finish	Adhesive over wood block	None / High	Remove adhesive and retain wood block				
	Fixtures & Fittings	Built in cupboard Wall hatch Radiator brackets	None Low Low	Remove Remove Remove				Remove: - Built in cupboard - Wall hatch - Radiator brackets
	M&E Items	Light switch Conduit Modern lights Heating pipe Radiator	None None None Low Low	Remove all				Remove: - Light switch - Conduit - Modern lights - Heating pipe - Radiator


Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.83	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 2m2 of plaster missing				
	Floor Finish	Adhesive over wood block	None / High	Remove adhesive and retain wood block				
	Fixtures & Fittings	Timber batten Radiator brackets Shelves Wall hatch	None Low None Low	Remove Remove Remove Remove				Remove: • Timber batten • Radiator brackets • Shelves • Wall hatch
	M&E Items	Light switch Conduit Modern light Misc. wires and electrical boxes Heating pipe Radiator Plug socket	None None None None Low Low None	Remove all				Remove: • Light switch • Conduit & Modern light • Misc. wires and electrical boxes • Heating pipe / Radiator • Plug socket


Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.84	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 100m2 of plaster missing				
	Floor Finish	Wood block (50% lifted)	High	Retain				
	Fixtures & Fittings	Fireman's cupboard Curtain rails	High None	Retain Remove				Remove: Curtain rails
	M&E Items	Light switch Conduit Plug socket Misc. cables	None None None None	Remove all				Remove: - Light switch - Conduit - Plug socket - Misc. cables

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.85	Wall Finish(es)	Paint	Low	Remove flaking paint				
	Ceiling Finish	Paint	Low	Remove flaking paint				
	Floor Finish	Red clay tile	Low	Retain				
	Fixtures & Fittings	Timber board Toilet roll holder	None None	Remove Remove				Remove: • Timber board • Toilet roll holder
	M&E Items	Light switch Conduit Light Waster pipe	None None None None	Remove all				Remove: • Light switch • Conduit • Light • Waster pipe

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.86	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	N/A	N/A	12m2 of missing ceiling				
	Floor Finish	Wood block	High	Retain				
	Fixtures & Fittings	Raised hearth	None	Remove				Remove: Raised hearth
	M&E Items	Conduit	None	Remove				Remove: Conduit

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.87	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 10m2 of plaster missing				
	Floor Finish	Carpet and adhesive over wood block Red clay tile	None / None / High Low	Remove carpet and adhesive and retain wood block Retain				Remove: • Carpet
	Fixtures & Fittings	Cupboard Ventilation grill Fireman's cupboard	None Low High	Remove Retain Retain				Remove: • Cupboard
	M&E Items	Fuse box Switches Wall lights Plu sockets	None None None None	Remove all				Remove: • Fuse box • Switches • Wall lights • Plug sockets

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.88	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 3m2 of plaster missing				
	Floor Finish	Red clay tile White tile	Low Low	Retain Retain				
	Fixtures & Fittings	Shelf Timber batten	None None	Remove Remove				Remove: - Shelf - Timber batten
	M&E Items	Switch Conduit Light Misc. pipe	None None None None	Remove all				Remove: - Switch - Conduit - Light - Misc. pipe

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.89	Wall Finish(es)	Wallpaper White tile	None None	Remove Remove				Remove: White tile
	Ceiling Finish	Ceiling paper	None	Remove Approx. 6m2 of plaster missing				
	Floor Finish	Red clay tile	Low	Retain				
	Fixtures & Fittings	Timber boards Misc. timber item	None None	Remove Remove				Remove: - Timber boards - Misc. timber item
	M&E Items	Conduit Ventilation ductwork Misc. cables	None None None	Remove Remove Remove				Remove: - Conduit - Ventilation ductwork - Misc. cables



Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.90	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Ceiling paper	None	Remove Approx. 4m2 of plaster missing				
	Floor Finish	Adhesive over wood block	None / High	Remove adhesive and retain wood block				
	Fixtures & Fittings	Wall hatch Ventilation grill	Low Low	Retain Retain				
	M&E Items	Light switch Conduit Modern light Plug socket	None None None None	Remove all				Remove: • Light switch • Conduit • Modern light • Plug socket

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.91	Wall Finish(es)	Wallpaper White tile	None None	Remove Remove				Remove: White tile
	Ceiling Finish	Ceiling paper Paint	None Low	Remove Remove flaking paint Approx. 5m2 of plaster missing				
	Floor Finish	Red clay tile White tile	Low Low	Retain Retain				
	Fixtures & Fittings	Timber batten	None	Remove				Remove: Timber batten
	M&E Items	Switches Conduit Light Plug socket	None None None None	Remove all				Remove: - Switches - Conduit - Light - Plug socket

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.92	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 8m2 of plaster missing				
	Floor Finish	Wood block Glazed tile	High Low	Retain Retain				
	Fixtures & Fittings	Fireman's cupboard Ventilation grill	High Low	Retain Retain				
	M&E Items	Early light switch Conduit Light	Low None None	Remove all				Remove: • Early light switch • Conduit • Light

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.93	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Ceiling paper	None	Remove Approx. 10m2 of plaster missing				
	Floor Finish	Wood block Glazed tile	High Low	Retain Retain				
	Fixtures & Fittings	Light switch mount	None	Remove				Remove: Light switch mount
	M&E Items	Plug socket Conduit Misc. cables	None None None	Remove all				Remove: - Plug socket - Conduit - Misc. cables

Room Reference	Element	Description	Significance	Removed or Retained	Photographs	Allied London Phase 1A Requirements
2.94	Wall Finish(es)				See 2.93	
	Ceiling Finish					
	Floor Finish					
	Fixtures & Fittings					
	M&E Items					

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.95	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Ceiling paper	None	Remove Approx. 6m2 of plaster missing				
	Floor Finish	Wood block	High	Retain				
	Fixtures & Fittings							
	M&E Items	Early light switch Conduit Light Ventilation ductwork Plug socket	Low None None Low None	Remove all				Remove: • Early light switch • Conduit • Light • Ventilation ductwork • Plug socket

Room Reference	Element	Description	Significance	Removed or Retained	Photographs	Allied London Phase 1A Requirements
2.96	Wall Finish(es)				See 2.95	
	Ceiling Finish					
	Floor Finish					
	Fixtures & Fittings					
	M&E Items					



Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.97	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 2m2 of plaster missing				
	Floor Finish	Wood block Glazed tile	High Low	Retain Retain				
	Fixtures & Fittings	Timber plug socket mount Ventilation grill	None Low	Remove Retain				Remove: Timber plug socket mount
	M&E Items	Early light switch Conduit Light	Low None None	Remove all				Remove: - Early light switch - Conduit - Light

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.98	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 0.5m2 of plaster missing				
	Floor Finish	Wood block	High	Retain				
	Fixtures & Fittings	Timber plug socket mount Ventilation grill Firemans cupboard and pole	None Low High	Remove Retain Retain				Remove: • Timber plug socket mount
	M&E Items	Conduit Light Plug socket	None None None	Remove all				Remove: • Conduit • Light • Plug socket

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.99	Wall Finish(es)	Wallpaper White tile	None None	Remove Remove				Remove: White tile
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 6m2 of plaster missing				
	Floor Finish	Red clay tile White tile	Low Low	Retain Retain				
	Fixtures & Fittings	Timber board	None	Remove				Remove: Timber board
	M&E Items	Light switch Conduit Light Plug socket Cable	None None None None None	Remove all				Remove: - Light switch - Conduit - Light - Plug socket - Cable

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.100	Wall Finish(es)	Wallpaper Tile	None None	Remove Remove				Remove: Tile
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 8m2 of plaster missing				
	Floor Finish	Red clay tile	Low	Retain				
	Fixtures & Fittings	Timber batten Timber board	None None	Remove Remove				Remove: - Timber batten - Timber board
	M&E Items	Conduit Misc. cable Ventilation ductwork	None None Low	Remove all				Remove: - Conduit - Misc. cable - Ventilation ductwork

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.101	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 6m2 of plaster missing				
	Floor Finish	Red clay tile Yellow tile	Low Low	Retain Retain				
	Fixtures & Fittings							
	M&E Items							

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.102	Wall Finish(es)	Wallpaper Paint	None Low	Remove Remove flaking paint				
	Ceiling Finish	N/A	N/A	7m2 of ceiling missing				
	Floor Finish	Red clay tile	Low	Retain				
	Fixtures & Fittings							
	M&E Items	Misc. electrical items Early switches Conduit	None Low None	Remove all				Remove: - Misc. electrical items - Early switches - Conduit

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.103	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Ceiling paper	Low	Remove flaking paint Approx. 2m2 of plaster missing				
	Floor Finish	Wood block Glazed tile	High Low	Retain Retain				
	Fixtures & Fittings	Fireman's cupboard	High	Retain				
	M&E Items	Early light switch Conduit Plug socket	Low None None	Remove all				Remove: • Early light switch • Conduit • Plug socket

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.104	Wall Finish(es)	Glazed brick	High	Retain				
	Ceiling Finish	Exposed concrete	N/A	N/A				
	Floor Finish	Concrete	N/A	N/A				
	Fixtures & Fittings	Riser cupboard	Low	Retain				
	M&E Items	Misc. wires Heating pipes Conduit	None Low None	Remove all				Remove: - Misc. wires - Heating pipes - Conduit

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.105	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 4m2 of plaster missing				
	Floor Finish	Wood block Glazed tile	High Low	Retain Retain				
	Fixtures & Fittings							
	M&E Items	Light switch Conduit	None None	Remove Remove				Remove: • Light switch • Conduit

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.106	Wall Finish(es)	Wallpaper White tile	None None	Remove Remove				Remove: White tile
	Ceiling Finish	Ceiling tile	None	Remove Approx. 4m2 of plaster missing				Remove: Ceiling tile
	Floor Finish	Red clay tile White tile	Low Low	Retain Retain				
	Fixtures & Fittings	Timber light switch mount Shelf over fireplace	None None	Remove Remove				Remove: - Timber light switch mount - Shelf over fireplace
	M&E Items	Light switches Conduit Switches Plug sockets	None None None None	Remove all				Remove: - Light switches - Conduit - Switches - Plug sockets


Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.107	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 8m2 of plaster missing				
	Floor Finish	Wood block Glazed tile	High Low	Retain Retain				
	Fixtures & Fittings							
	M&E Items	Ventilation ductwork Conduit Plug socket	None None None	Remove all				Remove: • Ventilation ductwork • Conduit • Plug socket


Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.108	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Ceiling paper	None	Remove Approx. 10m2 of plaster missing				Remove: Loose ceiling paper
	Floor Finish	Wood block Glazed tile	High Low	Retain Retain				
	Fixtures & Fittings	Curtain rail	None	Remove				Remove: Curtain rail
	M&E Items	Light switch Conduit Misc. cable Plug socket	None None None None	Remove all				Remove: - Light switch - Conduit - Misc. cable - Plug socket

Room Reference	Element	Description	Significance	Removed or Retained	Photographs	Allied London Phase 1A Requirements
2.109	Wall Finish(es)				See 2.108	
	Ceiling Finish					
	Floor Finish					
	Fixtures & Fittings					
	M&E Items					

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.110	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 4m2 of plaster missing				
	Floor Finish	Wood block Glazed tile	High Low	Retain Retain				
	Fixtures & Fittings	Fireman's cupboard	High	Retain				
	M&E Items	Light switch Conduit Plug socket	None None None	Remove all				Remove: • Light switch • Conduit • Plug socket

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.111	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 2m2 of plaster missing				
	Floor Finish	Wood block Glazed tile	High Low	Retain Retain				
	Fixtures & Fittings	Timber board over vent	None / low	Remove timber board				Remove: Timber board over vent
	M&E Items	Early light switch Conduit Misc. cables	Low None None	Remove all				Remove: - Early light switch - Conduit - Misc. cables

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.112	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	N/A	N/A	Approx. 5m2 of plaster missing				
	Floor Finish	Red clay tile	Low	Retain				
	Fixtures & Fittings	Timber boards Ventilation ductwork	None Low	Remove Remove				Remove: - Timber boards - Ventilation ductwork
	M&E Items	Early light switch Conduit Misc. electrical items Plug socket Misc. cables	Low None None None None	Remove all				Remove: - Early light switch - Conduit - Misc. electrical items - Plug socket - Misc. cables

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.113	Wall Finish(es)	Wallpaper White tile Black tile	None None None	Remove Remove Remove				Remove: - White tile - Black tile
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 10m2 of plaster missing				
	Floor Finish	Red clay tile	Low	Retain				
	Fixtures & Fittings	Boxing in Timber boards Timber battens	None Low None	Remove Remove Remove				Remove: - Boxing in - Timber boards - Timber battens
	M&E Items	Conduit Pipe with tap Misc. cables	None None None	Remove all				Remove: - Conduit - Pipe with tap - Misc. cables

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.114	Wall Finish(es)	Wallpaper White tile	None None	Remove Remove				Remove: White tile
	Ceiling Finish	Ceiling paper	None	Remove Approx. 3m2 of plaster missing				
	Floor Finish	Red clay tile White tile	Low Low	Retain Retain				
	Fixtures & Fittings	Timber battens Timber boards Ventilation grill	None None Low	Remove Remove Retain				Remove: - Timber battens - Timber boards
	M&E Items	Switches Plug socket Conduit Gas tap Misc. cables	None None None Low None	Remove Remove Remove Retain Remove				Remove: - Switches - Plug socket - Conduit - Misc. cables

Room Reference	Element	Description	Significance	Removed or Retained	Photographs	Allied London Phase 1A Requirements
2.115	Wall Finish(es)				See 2.113	
	Ceiling Finish					
	Floor Finish					
	Fixtures & Fittings					
	M&E Items					

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.116	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 4m2 of plaster missing				
	Floor Finish	Wood block Glazed tile	High Low	Retain Retain				
	Fixtures & Fittings							
	M&E Items	Conduit	None	Remove				Remove: Conduit

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.117	Wall Finish(es)	Wallpaper Pink tile Black tile	None None None	Remove Remove Remove				Remove: • Pink tile • Black tile
	Ceiling Finish	Ceiling paper	None	Remove Approx. 8m2 of plaster missing				
	Floor Finish	Red clay tile	Low	Retain				
	Fixtures & Fittings	Boxing in Timber bard Timber battens	None None None	Remove Remove Remove				Remove: • Boxing in • Timber board • Timber battens
	M&E Items	Water pipe	None	Remove				Remove: • Water pipe

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.118	Wall Finish(es)	Wallpaper White tile	None None	Remove Remove				Remove: White tile
	Ceiling Finish	Ceiling paper	None	Remove Approx. 5m2 of plaster missing				
	Floor Finish	Red clay tile White tile	Low Low	Retain Retain				
	Fixtures & Fittings	Timber boards Timber batten	None None	Remove Remove				Remove: - Timber boards - Timber batten
	M&E Items	Misc. cables Plug sockets	None None	Remove Remove				Remove: - Misc. cables - Plug sockets

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.119	Wall Finish(es)	Wallpaper Paint	None Low	Remove Remove flaking paint				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 5m2 of plaster missing				
	Floor Finish	Wood block (lifted) Glazed tile	High Low	Retain Retain				
	Fixtures & Fittings							
	M&E Items	Conduit	None	Remove				Remove: Conduit

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.120	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Ceiling paper	None	Remove Approx. 10m2 of plaster missing				
	Floor Finish	Wood block Glazed tile	High Low	Retain Retain				
	Fixtures & Fittings							
	M&E Items	Ventilation ductwork Misc. cables	Low None	Remove Remvove				Remove: - Ventilation ductwork - Misc. cables

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.121	Wall Finish(es)	Paint	Low	remove flaking paint				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 1m2 of plaster missing				
	Floor Finish	Red clay tile	Low	Retain				
	Fixtures & Fittings							
	M&E Items	Switch Conduit Light	None None None	Remove Remove Remove				Remove: • Switch • Conduit • Light


Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.122	Wall Finish(es)	Paint	Low	Remove flaking paint				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 12m2 of plaster missing				
	Floor Finish	Wood block (lifted) Glazed tile	High Low	Retain Retain				
	Fixtures & Fittings	Raised hearth (not original)	None	Remove				Remove: • Raised hearth (not original)
	M&E Items	Light switch Plug socket Misc. cables Modern light	None None None None	Remove all				Remove: • Light switch • Plug socket • Misc. cables • Modern light


Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.123	Wall Finish(es)	Wallpaper Paint	None Low	Remove Remove flaking paint				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 25m2 of plaster missing				
	Floor Finish	Wood block (lifted) Glazed tile	High Low	Retain Retain				
	Fixtures & Fittings	Raised hearth (not original)	None	Remove				Remove: • Raised hearth (not original)
	M&E Items	Switches Plug socket Misc. cables	None None None	Remove all				Remove: • Switches • Plug socket • Misc. cables

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.124	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	N/A	N/A	Approx. 15m2 of plaster missing				
	Floor Finish	Red clay tile White tile	Low Low	Retain Retain				
	Fixtures & Fittings	Timber boards	None	Remove				Remove: Timber boards
	M&E Items	Misc. cables Switch	None None	Remove Remove				Remove: - Misc. cables - Switch

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.125	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 2m2 of plaster missing				
	Floor Finish	Wood block Glazed tile	High Low	Retain Retain				
	Fixtures & Fittings	Pinboard Timber wall mount	None None	Remove Remove				Remove: - Pinboard - Timber wall mount
	M&E Items	Conduit Light Plug socket Cables	None None None None	Remove all				Remove: - Conduit - Light - Plug socket - Cables


Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.126	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 1m2 of plaster missing				
	Floor Finish	Wood block Glazed tile	High Low	Retain Retain				
	Fixtures & Fittings	Timber wall mount	None	Remove				Remove: Timber wall mount
	M&E Items	Conduit Light	None None	Remove Remove				Remove: - Conduit - Light




Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.127	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Paint	Low	remove flaking paint				
	Floor Finish	Red clay tile	Low	Retain				
	Fixtures & Fittings	Shelf brackets Timber boards	None None	Remove Remove				Remove: - Shelf brackets - Timber boards
	M&E Items	Conduit Light Plug socket	None None None	Remove all				Remove: - Conduit - Light - Plug socket

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.128	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 5m2 of plaster missing				
	Floor Finish	Red clay tile Decorative tile	Low High	Retain Retain				
	Fixtures & Fittings	Timber boards Timber battens	None None	Remove Remove				Remove: • Timber boards • Timber battens
	M&E Items	Conduit Light Misc. electrical items	None None None	Remove all				Remove: • Conduit • Light • Misc. electrical items

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.129	Wall Finish(es)	Wallpaper White tile	None None	Remove Remove				Remove: White tile
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 2m2 of plaster missing				
	Floor Finish	Red clay tile	Low	Retain				
	Fixtures & Fittings	Shelf bracket Timber boards	None None	Remove Remove				Remove: - Shelf bracket - Timber boards
	M&E Items	Plug socket Conduit Light	None None None	Remove all				Remove: - Plug socket - Conduit - Light

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.130	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 1m2 of plaster missing				
	Floor Finish	Red clay tile	Low	Retain				
	Fixtures & Fittings	Timber boards Bathtub	None None	Remove Remove				Remove: • Timber boards • Bathtub
	M&E Items	Conduit Light	None None	Remove Remove				Remove: • Conduit • Light

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.131	Wall Finish(es)	Glazed brick	High	Retain				
	Ceiling Finish	Painted concrete	N/A	N/A				
	Floor Finish	Concrete stairs	High	Retain				
	Fixtures & Fittings	Staircase balustrade	High	Retain				
	M&E Items	Heating pipes Conduit Light	Low None None	Remove all				Remove: • Heating pipes • Conduit • Light


Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.132	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 6m2 of plaster missing				
	Floor Finish	Red clay tile	Low	Retain				
	Fixtures & Fittings							
	M&E Items	Misc. electrical items Switches Sockets Gas pipe	None None None Low	Remove all				Remove: - Misc. electrical items - Switches - Sockets - Gas pipe

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.133	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 4m2 of plaster missing				
	Floor Finish	Floor tile over wood block	None / High	Remove floor tile and retain Wood block				
	Fixtures & Fittings	Cupboard	None	Remove				Remove: Cupboard
	M&E Items	Gas pipe Switches Misc. electrical items Plug socket	Low None None None	Remove all				Remove: - Gas pipe - Switches - Misc. electrical items - Plug socket

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.134	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 4m2 of plaster missing				
	Floor Finish	Adhesive over wood block	None / High	Remove floor tile and retain Wood block				
	Fixtures & Fittings	Staircase balustrade	Low	Retain				
	M&E Items	Gas pipe Conduit	Low None	Remove all				Remove: • Gas pipe • Conduit

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.135	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 4m2 of plaster missing				
	Floor Finish	Adhesive over wood block	None / High	Remove floor tile and retain Wood block				
	Fixtures & Fittings	Staircase balustrade	Low	Retain				
	M&E Items	Gas pipe Conduit	Low None	Remove all				Remove: • Gas pipe • Conduit

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.136	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Wallpaper	None	Remove				
	Floor Finish	Vinyl	None	Remove				
	Fixtures & Fittings	Shelf Fixed cupboard Hooks	None None None	Remove Remove Remove				Remove: - Shelf - Fixed cupboard - Hooks
	M&E Items	Light switch Modern light	None None	Remove Remove				Remove: - Light switch - Modern light

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.137	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Paint	Low	Remove flaking paint				
	Floor Finish	Red clay tile	Low	Retain				
	Fixtures & Fittings							
	M&E Items	Light switch Conduit Light	None None None	Remove all				Remove: • Light switch • Conduit • Light

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.138	Wall Finish(es)	Wallpaper White tile	None None	Remove Remove				Remove: White tile
	Ceiling Finish	Ceiling tile	None	Remove				Remove: Ceiling tile
	Floor Finish	Red clay tile	Low	Retain				
	Fixtures & Fittings							
	M&E Items	Plug socket Light switch Conduit	None None None	Remove all				Remove: - Plug socket - Light switch - Conduit


Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.139	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	No ceiling	N/A	N/A				
	Floor Finish	Red clay tile	Low	Retain				
	Fixtures & Fittings							
	M&E Items	Misc. electrical items Conduit	None None	Remove all				Remove: - Misc. electrical items - Conduit

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.140	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 5m2 of plaster missing				
	Floor Finish	Red clay tile	Low	Retain				
	Fixtures & Fittings							
	M&E Items	Conduit Light	None None	Remove all				Remove: • Conduit • Light



Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.141	Wall Finish(es)	Paint	Low	Remove flaking paint				
	Ceiling Finish	No ceiling	N/A	N/A				
	Floor Finish	Wood block (lifted)	High	Retain				
	Fixtures & Fittings	Staircase	High	Retain				
	M&E Items	Light switch Conduit	None None	Remove all				Remove: • Light switch • Conduit

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.142	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	No ceiling	N/A	N/A				
	Floor Finish	Red clay tile	Low	Retain				
	Fixtures & Fittings							
	M&E Items	Timber light Early switches Misc. electrical items	None Low None	Remove all				Remove: • Timber light • Early switches • Misc. electrical items

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.143	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	No ceiling	N/A	N/A				
	Floor Finish	Red clay tile	Low	Retain				
	Fixtures & Fittings							
	M&E Items	Misc. electrical items	None	Remove all				Remove: Misc. electrical items


Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.144	Wall Finish(es)	Paint White tile	Low None	Remove flaking paint Remove				Remove: White tile
	Ceiling Finish	Paint	Low	Remove flaking paint				
	Floor Finish	Red clay tile	Low	Retain				
	Fixtures & Fittings	Timber cupboard Battens Shelf	None None None	Remove Remove Remove				Remove: - Timber cupboard - Battens - Shelf
	M&E Items	Pipe Modern light Misc. cables	None None None	Remove all				Remove: - Pipe - Modern light - Misc. cables


Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.145	Wall Finish(es)	Paint	None	Remove flaking paint				
	Ceiling Finish	Paint	None	Remove				
	Floor Finish	Vinyl and step nosings		Remove				Remove: Step nosings
	Fixtures & Fittings	Steel doors Battens Staircase and balustrade	Medium None High	Retain Remove Retain				Remove: Battens
	M&E Items	Misc. cables Switches Conduit Light Fuse board Misc. telephone wires	None None None None None None	Remove all				Remove: - Misc. cables - Switches - Conduit - Light - Fuse board - Misc. telephone wires

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.146	Wall Finish(es)	Paint on glazed bricks Plyboard sheets to lift shaft	None / high None	Remove paint and retain glazed brick Remove				
	Ceiling Finish	Paint	Low	Remove flaking paint				
	Floor Finish	Terrazzo tile Floor paint	Medium None	Retain Remove				
	Fixtures & Fittings	Timber balustrade Lift doors Boxing in Fire hose pipe outlet	Medium Medium None High	Retain Retain Remove Retain				Remove: Boxing in
	M&E Items	Misc. pipes Misc. cables Conduit Modern lights Misc. electrical items	Low None None None None	Remove all				Remove: - Misc. pipes - Misc. cables - Conduit - Modern lights - Misc. electrical items

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.147	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 2m2 of ceiling missing				
	Floor Finish	Wood block	High	Retain				
	Fixtures & Fittings	Staircase	High	Retain				
	M&E Items	Timber conduit Heating pipe Light switch Conduit Light	Low Low None None None	Remove all				Remove: • Timber conduit • Heating pipe • Light switch • Conduit • Light


Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.148	Wall Finish(es)	Paint	Low	Remove flaking paint				
	Ceiling Finish	Paint	Low	Remove flaking paint				
	Floor Finish	Red lay tile	Low	Retain				
	Fixtures & Fittings							Remove: Scrap timber items
	M&E Items	Conduit Light	None None	Remove all				Remove: - Conduit - Light

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.149	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Ceiling paper	None	Remove Approx. 8m2 of plaster missing				
	Floor Finish	Wood block	High	Retain				
	Fixtures & Fittings	Fire extinguisher bracket	Low	Remove				Remove: Fire extinguisher bracket
	M&E Items	Heating pipe Conduit Light Misc. wire	Low None None None	Remove all				Remove: - Heating pipe - Conduit - Light - Misc. wire




Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
2.150	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 8m2 of plaster missing				
	Floor Finish	Wood block Red clay tile	High Low	Retain Retain				
	Fixtures & Fittings	Timber board and hooks Shelves Battens	None None None	Remove Remove Remove				Remove: • Timber board and hooks • Shelves • Battens
	M&E Items	Switches Modern light Heating pipe	None None Low	Remove all				Remove: • Switches • Modern light • Heating pipe


THIRD FLOOR – ROOM SCHEDULE


Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.01	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Ceiling paper Timber boarding, painted	None Low	Remove Approx. 25m2 of plaster missing Remove flaking paint				
	Floor Finish	Wood block (lifted)	High	Retain				
	Fixtures & Fittings	Non - original hearth with cream tile Timber boarding Timber battens Radiator brackets	None Low None None	Remove Retain Remove Remove				Remove: - Non - original hearth with cream tile - Timber battens - Radiator brackets
	M&E Items	Light switch Modern light Heating pipes Cast iron radiators	None None Low Low	Remove Remove Remove Remove and retain for re-use				Remove: - Light switch - Modern light - Heating pipes - Cast iron radiators


Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.02	Wall Finish(es)	Glazed brick	High	Retain				
	Ceiling Finish	N/A	N/A	8m2 of plaster missing				
	Floor Finish	Exposed concrete	N/A	N/A				
	Fixtures & Fittings	Timber batten	None	Remove				Remove: Timber batten
	M&E Items	Light switch Conduit	None None	Remove Remove				Remove: - Light switch - Conduit



Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.03	Wall Finish(es)	Glazed brick partially painted	High / None	Remove paint and retain glazed brick				
	Ceiling Finish	N/A	N/A	11m2 of plaster missing				
	Floor Finish	Vinyl	None	Remove				
	Fixtures & Fittings	Timber boards Fire extinguisher bracket	None Low	Remove Remove				Remove: • Timber boards • Fire extinguisher bracket
	M&E Items	Heating pipes Fire alarm Conduit Plug socket Misc. cables	Low Low None None None	Remove all				Remove: • Heating pipes • Fire alarm • Conduit • Plug socket • Misc. cables



Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.04	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 30m2 of plaster missing				
	Floor Finish	Exposed concrete	N/A	N/A				
	Fixtures & Fittings	Timber batten Timber boxing in Conduit Chain	None None None	Remove Remove Remove				Remove: • Timber batten • Timber boxing in • Conduit • Chain
	M&E Items	Heating pipes Light switch Conduit Lights Plug sockets Misc. cables	Low None None None None None	Remove all				Remove: • Heating pipes • Light switch • Conduit • Lights • Plug sockets • Misc. cables

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.05	Wall Finish(es)	Paint White tile	Low None	Remove flaking paint Remove				Remove: White tile
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 12m2 of plaster missing				
	Floor Finish	Exposed concrete	N/A	N/A				
	Fixtures & Fittings	Timber battens Hooks Timber boards	None None None	Remove Remove Remove				Remove: - Timber battens - Hooks - Timber boards
	M&E Items	Switches Conduit Modern light Plug socket Heating pipes Radiators (removed) Misc. cables Fuse boxes	None None None None Low Low None None	Remove all				Remove: - Switches & Conduit - Modern light - Plug socket - Heating pipes - Radiators (removed) - Cables & Fuse boxes

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.06	Wall Finish(es)	Paint	Low	Remove flaking paint				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 6m2 of plaster missing				
	Floor Finish	Painted concrete	None	None				
	Fixtures & Fittings							
	M&E Items	Heating pipe Switch Plug socket Light	Low None None None	Remove all				Remove: • Heating pipe • Switch • Plug socket • Light

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.07	Wall Finish(es)	Paint	Low	Remove flaking paint				
	Ceiling Finish	Paint	Low	Remove flaking paint				
	Floor Finish	Exposed concrete	N/A	N/A				
	Fixtures & Fittings							
	M&E Items	Light switch Light Plug sockets Heating pipe	None None None Low	Remove all				Remove: • Light switch • Light • Plug sockets • Heating pipe

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.08	Wall Finish(es)	Paint	Low	Remove flaking paint				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 3m2 of plaster missing				
	Floor Finish	Exposed concrete	N/A	N/A				
	Fixtures & Fittings	Mesh vent	None	Remove				Remove: Mesh vent
	M&E Items	Light switch Plug socket Light Heating pipe	None None None Low	Remove all				Remove: - Light switch - Plug socket - Light - Heating pipe

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.09	Wall Finish(es)	Paint	Low	Remove flaking paint				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 9m2 of plaster missing				
	Floor Finish	Exposed concrete	N/A	N/A				
	Fixtures & Fittings	Mesh vent	None	Remove				Remove: Mesh vent
	M&E Items	Light switch Plug socket Light Heating pipe	None None None Low	Remove all				Remove: - Light switch - Plug socket - Light - Heating pipe

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.10	Wall Finish(es)	Paint	Low	Remove flaking paint				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 1m2 of plaster missing				
	Floor Finish	Exposed concrete	N/A	N/A				
	Fixtures & Fittings	Mesh vent	None	Remove				Remove: Mesh vent
	M&E Items	Light switch Plug socket Light Heating pipe	None None None Low	Remove all				Remove: - Light switch - Plug socket - Light - Heating pipe


Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.11	Wall Finish(es)	Paint	Low	Remove flaking paint				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 4m2 of plaster missing				
	Floor Finish	Exposed concrete	N/A	N/A				
	Fixtures & Fittings	Mesh vent	None	Remove				
	M&E Items	Light switch Plug socket Light Heating pipe	None None None Low	Remove all				Remove: • Light switch • Plug socket • Light • Heating pipe



Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.12	Wall Finish(es)	Paint	Low	Remove flaking paint				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 4m2 of plaster missing				
	Floor Finish	Exposed concrete	N/A	N/A				
	Fixtures & Fittings	Mesh vent	None	Remove				Remove: Mesh vent
	M&E Items	Light switch Plug socket Light Heating pipe	None None None Low	Remove all				Remove: - Light switch - Plug socket - Light - Heating pipe



Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.13	Wall Finish(es)	Paint	Low	Remove flaking paint				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 3m2 of plaster missing				
	Floor Finish	Exposed concrete	N/A	N/A				
	Fixtures & Fittings	Mesh vent	None	Remove				
	M&E Items	Light switch Plug socket Light Heating pipe	None None None Low	Remove all				Remove: • Light switch • Plug socket • Light • Heating pipe


Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.14	Wall Finish(es)	Paint	Low	Remove flaking paint				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 4m2 of plaster missing				
	Floor Finish	Exposed concrete	N/A	N/A				
	Fixtures & Fittings	Fire extinguisher bracket Sticker sign	Low None	Remove Remove				Remove: • Fire extinguisher bracket • Sticker sign
	M&E Items	Switches Conduit Modern lights Plug socket Fire alarm Fuse box Heating pipes	None None None None Low None Low	Remove all				Remove: • Switches • Conduit • Modern lights • Plug socket • Fire alarm & Fuse box • Heating pipes

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.15	Wall Finish(es)	Paint White tile	Low None	Remove flaking paint Remove				Remove: White tile
	Ceiling Finish	Paint	Low	Remove flaking paint				
	Floor Finish	Painted concrete	None	Remove flaking paint				
	Fixtures & Fittings	Ceiling pulleys Shower base Boiler cupboard Ventilation hood, grills and ductwork Timber battens	None None None None None	Remove all				Remove: - Ceiling pulleys - Shower base - Boiler cupboard - Ventilation hood, grills and ductwork - Timber battens
	M&E Items	Heating pipes Light switches Conduit Lights	Low None None None	Remove all				Remove: - Heating pipes - Light switches - Conduit - Lights


Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.16	Wall Finish(es)	Paint White tile	Low None	Remove flaking paint Remove				Remove: White tile
	Ceiling Finish	Paint Timber board	Low Low	Remove flaking paint Remove				
	Floor Finish	Modern floor tile	None	Remove				
	Fixtures & Fittings	Sink brackets	None	Remove				Remove: Sink Brakets
	M&E Items	Heating pipes Light Misc. wires Waste pipes	Low None None None	Remove all				Remove: - Heating pipes - Light - Misc. wires - Waste pipes

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.17	Wall Finish(es)	Paint White tile	Low None	Remove flaking paint Remove				Remove: • White tile
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 1m2 of plaster missing				
	Floor Finish	Modern floor tile	None	Remove				
	Fixtures & Fittings	Timber rails / boards Ventilation grill Shower unit	None None None	Remove all				Remove: • Timber rails / boards • Ventilation grill • Shower unit
	M&E Items	Light switch Conduit Lights Heating pipes	None None None Low	Remove all				Remove: • Light switch • Conduit • Lights • Heating pipes

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.18	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Paint	Low	Remove flaking paint				
	Floor Finish	Exposed concrete	N/A	N/A				
	Fixtures & Fittings	Mesh vent	None	Remove				Remove: Mesh vent
	M&E Items	Switch Conduit Light Plug socket Heating pipe	None None None None Low	Remove all				Remove: - Switch - Conduit - Light - Plug socket - Heating pipe

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.19	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Paint	Low	Remove flaking paint				
	Floor Finish	Exposed concrete	N/A	N/A				
	Fixtures & Fittings	Mesh vent	None	Remove				Remove: • Mesh vent
	M&E Items	Switch Conduit Light Plug socket Heating pipe	None None None None Low	Remove all				Remove: • Switch • Conduit • Light • Plug socket • Heating pipe

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.20	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Paint	Low	Remove flaking paint				
	Floor Finish	Exposed concrete	N/A	N/A				
	Fixtures & Fittings	Mesh vent	None	Remove				Remove: Mesh vent
	M&E Items	Switch Conduit Light Plug socket Heating pipe	None None None None Low	Remove all				Remove: - Switch - Conduit - Light - Plug socket - Heating pipe



Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.21	Wall Finish(es)	Paint	Low	Remove flaking paint				
	Ceiling Finish	Paint	Low	Remove flaking paint				
	Floor Finish	Exposed concrete	N/A	N/A				
	Fixtures & Fittings	Mesh vent Timber battens	None None	Remove Remove				Remove: • Mesh vent • Timber battens
	M&E Items	Switch box Light Heating pipes Misc. wire Misc. pipes	None None Low None None	Remove all				Remove: • Switch box • Light • Heating pipes • Misc. wire • Misc. pipes

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.22	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Paint	Low	Remove flaking paint				
	Floor Finish	Exposed concrete	N/A	N/A				
	Fixtures & Fittings	Ceiling hatch	None	Remove				Remove: • Ceiling hatch
	M&E Items	Switch box Light Heating pipes Misc. wire	None None Low None	Remove all				Remove: • Switch box • Light • Heating pipes • Misc. wire

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.23	Wall Finish(es)	Paint	Low	Remove flaking paint				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 2m2 of plaster missing				
	Floor Finish	Exposed concrete	N/A	N/A				
	Fixtures & Fittings	Mesh vent	None	Remove				Remove: Mesh vent
	M&E Items	Switch box Light Heating pipes Plug sockets	None None Low None	Remove all				Remove: - Switch box - Light - Heating pipes - Plug sockets




Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.24	Wall Finish(es)	Paint	Low	Remove flaking paint				
	Ceiling Finish	Paint	Low	Remove flaking paint				
	Floor Finish	Exposed concrete	N/A	N/A				
	Fixtures & Fittings	Mesh vent	None	Remove				Remove: Mesh vent
	M&E Items	Switch box Light Heating pipes Plug sockets	None None Low None	Remove all				Remove: - Switch box - Light - Heating pipes - Plug sockets


Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.25	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Paint	Low	Remove flaking paint				
	Floor Finish	Exposed concrete	N/A	N/A				
	Fixtures & Fittings	Curtain rail and batten Mesh vent	None None	Remove Remove				Remove: • Curtain rail and batten • Mesh vent
	M&E Items	Switch Conduit Light Heating pipes Plug sockets	None None None Low None	Remove all				Remove: • Switch • Conduit • Light • Heating pipes • Plug sockets




Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.26	Wall Finish(es)	Paint	Low	Remove flaking paint				
	Ceiling Finish	Paint	Low	Remove flaking paint				
	Floor Finish	Exposed concrete	N/A	N/A				
	Fixtures & Fittings	Ceiling hatch Mesh vents	None None	Remove Remove				Remove: • Ceiling hatch • Mesh vents
	M&E Items	Switch Conduit Light Plug socket Heating pipe Fire alarm Misc. wires	None None None None Low None None	Remove all				Remove: • Switch • Conduit • Light • Plug socket • Heating pipe • Fire alarm / Misc. wires

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.27	Wall Finish(es)	Wallpaper and large image of lake bled, Slovenia to one wall.	None None	Remove Remove				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 20m2 of plaster missing				
	Floor Finish	Exposed concrete	N/A	N/A				
	Fixtures & Fittings	Radiator brackets	None	Remove				Remove: • Radiator brackets
	M&E Items	Switches Lights Plug sockets Heating pipes Radiators	None None None Low Low	Remove all				Remove: • Switches • Lights • Plug sockets • Heating pipes • Radiators


Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.28	Wall Finish(es)	Paint White tile	Low None	Remove flaking paint Remove				Remove: White tile
	Ceiling Finish	Paint	Low	Remove flaking paint				
	Floor Finish	Paint	Low	Remove flaking paint				
	Fixtures & Fittings	Cistern brackets Sink brackets Timber board Timber battens Shower trays	None None None None None	Remove all				Remove: - Cistern brackets - Sink brackets - Timber board - Timber battens - Shower trays
	M&E Items	Switches Conduit Lights Misc. wires Shaving sockets Heating pipes Ventilation ductwork	None None None None None Low None	Remove all				Remove: - Switches - Conduit - Lights & Misc. wires - Shaving sockets - Heating pipes - Ventilation ductwork

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.29	Wall Finish(es)	Paint	Low	Remove flaking paint				
	Ceiling Finish	Paint	Low	Remove flaking paint				
	Floor Finish	Paint	Low	Remove flaking paint				
	Fixtures & Fittings	Timber battens Fire alarm Fire bell	None Low Low	Remove Remove Remove				Remove: • Timber battens • Fire alarm • Fire bell
	M&E Items	Switch Conduit Light Heating pipes Plug socket	None None None Low None	Remove all				Remove: • Switch • Conduit • Light • Heating pipes • Plug socket

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.30	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 8m2 of plaster missing				
	Floor Finish	Paint	Low	Remove flaking paint				
	Fixtures & Fittings	Ceiling hatch Radiator brackets Timber boxing in	None None None	Remove Remove Remove				Remove: • Ceiling hatch • Radiator brackets • Timber boxing in
	M&E Items	Light switch Lights Plug socket Misc. cables Heating pipes Radiators Waste pipe	None None None None Low Low None	Remove all				Remove: • Light switch • Lights & Plug socket • Misc. cables • Heating pipes & Radiators • Waste pipe


Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.31	Wall Finish(es)	Painted brick	None	Remove flaking paint				
	Ceiling Finish							
	Floor Finish	Red clay tile Exposed concrete	Low N/A	Retain N/A				
	Fixtures & Fittings	Large wall brackets Drying unit Misc. equipment Timber boards Metal wall and floor mount	None High Low None None	Remove Retain Remove Remove Remove				Remove: • Large wall brackets • Misc. equipment • Timber boards • Metal wall & floor mount RETAIN: DRYING UNIT
	M&E Items	Switches Misc. electrical items Conduit Early light	None None None High	Remove Remove all Remove Retain				Remove: • Switches • Misc. electrical items • Conduit

Room Reference	Element	Description	Significance	Removed or Retained	Photographs	Allied London Phase 1A Requirements
3.32	Wall Finish(es)	See 2.36				
	Ceiling Finish					
	Floor Finish					
	Fixtures & Fittings					
	M&E Items					

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.33	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	N/A	N/A	12m2 of plaster missing				
	Floor Finish	Wood block Glazed tile	High Low	Retain Retain				
	Fixtures & Fittings							
	M&E Items	Early light switch Conduit Light Misc. cables Heating pipes Plug socket	Low None None None Low None	Remove all				Remove: • Early light switch • Conduit • Light • Misc. cables • Heating pipes • Plug socket

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.34	Wall Finish(es)	Paint	Low	Remove flaking paint				
	Ceiling Finish	N/A	N/A	13m2 of plaster missing				
	Floor Finish	Wood block (lifted) Glazed tile	High Low	Retain Retain				
	Fixtures & Fittings	Light switch mount	None	Remove				Remove: Light switch mount
	M&E Items	Conduit	None	Remove				Remove: Conduit

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.35	Wall Finish(es)	Wallpaper Paint	None Low	Remove Remove flaking paint				
	Ceiling Finish	Ceiling paper	None	Remove Approx. 1m2 of plaster missing				
	Floor Finish	Red clay tile White tile	Low Low	Retain Retain				
	Fixtures & Fittings							
	M&E Items	Switches Conduit Light Misc. wires	None None None None	Remove all				Remove: • Switches • Conduit • Light • Misc. wires

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.36	Wall Finish(es)	Paint Timber boards	Low Low	Remove flaking paint Remove				Remove: Timber boards
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 3m2 of plaster missing				
	Floor Finish	Red clay tile	Low	Retain				
	Fixtures & Fittings	Shelves Brackets Timber boards	None None None	Remove Remove Remove				Remove: - Shelves - Brackets - Timber boards
	M&E Items	Switch Cable Light Gas pipe	None None None Low	Remove Remove Remove Remove				Remove: - Switch - Cable - Light - Gas pipe

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.37	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Plasterboard	None	Remove				
	Floor Finish	Wood block Glazed tile	High Low	Retain Retain				
	Fixtures & Fittings							
	M&E Items							

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.38	Wall Finish(es)	Wallpaper Paint	None Low	Remove Remove flaking paint				
	Ceiling Finish	Plasterboard	None	Remove				
	Floor Finish	Wood block Glazed tile	High Low	Retain Retain				
	Fixtures & Fittings							
	M&E Items	Early switch	Low	Remove				Remove: Early switch

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.39	Wall Finish(es)	Wallpaper Paint White tile	None Low None	Remove Remove flaking paint Remove				Remove: White tile
	Ceiling Finish	Ceiling tile	None	Remove				Remove: Ceiling tile
	Floor Finish	Red clay tile	Low	Retain				
	Fixtures & Fittings	Timber cupboards Timber boards Cistern brackets	None None None	Remove Remove Remove				Remove: - Timber cupboards - Timber boards - Cistern brackets
	M&E Items	Misc. wires Light	None None	Remove Remove				Remove: - Misc. wires - Light

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.40	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Paint	Low	Remove flaking paint				
	Floor Finish	Red clay tile	Low	Retain				
	Fixtures & Fittings	Timber cupboard Suspended ceiling rail	None None	Remove Remove				Remove: • Timber cupboard • Suspended ceiling rail
	M&E Items	Misc. Electrical equipment and wires Fire alarm bell Misc. cables Wall light Gas pipe	None Low None None Low	Remove all				Remove: • Misc. Electrical equipment and wires • Fire alarm bell • Misc. cables • Wall light • Gas pipe

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.41	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Ceiling paper	None	Remove Approx. 4m2 of plaster missing				
	Floor Finish	Red clay tile White tile	Low Low	Retain Retain				
	Fixtures & Fittings							
	M&E Items	Early light switch Conduit Light Plug socket and wires	Low None None None	Remove all				Remove: • Early light switch • Conduit • Light • Plug socket and wires

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.42	Wall Finish(es)	Paint	Low	Remove flaking paint				
	Ceiling Finish	Plasterboard	None	Remove				
	Floor Finish	Wood block Glazed tile	High Low	Retain Retain				
	Fixtures & Fittings							
	M&E Items	Plug sockets and wires	None	Remove				Remove: Plug sockets and wires

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.43	Wall Finish(es)	Wallpaper White tile	None None	Remove Remove				Remove: White tile
	Ceiling Finish	Ceiling tile	None	Remove Approx. 1m2 of plaster missing				Remove: Ceiling tile
	Floor Finish	Red clay tile	Low	Retain				
	Fixtures & Fittings							
	M&E Items	Switches including 1no. Early switch Vent-Axia control Light Misc. wires Plug sockets	None / low None None None None	Remove all				Remove: - Switches including 1no. - Early switch - Vent-Axia control - Light - Misc. wires - Plug sockets

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.44	Wall Finish(es)	Wallpaper Paint	None Low	Remove Remove flaking paint				
	Ceiling Finish	Plasterboard	None	Remove				
	Floor Finish	Wood block White tile	High Low	Retain				
	Fixtures & Fittings							
	M&E Items	Early switch Conduit Plug socket and wires Waste pipe	Low None None None	Remove all				Remove: • Early switch • Conduit • Plug socket and wires • Waste pipe

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.45	Wall Finish(es)	Wallpaper Paint	None Low	Remove Remove flaking paint				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 4m2 of plaster missing				
	Floor Finish	Wood block Glazed tile	High Low	Retain Retain				
	Fixtures & Fittings	Timber switch mount	None	Remove				Remove: Timber switch mount
	M&E Items	Conduit Plug socket Gas outlet	None None None	Remove Remove Remove				Remove: - Conduit - Plug socket - Gas outlet

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.46	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 2m2 of plaster missing				
	Floor Finish	Wood block Glazed tile	High Low	Retain Retain				
	Fixtures & Fittings							
	M&E Items	Light switch Conduit Plug socket	None None None	Remove all				Remove: • Light switch • Conduit • Plug socket

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.47	Wall Finish(es)	None, exposed plaster	N/A	N/A				
	Ceiling Finish	Plasterboard	None	Remove				
	Floor Finish	Wood block Glazed tile	High Low	Retain Retain				
	Fixtures & Fittings							
	M&E Items	Light switch Conduit Plug socket	None None None					Remove: • Light switch • Conduit • Plug socket

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.48	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Ceiling tile	None	Remove				Remove: Ceiling tile
	Floor Finish	Red clay tile	Low	Retain				
	Fixtures & Fittings	Timber battens Timber boards	None None	Remove Remove				Remove: - Timber battens - Timber boards
	M&E Items							

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.49	Wall Finish(es)	Paint	Low	Remove flaking paint				
	Ceiling Finish	Paint	Low	Remove flaking paint				
	Floor Finish	Red clay tile	Low	Retain				
	Fixtures & Fittings	Timber boards Shelf Ceiling hatch	None None None	Remove Remove Remove				Remove: • Timber boards • Shelf • Ceiling hatch
	M&E Items	Misc. electrical items Early switch Gas pipe	None Low Low	Remove all				Remove: • Misc. electrical items • Early switch • Gas pipe

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.50	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Paint	Low	Remove flaking paint				
	Floor Finish	Red clay tile White tile	Low Low	Retain Retain				
	Fixtures & Fittings	Timber boards	None	Remove				Remove: Timber boards
	M&E Items	Switch Conduit Light Misc. cables	None None None None	Remove all				Remove: - Switch - Conduit - Light - Misc. cables

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.51	Wall Finish(es)	Paint	Low	Remove flaking paint				
	Ceiling Finish	Plasterboard	None	Remove				
	Floor Finish	Wood block (lifted)	High	Retain				
	Fixtures & Fittings							
	M&E Items							

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.52	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Ceiling paper	None	Remove				
	Floor Finish	Wood block (lifted)	High	Retain				
	Fixtures & Fittings							
	M&E Items	Light switch Conduit Light Gas outlet	None None None None	Remove all				Remove: • Light switch • Conduit • Light • Gas outlet

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.53	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Plasterboard	None	Remove				
	Floor Finish	Wood block Glazed tile	High Low	Retain Retain				
	Fixtures & Fittings							
	M&E Items	Early light switch Misc. wires	Low None	Remove all				Remove: • Early light switch • Misc. wires

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.54	Wall Finish(es)	Paint	Low	Remove flaking paint				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 1m2 of plaster missing				
	Floor Finish	Red clay tile	Low	Retain				
	Fixtures & Fittings	Shelf	None	Remove				Remove: Shelf
	M&E Items							


Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.55	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Paint	Low	Remove flaking paint				
	Floor Finish	Red clay tile	Low	Retain				
	Fixtures & Fittings	Ceiling hatch	Low	Remove				Remove: Ceiling hatch
	M&E Items	Early light switch Conduit Misc. electrical items Gas pipe	Low None None Low	Remove all				Remove: - Early light switch - Conduit - Misc. electrical items - Gas pipe


Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.56	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 4m2 of plaster missing				
	Floor Finish	Red clay tile White tile	Low Low	Retain Retain				
	Fixtures & Fittings							
	M&E Items	Light switch Plug socket Ceiling light pendant	None None None	Remove all				Remove: • Light switch • Plug socket • Ceiling light pendant

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.57	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Paint	Low	Remove flaking paint				
	Floor Finish	Wood block Glazed tile	High Low	Retain Retain				
	Fixtures & Fittings							
	M&E Items	Conduit Plug socket	None None	Remove all				Remove: • Conduit • Plug socket

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.58	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Plasterboard	None	Remove				
	Floor Finish	Wood block Glazed tile	High Low	Retain Retain				
	Fixtures & Fittings							
	M&E Items							

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.59	Wall Finish(es)	Wallpaper White tile	None None	Remove Remove				Remove: White tile
	Ceiling Finish	Ceiling paper Paint	None None	Remove Remove flaking paint Approx. 4m2 of plaster missing				
	Floor Finish	Red clay tile	Low	Retain				
	Fixtures & Fittings	Timber batten	None	Remove				Remove: Timber batten
	M&E Items	Switches Conduit Plug socket	None None None	Remove all				Remove: - Switches - Conduit - Plug socket

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.60	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Paint	Low	Remove flaking paint				
	Floor Finish	Red clay tile	Low	Retain				
	Fixtures & Fittings							
	M&E Items	Early light switch Conduit Light	Low None None	Remove all				Remove: • Early light switch • Conduit • Light


Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.61	Wall Finish(es)	Wallpaper Tiles	None None	Remove Remove				Remove: • Tiles
	Ceiling Finish	Ceiling tile	None	Remove Approx. 1m2 of plaster missing				Remove: • Ceiling tiles
	Floor Finish	Floor tile over red clay tile	None / low	Remove floor tile and adhesive, retain red clay tile				
	Fixtures & Fittings	Timber board Timber cupboard	None None	Remove Remove				Remove: • Timber board • Timber cupboard
	M&E Items	Conduit Misc. wires	None None	Remove all				Remove: • Conduit • Misc. wires

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.62	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Ceiling paper Paint	None None	Remove Remove flaking paint Approx. 6m2 of plaster missing				
	Floor Finish	Wood block Glazed tile	High Low	Retain Retain				
	Fixtures & Fittings	Timber board	None	Remove				Remove: Timber board
	M&E Items	Conduit Light	None None	Remove all				Remove: - Conduit - Light

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.63	Wall Finish(es)	Paint	Low	Remove flaking paint				
	Ceiling Finish	N/A	N/A	12m2 of plaster missing				
	Floor Finish	Wood block Glazed tile	High Low	Retain Retain				
	Fixtures & Fittings							
	M&E Items	Conduit	None	Remove				Remove: Conduit

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.64	Wall Finish(es)	Wallpaper Yellow tiles	None None	Remove Remove				Remove: Yellow tiles
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 5m2 of plaster missing				
	Floor Finish	Red clay tile	Low	Retain				
	Fixtures & Fittings							
	M&E Items	Light	None	Remove				Remove: Light

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.65	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Ceiling paper	None	Remove Approx. 5m2 of plaster missing				
	Floor Finish	Wood block (lifted and stored in 3.66) Glazed tile	High Low	Retain Retain				
	Fixtures & Fittings							
	M&E Items	Conduit	None	Remove				Remove: • Conduit

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.66	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Paint	Low	Remove flaking paint				
	Floor Finish	Red clay tile	Low	Retain				
	Fixtures & Fittings	Timber batten	None	Remove				Remove: Timber batten
	M&E Items	Conduit Misc. wires	None None	Remove all				Remove: - Conduit - Misc. wires

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.67	Wall Finish(es)	Wallpaper Paint	None Low	Remove Remove flaking paint				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 1m2 of plaster missing				
	Floor Finish	Wood block	High	Retain				
	Fixtures & Fittings	Radiator brackets	None	Remove				Remove: Radiator Brackets
	M&E Items	Heating pipes Radiators Modern lights	Low Low None	Remove all				Remove: - Heating pipes - Radiators - Modern lights

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.68	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 8m2 of plaster missing				
	Floor Finish	Wood block	High	Retain				
	Fixtures & Fittings	Radiator brackets	None	Remove				Remove: Radiator Brackets
	M&E Items	Heating pipes Plug socket	Low None	Remove all				Remove: - Heating pipes - Plug socket

Room Reference	Element	Description	Significance	Removed or Retained	Photographs			Allied London Phase 1A Requirements
3.69	Wall Finish(es)	Wallpaper	None	Remove				
	Ceiling Finish	Paint	Low	Remove flaking paint Approx. 4m2 of plaster missing				
	Floor Finish	Wood block (lifted) Glazed tile	High Low	Retain Retain				
	Fixtures & Fittings							
	M&E Items	Switch Conduit Misc. wires	None None None	Remove all				Remove: • Switch • Conduit • Misc. wires