

Block Compliance WorkSheet: The Plaza, South Block (As Built)

User Details

Assessor Name:

Software Name: Stroma FSAP

Stroma Number:

Software Version:

Version: 1.0.4.16

Calculation Details

Dwelling	DER	TER	DFEE	TFEE	TFA
G01	23.1	23.72	38.2	47.1	96
G02	25.06	25.49	36.2	42.2	62
G03	25.06	25.49	36.2	42.2	62
G04	25.06	25.49	36.2	42.2	62
101	19.09	23.85	30.1	47.6	96
102	19.75	22	24.6	30.5	62
103	19.75	22	24.6	30.5	62
104	20.26	24.12	24.4	30.3	47
105	22.3	25.59	32.5	46.8	73
201	28.16	28.8	44.4	56.1	65
202	17.98	21.48	18.1	23.8	52
203	17.89	19.88	18.2	23.7	64
204	20.11	24.12	24.2	30.3	47
205	21.97	23.77	31.8	40.7	73
206	19.19	21.09	22.7	30.3	67
207	20.98	23.21	27.2	37.1	64
301	28.06	28.8	44.2	56.1	65
302	17.98	21.48	18.1	23.8	52
303	17.89	19.88	18.2	23.7	64
304	20.11	24.12	24.2	30.3	47
305	19.6	21.87	26.5	34.3	73
306	18.53	20.4	20.9	27.9	67
307	20.49	21.91	25.9	32.7	64
401	24.2	25.26	40.5	51.8	89
402	17.76	19.75	18.1	23.6	65
403	20.11	24.12	24.2	30.3	47

Block Compliance WorkSheet: The Plaza, South Block (As Built)

Dwelling	DER	TER	DFEE	TFEE	TFA
404	19.6	21.87	26.5	34.3	73
405	18.53	20.4	20.9	27.9	67
406	20.49	21.91	25.9	32.7	64
501	26.27	27.29	43.3	54.1	74
502	18.1	20.12	18.6	24.2	63
503	20.11	24.12	24.2	30.3	47
504	19.6	21.87	26.5	34.3	73
505	18.53	20.4	20.9	27.9	67
506	20.5	21.91	25.9	32.7	64
601	27.17	27.79	43.2	54.5	70
602	18.77	22.31	19.9	25.9	49
603	19.95	24.12	24.1	30.3	47
604	19.6	21.87	26.5	34.3	73
605	18.53	20.4	20.9	27.9	67
606	20.49	21.91	25.9	32.7	64
701	21.4	23.49	37.6	50.5	109
702	20.11	24.12	24.2	30.3	47
703	19.6	21.87	26.5	34.3	73
704	18.53	20.4	20.9	27.9	67
705	20.49	21.91	25.9	32.7	64
801	25.79	29.46	43.2	65.2	88
802	22.95	29.79	31	49.4	47
803	23.03	28.35	34	56.1	73
804	18.53	20.4	20.9	27.9	67
805	20.49	21.91	25.9	32.7	64
901	17.78	21.2	24.5	36.9	89
902	20.4	21.91	25.8	32.7	64
1001	21.23	26.08	32.3	53.4	89
1002	24.3	27.22	34.4	50.5	64

Block Compliance WorkSheet: The Plaza, South Block (As Built)

Calculation Summary

Total Floor Area	3654.00
Average TER	23.38
Average DER	21.03
Average DFEE	28.50
Average TFEE	37.86
Compliance	Pass
% Improvement DER TER	10.05
% Improvement DFEE TFEE	24.72