

From: **Mohammed Sultan** < >
Date: Mon, 6 Jan 2020 at 14:44
Subject: FW: App. 125399 - Unit 1, 1 Portland Street
To: Carolyn Parry < >
Cc: Players® UK < >

Dear Carolyn

Please see email below regarding points 5,6 from Environmental Health

Should you require additional information please do not hesitate to contact us

Regards,

**Mohammed Sultan Malik (MArch)
Architecture & Interior Design**

Please note that the views and opinions expressed in this email are those of the sender and not necessarily those of Architecture & Interior Design. The contents of this email are confidential to the intended recipient at the email address to which it has been addressed. It may not be disclosed to or used by anyone other than this addressee, nor may it be copied in any way. If received in error, please contact Architecture & Interior Design on 0121 783 6211 quoting the name of the sender and the addressee and then delete it from your system. Please note that neither Architecture & Interior Design nor the sender accepts any responsibility for viruses and it is your responsibility to scan the email and attachments (if any). Architecture & Interior Design is located at 17 Coleshill Road, Birmingham B36 8DT.

From: Players® UK [mailto]
Sent: 06 January 2020 14:01
To: Mohammed Sultan < >; Gulraiz Siddique < >
Subject: Fwd: App. 125399 - Unit 1, 1 Portland Street

Sent from my iPhone

Begin forwarded message:

From: David Thurstan < >
Date: 6 January 2020 at 13:49:56 GMT
To: Players® UK < >
Subject: RE: **App. 125399 - Unit 1, 1 Portland Street**

Hi Kay

Happy New Year to you too.

Thanks for your email, Environmental Health have generally accepted our assessment. As discussed here are the recommended maximum permissible music levels for this site. These levels are based on the assumed trading noise levels set out in our report but have been reduced by 5 dB. This

accounts for the fact that the measured trading noise levels include both background music and customer noise.

Table: Maximum permissible music levels (dB)

Description	Octave Band Centre Frequency (Hz)						
	63	125	250	500	1k	2k	4k
Music Level (L_{eq})	59	64	65	70	68	65	58

The proposed conditions require verification testing upon completion, I would be happy to provide a quote to carry out this testing.

Kind Regards
David

David Thurstan BSc MIOA
Senior Consultant

21 Little Peter Street, Manchester M15 4PS
hepworth-acoustics.co.uk