Good afternoon Tim,

I have filled a full video of the paths directly around site along with the road and paths across the street – due to the size it wont let me send it.

I have done a report below of what the current condition of the path is in;

Chorlton Street
The path that is directly outside site to the entrance is in a bad condition with many broken and loose slabs and curbs

- Cracked slabs – 11
- Loose slabs – 9
- Damaged curbs – 16
- Loose curbs – 0
- Damaged covers – 2

Bloom Street
The footpath on the Bloom Street side is in an even worse state;

- Cracked slabs – 15
- Loose slabs – 13
- Damaged curbs – 9
- Loos curbs – 5
- Damaged covers – 0

The blocks at either side of the big double doors have sank in various places and around 6 area cracked, all could do with being reset. Both paths on Bloom and Chorlton street have sunk in various places and all curbs have suffered impact damage from heavy traffic.

Regards

Daniel Ormerod | Assistant Site Manager