Ralph Taylor

From: Geoff Kennedy <geoff.kennedy@swan-projects.com>
Sent: 28 June 2017 15:11
To: 'Paul Astill (paul@astillassociates.com)'
Cc: Ralph Taylor
Subject: The Bay Horse, Thomas Street

Good afternoon Paul,
When designing the proposed kitchen ventilation system to The Bay Horse, Thomas Street, it was clear that if the kitchen extract discharge duct had terminated 1.0m above the eaves, it would still have been lower than the eaves of adjoining premises, so the decision was made to incorporate full odour control, with UV module, ESP filter module and carbon filters, so that kitchen ventilation discharge can be accommodated at low level, at the rear courtyard.

If you require any further information. Please do not hesitate to contact me

Kind regards

Geoff Kennedy
SWAN Projects

38 Stanway Road
Whitefield
Manchester
M45 8FX

Tel: 0161 300 3465
Fax: 0161 959 2093
Mob: 07557 337754
E mail: geoff@swan-projects.com
Web: swan-projects.com

This e-mail is intended for the addressees named above and any other use is prohibited. Access to this e-mail by anyone else is unauthorised. It may contain confidential information. If you have received this e-mail in error, please notify the sender by return e-mail. SWAN Projects does not accept legal responsibility for the contents of this message, if it has reached you via the internet. Any opinions expressed are those of the author and not necessarily endorsed by SWAN Projects. Recipients are advised to apply their own virus check to this message and all incoming e-mails upon delivery.