Our Ref: HT: 17852/ROW

27 June 2013

Hann Tucker Associates
Consultants in Acoustics
Noise and Vibration Control

First Floor 346 Deansgate
Manchester M3 4LY

(T) +44 (0)161 832 7041
(F) +44 (0)161 832 8075
(E) enquiries@hanntucker.co.uk
(W) www.hanntucker.co.uk

Directors:
Stuart G Morgan CEng MIMechE MCIBSE FIOA (Chairman)
Simon R Hancock BEng(Hons) CEng MCIBSE FIOA (Managing)
John L Gibbs MIOA(D) MSEE CEnv
John R Ridpath BSc(Hons) MIOA

Associates:
Teli Chinelis BSc(Hons) PgDip CEng MIOA
Robin O Wood BEng(Hons) MIOA
Andrew D Fermer BSc(Hons) MIOA
Andrew G Jameson BSc(Hons) MIOA

Phil Westwood
TelecityGroup
9th Floor
6&7 Harbour Exchange Square
London
E14 9GE

By email only at:
phil.westwood@telecity.com

Dear Phil

RE: SYNERGY HOUSE, MANCHESTER SCIENCE PARK MANCHESTER CITY COUNCIL QUERIES

Further to Manchester City Council's memo dated 26 June 2013 we provide the following responses to the queries raised with our Environmental Noise Survey and Plant Noise Assessment Report 17852/PNA1 Revision 5 dated 3 May 2013.

> *"Regarding the non emergency plant described in the acoustic report by Hann Tucker Associates dated 3 May 2013, no sensitive noise receptors have been identified in the Science Park other than Unit 3. Clarification is needed regarding the other units in the Science Park and why they have not been identified as potential sensitive noise receptors."*

Unit 3 has been assessed to since this is immediately adjacent to the proposed non-emergency plant and is occupied by others. Units 1 and 6 are immediately adjacent to the other 2No. areas of proposed non-emergency plant, however, these units are unoccupied data center spaces occupied by Telecity Group and as such have not been assessed to.

> *"Finally, there has been no information regarding the resiting of the 2 dual fan units and Environmental Health need further details to ensure this will not impact any sensitive noise receptors."*

Our report details the 2 dual fan units (referenced as Group B) in the new location and considers them in the noise assessment to the nearest noise sensitive receptors.

We trust the above to be clear and of assistance, however, should you have any queries please do not hesitate to contact us.

Yours sincerely
for HANN TUCKER ASSOCIATES

Robin Wood