


SMOKE DETECTION

PROVIDE A LINKED SMOKE ALARM DETECTION SYSTEM TO BS EN 14600, AND BS 5839-6:2019 TO AT LEAST A GRADE D2 (GRADE A FOR LARGE HOUSES) CATEGORY LD2 STANDARD. SYSTEM TO BE MAINS POWERED WITH BATTERY BACK UP. SMOKE DETECTORS TO BE PROVIDED TO:

- EACH HALLWAY AND LANDING
- EVERY PRINCIPAL LIVING ROOM (AS REQUIRED BY THE BUILDING CONTROL OFFICER)
- AN INTERLINK HEAT DETECTOR TO BE PROVIDED IN THE KITCHEN

IN HALLWAYS EXCEEDING 1.5M IN LENGTH, NO POINT WITHIN THE HALLWAY SHOULD EXCEED 7.5M FROM THE NEAREST DETECTOR AND NO BEDROOM DOOR SHOULD BE FURTHER THAN 3M FROM THE NEAREST SMOKE ALARM. IF CEILING MOUNTED DETECTORS TO BE 300MM FROM THE WALLS AND LIGHT FITTINGS.



PROPOSED SINGLE STOREY REAR EXTENSION			
		LDM Design	
PROJECT : 27 Wynne Close, Manchester M11 3TR			
SHEET : Proposed Drawings			
CLIENT : Mrs Moo Hing Lang			
Scale (at A1) :		As indicated	
Drawn by :	RI	DRAWING NUMBER :	REV :
Checked by :	KK	27W_A1_ZZ_ZZ_DR_301	A