

PP Condition 18 – EV Charging Details

Bruntwood Employer Requirements:

- Procurement, supply, installation and testing of 2no single phase 7kW EV chargers -
Chargers to have RFID readers and fobs
 - Project EV 7.3kW or Bruntwood approved similar
- Provision of metering panel adjacent to DB, including 2no direct connect power meters with Modbus connectivity, panel to allow space for future meter installations for future EV points.
- Connection of the 2no meters to the sitewide meter network and integration & programming into the sites BMS.
- Secondary containment shall be perforated medium-duty tray with brackets, metal tie wraps.